

LONDON WC CLERKENWELL, United Kingdom

WMO: 037790

Lat: 51.522N

Lon: 0.112W

Elev: 128

StdP: 14.63

Time Zone: 0.00 (EUW)

Period: 94-10

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	30.8	32.8	19.7	14.8	38.3	22.3	16.8	38.4	24.6	46.0	22.8	47.0	9.8	50	0.531

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	13.3	83.2	65.2	79.6	63.9	76.4	62.5	67.1	78.5	65.6	75.8	64.2	73.5	8.8	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.0	86.5	71.1	61.6	82.3	70.0	60.3	78.4	68.8	31.6	78.1	30.5	76.0	29.4	73.7	79.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.7	18.5	16.5	DB	28.3	89.1	2.2	3.2	26.7	91.4	25.5	93.3	24.2	95.1	22.6	97.4	(4)
(5)			WB	26.1	71.2	2.1	3.0	24.6	73.3	23.4	75.0	22.3	76.7	20.7	78.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	54.3	43.7	44.6	47.5	51.7	57.3	62.8	66.5	66.6	61.5	55.6	49.3	44.1
	DBStd	9.82	5.61	5.50	5.28	5.63	5.73	5.14	4.95	4.91	4.42	4.82	4.97	5.87
	HDD50	812	204	162	110	48	7	0	0	0	0	11	72	198
	HDD65	4134	661	572	542	399	248	101	41	35	122	293	472	648
	CDD50	2387	8	10	32	99	233	384	510	516	346	184	50	15
	CDD65	236	0	0	0	0	9	35	86	86	19	1	0	0
	CDH74	1248	0	0	0	1	54	221	456	448	67	1	0	0
	CDH80	275	0	0	0	0	5	49	99	116	6	0	0	0
Wind	WSAvg	9.0	10.3	10.0	9.7	9.0	9.1	8.7	8.3	8.0	8.2	9.0	8.5	9.4
Precipitation	PrecAvg	23.1	2.0	1.3	1.8	1.7	1.9	1.9	1.7	1.9	2.2	2.4	2.2	2.1
	PrecMax	31.5	5.0	3.5	3.9	4.2	3.5	4.2	3.6	4.6	5.7	5.4	5.5	4.4
	PrecMin	17.2	0.4	0.3	0.2	0.4	0.0	0.2	0.4	0.3	0.2	0.1	0.7	0.5
	PrecStd	3.4	1.1	0.7	0.9	0.9	1.0	1.2	0.9	1.1	1.5	1.7	1.2	1.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	57.2	58.8	63.8	71.5	79.1	85.6	87.0	87.8	80.5	71.3	61.6	58.0
		MCWB	53.0	51.4	52.9	57.1	60.9	66.5	66.5	67.3	64.2	62.4	56.8	53.9
	2%	DB	55.1	55.6	59.9	67.3	74.8	79.8	82.8	83.1	75.3	66.3	59.4	56.3
		MCWB	51.0	50.4	50.3	53.5	59.9	63.5	64.8	65.1	62.7	58.9	55.1	52.6
	5%	DB	53.3	53.7	57.4	63.6	71.1	75.6	79.2	78.9	71.2	64.1	57.9	54.8
		MCWB	49.6	48.8	49.5	52.3	57.8	61.5	63.8	64.4	60.8	58.1	53.6	51.2
	10%	DB	51.6	52.1	55.1	60.5	67.1	72.2	75.7	75.1	68.5	62.3	56.4	52.9
		MCWB	48.0	47.6	48.8	50.8	56.2	59.8	62.3	63.0	59.2	57.0	52.2	49.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.8	53.3	54.5	58.6	64.0	67.5	69.1	69.8	66.2	62.9	58.1	54.9
		MCDB	56.5	56.7	60.7	68.5	74.9	81.7	82.0	85.1	76.1	68.6	60.5	57.0
	2%	WB	51.7	51.3	52.6	55.8	61.2	64.8	66.8	67.3	64.4	60.8	55.9	53.3
		MCDB	54.7	54.6	57.4	63.9	71.2	76.4	78.4	78.0	72.0	64.6	58.8	55.9
	5%	WB	50.0	49.6	51.2	53.5	58.9	62.9	65.3	65.8	62.6	59.3	54.3	51.6
		MCDB	53.0	53.0	55.7	60.5	68.8	72.9	75.8	75.3	68.7	63.0	57.5	54.5
	10%	WB	48.3	48.0	49.7	51.9	57.0	61.2	63.7	64.3	61.0	57.8	52.6	49.5
		MCDB	51.3	51.3	54.1	59.0	65.7	70.3	73.5	73.0	66.8	61.7	55.9	52.6
Mean Daily Temperature Range	5% DB	MDBR	7.1	8.2	10.0	12.4	13.3	13.6	13.8	13.3	11.6	9.6	7.7	6.8
		MCDBR	8.4	9.4	13.4	17.1	19.5	19.3	18.8	18.9	15.4	10.8	7.8	7.6
		MCWBR	8.2	7.2	7.3	7.9	8.8	8.5	7.1	6.7	6.6	6.6	6.7	7.6
	5% WB	MCDBR	8.2	8.8	11.0	14.8	17.8	16.9	16.5	16.4	13.3	10.2	7.8	7.9
		MCWBR	8.5	8.0	7.6	7.9	8.9	8.5	7.6	7.0	7.5	7.7	7.5	8.2
Clear-Sky Solar Irradiance	taub	0.331	0.346	0.383	0.404	0.409	0.410	0.406	0.396	0.378	0.361	0.334	0.320	
	taud	2.372	2.375	2.267	2.228	2.254	2.278	2.296	2.342	2.391	2.421	2.416	2.357	
	Ebn at Noon	214	245	255	264	268	268	267	264	255	236	211	196	
	Edh at Noon	20	26	34	40	41	40	39	35	30	24	19	17	
All-Sky Solar Radiation	RadAvg	254	463	810	1269	1527	1691	1603	1334	1004	580	304	199	
	RadStd	22	64	108	138	102	157	153	107	84	53	35	25	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (81 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page