

SHEERNESS, United Kingdom

WMO: 037910

Lat: 51.446N

Lon: 0.746E

Elev: 25

StdP: 101.03

Time Zone: 0.00 (EUW)

Period: 94-08

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -0.5	(c) 0.5	(d) -4.3	(e) 2.6	(f) 2.8	(g) -3.2	(h) 2.9	(i) 2.8	(j) 19.5	(k) 11.3	(l) 17.8	(m) 8.2	(n) 6.3	(o) 300	(p) 0.676

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 4.8	(c) 24.8	(d) 18.7	(e) 23.1	(f) 18.3	(g) 21.9	(h) 17.6	(i) 20.0	(j) 23.2	(k) 19.2	(l) 22.1	(m) 18.4	(n) 21.2	(o) 4.9	(p) 240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.7	13.6	21.7	18.0	13.0	21.0	17.2	12.3	20.4	57.2	23.3	54.7	22.3	52.3	21.2	23.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 15.1	(b) 13.5	(c) 12.4	(e) -1.8	(f) 29.0	(g) 1.3	(h) 1.3	(i) -2.7	(j) 29.9	(k) -3.5	(l) 30.7	(m) -4.3	(n) 31.4	(o) -5.2	(p) 32.4		
(a) 15.1	(b) 13.5	(c) 12.4	(e) -2.5	(f) 21.5	(g) 1.1	(h) 1.3	(i) -3.3	(j) 22.4	(k) -3.9	(l) 23.2	(m) -4.6	(n) 23.9	(o) -5.4	(p) 24.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	11.6	6.3	6.4	7.6	9.6	12.6	15.9	18.0	18.4	16.0	12.9	9.1	6.4		
	DBStd	5.15	2.89	2.80	2.80	2.72	2.57	2.48	2.29	2.21	2.14	2.48	2.72	3.04		
	HDD10.0	522	118	104	84	39	7	0	0	0	0	6	47	116		
	HDD18.3	2515	374	336	334	262	177	81	33	27	76	170	276	369		
	CDD10.0	1114	3	2	8	27	88	177	249	259	178	94	21	5		
	CDD18.3	66	0	0	0	0	1	8	24	28	4	1	0	0		
	CDH23.3	137	0	0	0	0	5	23	43	60	6	0	0	0		
	CDH26.7	14	0	0	0	0	1	3	3	7	1	0	0	0		
(14) Wind	WSAvg	6.2	7.4	7.0	6.7	5.8	6.0	5.6	5.5	5.3	5.6	6.2	6.0	6.8		
(15) Precipitation	PrecAvg	707	72	54	41	50	49	50	44	58	59	75	85	69		
	PrecMax	1005	165	131	108	127	108	126	85	117	131	211	177	132		
	PrecMin	523	18	12	6	6	11	15	10	11	10	11	33	9		
	PrecStd	111	34	32	22	30	25	32	20	31	32	43	41	35		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.3	13.7	15.2	19.2	22.6	25.8	27.0	27.6	23.8	19.9	16.1	13.7		
		MCWB	10.7	10.7	11.5	13.8	16.0	18.5	19.4	20.0	18.1	16.2	14.0	12.0		
	2%	DB	12.2	12.0	13.5	16.4	19.3	22.9	24.4	24.8	21.3	18.2	14.7	12.9		
		MCWB	10.3	10.0	10.4	12.4	15.0	17.3	18.8	19.2	17.3	15.6	12.9	11.4		
	5%	DB	11.3	11.1	12.4	14.7	17.5	21.1	22.9	23.0	20.0	17.2	13.9	12.0		
		MCWB	9.7	9.3	9.8	11.1	13.7	16.7	18.4	18.7	16.7	15.1	12.1	10.5		
	10%	DB	10.3	10.2	11.4	13.5	16.2	19.7	21.6	21.7	19.1	16.3	13.0	10.9		
		MCWB	8.8	8.4	9.2	10.6	13.1	15.7	17.6	17.9	16.2	14.4	11.2	9.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.4	11.2	12.2	14.6	17.1	19.4	20.9	21.4	19.2	17.1	14.5	12.6		
		MCDB	12.6	12.8	14.2	18.0	20.2	24.3	24.3	25.7	21.6	19.0	15.7	13.4		
	2%	WB	10.6	10.4	11.1	13.0	15.3	18.2	19.8	20.2	18.2	16.2	13.3	11.5		
		MCDB	11.9	11.8	12.9	15.8	18.2	21.7	23.0	23.3	20.3	17.6	14.5	12.6		
	5%	WB	9.9	9.6	10.3	11.8	14.3	17.2	19.1	19.4	17.5	15.4	12.4	10.7		
		MCDB	11.2	10.9	11.9	14.0	16.9	20.2	22.2	22.1	19.5	16.8	13.7	11.9		
	10%	WB	9.0	8.7	9.5	10.9	13.6	16.3	18.3	18.6	16.6	14.8	11.4	9.5		
		MCDB	10.3	10.1	11.1	12.9	15.9	19.2	21.1	21.2	18.7	16.2	12.7	10.6		
(35) Mean Daily Temperature Range	5% DB	MDBR	3.3	3.6	3.9	4.5	4.4	4.9	4.9	4.8	4.3	4.0	3.6	3.2		
		MCDBR	4.2	4.3	5.2	6.5	6.8	7.4	7.0	6.8	5.5	4.7	4.1	4.2		
	5% WB	MCWBR	4.0	3.7	3.5	3.7	3.9	4.0	3.7	3.4	3.2	3.5	3.6	4.1		
		MCWBR	4.2	4.1	4.8	6.0	5.9	6.7	5.8	5.7	4.9	4.3	4.0	4.2		
(40) Clear-Sky Solar Irradiance	taub		0.334	0.350	0.388	0.408	0.414	0.415	0.412	0.403	0.383	0.366	0.339	0.325		
	taud		2.371	2.373	2.261	2.235	2.263	2.286	2.304	2.350	2.397	2.419	2.412	2.362		
	Ebn at Noon		671	768	799	828	840	841	837	825	801	738	660	615		
	Edh at Noon		63	82	109	125	128	126	122	111	95	77	60	55		
(44) All-Sky Solar Radiation	RadAvg		0.79	1.46	2.58	4.15	4.93	5.48	5.21	4.34	3.25	1.86	0.94	0.60		
	RadStd		0.07	0.22	0.32	0.39	0.35	0.43	0.46	0.33	0.26	0.18	0.11	0.08		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (76 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page