

SCILLY SAINT MARY'S, United Kingdom

WMO: 038030

Lat: 49.9144N

Lon: 6.2958W

Elev: 102

StdP: 14.64

Time Zone: 0.00 (EUW)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	37.3	39.5	26.5	20.6	39.7	29.2	23.3	41.1	46.7	48.9	42.9	49.1	16.3	60	0.728

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.2	68.3	63.2	66.9	62.4	65.7	61.6	64.6	66.9	63.5	65.7	62.6	64.7	11.3	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.6	88.3	65.6	62.6	85.1	64.6	61.6	82.3	63.8	29.7	67.1	28.9	65.8	28.3	64.7	72.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 37.2	32.7	29.5	DB	34.7	71.5	3.2	2.1	32.4	73.0	30.6	74.2	28.8	75.3	26.4	76.8	(4)
(5)			WB	32.0	66.8	2.9	2.0	29.9	68.2	28.2	69.4	26.5	70.5	24.4	71.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	53.8	47.7	47.1	47.9	50.0	53.7	58.1	61.6	62.0	59.9	56.2	51.8	49.0		
	DBStd	6.10	3.63	3.47	3.05	2.68	2.52	2.48	2.41	1.84	2.28	2.70	3.20	3.55		
	HDD50	361	85	88	75	31	3	0	0	0	0	1	19	59		
	HDD65	4096	535	502	530	450	351	206	108	95	154	272	397	496		
	CDD50	1744	14	7	9	31	117	244	360	371	296	195	72	28		
	CDD65	5	0	0	0	0	0	0	3	2	0	0	0	0		
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
(14) Wind	WSAvg	15.2	19.2	18.1	16.3	14.5	13.6	12.5	11.7	11.9	13.2	15.6	17.2	19.0		
(15) Precipitation	PrecAvg	34.0	3.9	3.1	2.4	2.1	1.9	1.9	2.3	2.6	2.8	3.3	3.7	3.6		
	PrecMax	41.6	6.0	6.0	5.9	5.4	3.3	4.4	6.5	5.6	8.0	7.0	7.1	6.6		
	PrecMin	25.9	1.0	0.7	0.6	0.2	0.1	0.2	0.0	0.4	0.7	0.1	0.4	0.5		
	PrecStd	4.2	1.5	1.3	1.1	1.3	0.9	1.1	1.7	1.5	1.6	1.7	2.0	1.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.0	54.3	54.7	57.6	62.6	68.0	71.6	69.6	67.5	63.3	58.8	56.4		
		MCWB	53.1	52.3	52.0	53.4	58.1	62.2	64.9	64.6	63.3	60.5	56.9	54.7		
	2%	DB	54.1	53.1	53.3	56.1	60.3	65.5	69.2	67.9	65.7	61.8	57.7	55.5		
		MCWB	52.5	51.5	51.2	52.7	56.8	60.9	63.4	63.2	61.8	59.4	56.0	54.2		
	5%	DB	53.2	52.2	52.6	54.9	58.9	63.8	67.4	66.6	64.5	60.7	56.9	54.7		
		MCWB	51.8	50.6	50.6	51.9	55.8	59.7	62.4	62.4	61.1	58.5	55.3	53.4		
	10%	DB	52.5	51.5	51.8	53.8	57.5	62.4	65.9	65.5	63.5	59.9	56.1	53.9		
		MCWB	50.9	49.8	50.1	51.0	54.7	58.7	61.6	61.7	60.4	57.8	54.3	52.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	54.0	53.1	53.1	54.6	59.3	63.2	66.1	66.3	64.8	61.6	57.8	55.7		
		MCDB	54.3	53.5	53.6	56.2	61.3	66.3	69.9	68.4	66.2	62.6	58.1	55.9		
	2%	WB	53.1	52.1	52.1	53.5	57.6	61.6	64.5	64.7	63.3	60.3	56.7	54.7		
		MCDB	53.7	52.6	52.7	55.2	59.4	64.5	67.7	66.6	64.7	61.0	57.2	55.1		
	5%	WB	52.3	51.3	51.3	52.5	56.4	60.5	63.4	63.6	62.1	59.3	55.9	54.0		
		MCDB	53.0	51.9	52.1	54.1	58.1	63.1	66.3	65.4	63.6	60.2	56.7	54.5		
	10%	WB	51.4	50.4	50.5	51.7	55.3	59.4	62.4	62.7	61.2	58.5	54.9	52.9		
		MCDB	52.3	51.2	51.5	53.2	57.0	61.7	64.9	64.5	62.7	59.5	55.9	53.7		
(35) Mean Daily Temperature Range	5% DB	MDBR	4.9	5.1	5.4	6.2	6.5	7.1	7.6	7.2	6.3	5.2	4.6	4.7		
		MCDBR	4.9	4.9	5.6	6.8	7.6	8.6	9.2	8.2	7.2	5.6	4.5	4.8		
	5% WB	MCWBR	5.9	5.5	5.2	5.4	5.6	5.9	5.6	5.5	5.5	5.0	5.1	6.2		
		MCWBR	4.8	5.0	5.1	6.3	7.1	7.9	8.4	7.2	6.7	5.1	4.3	4.9		
(40) Clear-Sky Solar Irradiance	taub	taub	0.343	0.355	0.383	0.385	0.393	0.378	0.386	0.369	0.367	0.362	0.341	0.336		
		taud	2.342	2.374	2.323	2.357	2.381	2.456	2.442	2.503	2.490	2.446	2.391	2.310		
	Ebn at Noon	Ebn at Noon	216	247	259	273	275	279	275	275	264	241	216	198		
		Edh at Noon	22	27	33	36	36	34	34	30	28	25	21	20		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	281	529	891	1467	1752	1925	1748	1509	1134	668	357	225		
	RadStd	RadStd	22	41	93	88	126	160	133	92	78	37	30	22		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (11 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page