

SCILLY SAINT MARY'S, United Kingdom

WMO: 038030

Lat: 49.9144N

Lon: 6.2958W

Elev: 31

StdP: 100.95

Time Zone: 0.00 (EUW)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	3.0	4.1	-3.0	2.9	4.3	-1.5	3.3	5.1	20.9	9.4	19.2	9.5	7.3	60	0.728

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.0	20.2	17.3	19.4	16.9	18.7	16.5	18.1	19.4	17.5	18.7	17.0	18.2	5.1	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.6	12.6	18.7	17.0	12.2	18.1	16.5	11.8	17.7	51.2	19.5	49.3	18.8	47.8	18.2	22.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.6	14.6	13.2	DB	1.5	21.9	1.8	1.1	0.2	22.8	-0.8	23.4	-1.8	24.1	-3.1	24.9	(4)
(5)			WB	0.0	19.3	1.6	1.1	-1.2	20.1	-2.1	20.8	-3.0	21.4	-4.2	22.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	12.1	8.7	8.4	8.8	10.0	12.0	14.5	16.5	16.7	15.5	13.5	11.0	9.4	(6)	
	DBStd	3.39	2.02	1.93	1.70	1.49	1.40	1.38	1.34	1.02	1.27	1.50	1.78	1.97	(7)	
	HDD10.0	201	47	49	42	17	2	0	0	0	0	1	11	33	(8)	
	HDD18.3	2276	297	279	294	250	195	114	60	53	86	151	221	276	(9)	
	CDD10.0	969	8	4	5	17	65	136	200	206	164	108	40	16	(10)	
	CDD18.3	3	0	0	0	0	0	0	2	1	0	0	0	0	(11)	
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)	
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
(14) Wind	WSAvg	6.8	8.6	8.1	7.3	6.5	6.1	5.6	5.2	5.3	5.9	7.0	7.7	8.5	(14)	
(15) Precipitation	PrecAvg	864	98	80	60	53	49	47	58	66	70	83	93	92	(15)	
	PrecMax	1057	153	153	149	137	85	112	166	142	202	177	181	167	(16)	
	PrecMin	657	25	17	14	6	2	5	1	10	17	2	11	13	(17)	
	PrecStd	106	39	34	28	32	22	28	42	39	40	42	50	43	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.8	12.4	12.6	14.2	17.0	20.0	22.0	20.9	19.7	17.4	14.9	13.6	(19)	
		MCWB	11.7	11.3	11.1	11.9	14.5	16.8	18.3	18.1	17.4	15.8	13.8	12.6	(20)	
	2%	DB	12.3	11.7	11.9	13.4	15.7	18.6	20.7	19.9	18.7	16.5	14.3	13.1	(21)	
		MCWB	11.4	10.8	10.7	11.5	13.8	16.0	17.5	17.3	16.6	15.2	13.3	12.4	(22)	
	5%	DB	11.8	11.2	11.4	12.7	14.9	17.7	19.7	19.2	18.1	16.0	13.9	12.6	(23)	
		MCWB	11.0	10.3	10.3	11.0	13.2	15.4	16.9	16.9	16.2	14.7	12.9	11.9	(24)	
	10%	DB	11.4	10.8	11.0	12.1	14.2	16.9	18.8	18.6	17.5	15.5	13.4	12.1	(25)	
		MCWB	10.5	9.9	10.0	10.6	12.6	14.9	16.5	16.5	15.8	14.4	12.4	11.3	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.2	11.7	11.7	12.5	15.1	17.3	18.9	19.1	18.2	16.4	14.3	13.2	(27)	
		MCDB	12.4	11.9	12.0	13.4	16.3	19.0	21.0	20.2	19.0	17.0	14.5	13.3	(28)	
	2%	WB	11.7	11.2	11.2	11.9	14.2	16.5	18.1	18.2	17.4	15.7	13.7	12.6	(29)	
		MCDB	12.0	11.5	11.5	12.9	15.2	18.0	19.8	19.2	18.1	16.1	14.0	12.8	(30)	
	5%	WB	11.3	10.7	10.7	11.4	13.6	15.8	17.5	17.6	16.7	15.2	13.3	12.2	(31)	
		MCDB	11.7	11.1	11.1	12.3	14.5	17.3	19.0	18.6	17.6	15.6	13.7	12.5	(32)	
	10%	WB	10.8	10.2	10.3	10.9	13.0	15.2	16.9	17.0	16.2	14.7	12.7	11.6	(33)	
		MCDB	11.3	10.7	10.8	11.8	13.9	16.5	18.3	18.1	17.1	15.3	13.3	12.1	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	2.7	2.8	3.0	3.4	3.6	3.9	4.2	4.0	3.5	2.9	2.5	2.6	(35)	
		MCDBR	2.7	2.7	3.1	3.8	4.2	4.8	5.1	4.5	4.0	3.1	2.5	2.7	(36)	
	5% WB	MCWBR	3.3	3.1	2.9	3.0	3.1	3.3	3.1	3.1	3.0	2.8	2.8	3.4	(37)	
		MCWBR	2.7	2.8	2.8	3.5	4.0	4.4	4.7	4.0	3.7	2.8	2.4	2.7	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.343	0.355	0.383	0.385	0.393	0.378	0.386	0.369	0.367	0.362	0.341	0.336	(40)	
		taud	2.342	2.374	2.323	2.357	2.381	2.456	2.442	2.503	2.490	2.446	2.391	2.310	(41)	
	Ebn at Noon	Ebn at Noon	681	778	818	860	866	881	867	868	831	761	681	625	(42)	
		Edh at Noon	69	85	105	112	115	107	107	96	88	78	65	62	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	0.89	1.67	2.81	4.63	5.52	6.07	5.51	4.76	3.57	2.10	1.13	0.71	(44)	
	RadStd	RadStd	0.07	0.13	0.29	0.28	0.40	0.50	0.42	0.29	0.25	0.12	0.09	0.07	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (11 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page