

CAMBORNE, United Kingdom

WMO: 038080

Lat: 50.2183N

Lon: 5.3275W

Elev: 88

StdP: 100.27

Time Zone: 0.00 (EUW)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-0.6	0.9	-5.2	2.5	1.2	-3.7	2.8	2.3	15.7	8.5	14.3	8.4	4.0	50	0.662

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.1	21.5	17.0	20.1	16.3	19.0	15.9	18.1	19.9	17.3	18.9	16.7	18.1	5.3	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.4	12.6	18.6	16.7	12.0	17.9	16.1	11.6	17.4	51.2	20.1	49.1	18.9	47.3	18.2	22.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.2	11.8	10.6	-2.1	24.3	1.9	1.9	-3.4	25.7	-4.5	26.8	-5.6	27.8	-6.9	29.2		
(5)			-3.3	19.5	1.9	1.2	-4.7	20.3	-5.8	21.0	-6.9	21.7	-8.3	22.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	11.0	7.0	6.9	7.7	9.1	11.4	13.9	15.7	16.0	14.5	12.4	9.6	7.8	(6)
(7)		DBStd	3.91	2.65	2.44	2.26	2.13	2.04	1.92	1.73	1.51	1.66	2.02	2.19	2.67	(7)
(8)		HDD10.0	417	94	88	76	41	8	0	0	0	0	4	32	74	(8)
(9)		HDD18.3	2674	350	320	331	278	214	136	84	76	114	184	262	326	(9)
(10)		CDD10.0	792	2	2	3	13	52	116	177	185	136	78	21	7	(10)
(11)		CDD18.3	6	0	0	0	0	0	1	2	2	1	0	0	0	(11)
(12)		CDH23.3	13	0	0	0	0	0	4	4	4	1	0	0	0	(12)
(13)		CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	5.3	6.2	6.0	5.7	5.3	5.0	4.6	4.3	4.4	4.8	5.4	5.7	6.0	(14)
(15)	Precipitation	PrecAvg	1116	135	100	99	64	67	62	58	73	84	111	123	133	(15)
(16)		PrecMax	1380	243	213	179	166	132	164	159	152	175	271	211	276	(16)
(17)		PrecMin	841	18	10	7	6	9	3	15	4	24	18	49	44	(17)
(18)		PrecStd	146	59	56	43	39	31	39	34	42	42	63	51	58	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.5	12.2	14.0	18.4	20.2	23.4	23.8	23.4	21.1	18.1	14.9	13.4	(19)
(20)			MCWB	11.3	10.6	10.2	12.6	14.3	17.3	17.9	18.3	17.5	15.5	13.9	12.3	(20)
(21)		2%	DB	11.8	11.3	12.1	14.9	17.7	20.3	21.5	20.8	19.2	16.6	14.0	12.7	(21)
(22)			MCWB	11.0	10.2	10.1	11.1	13.5	15.6	16.9	17.1	16.2	14.9	13.1	11.9	(22)
(23)		5%	DB	11.2	10.7	11.2	13.2	15.8	18.4	19.9	19.5	18.1	15.8	13.4	12.1	(23)
(24)			MCWB	10.4	9.7	9.8	10.4	12.8	15.0	16.4	16.5	15.7	14.4	12.4	11.4	(24)
(25)		10%	DB	10.5	10.1	10.6	12.0	14.5	17.0	18.7	18.5	17.3	15.2	12.8	11.5	(25)
(26)			MCWB	9.7	9.2	9.4	9.9	12.2	14.4	16.0	16.1	15.2	14.0	11.8	10.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.9	11.4	11.6	13.1	15.6	18.1	19.0	19.2	18.3	16.3	14.2	12.8	(27)
(28)			MCDWB	12.1	11.7	12.1	15.9	18.6	22.2	22.1	21.1	19.8	17.2	14.5	12.9	(28)
(29)		2%	WB	11.3	10.7	10.9	11.8	14.2	16.4	17.9	18.1	17.2	15.5	13.4	12.2	(29)
(30)			MCDWB	11.6	11.1	11.5	13.9	16.3	19.0	19.9	19.6	18.3	16.2	13.8	12.6	(30)
(31)		5%	WB	10.6	10.1	10.3	11.1	13.4	15.6	17.1	17.4	16.5	14.9	12.8	11.7	(31)
(32)			MCDWB	11.0	10.5	11.0	12.5	15.1	17.6	18.7	18.7	17.5	15.5	13.2	12.1	(32)
(33)		10%	WB	9.9	9.4	9.7	10.5	12.7	14.9	16.5	16.8	15.9	14.4	12.0	10.9	(33)
(34)			MCDWB	10.5	10.1	10.5	11.7	14.1	16.5	18.0	18.0	16.9	15.1	12.7	11.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	3.8	4.0	4.3	4.9	5.0	5.1	5.0	5.1	5.0	4.3	3.8	3.8	(35)
(36)			MCDBR	3.8	3.9	4.7	6.5	6.9	7.4	7.0	6.2	6.0	4.4	3.7	3.6	(36)
(37)			MCWBR	4.2	3.7	3.6	4.1	4.2	4.4	3.8	3.5	3.9	3.5	3.7	4.2	(37)
(38)		5% WB	MCDWB	3.8	3.8	4.1	5.3	5.9	6.4	5.8	5.4	5.0	4.0	3.5	3.6	(38)
(39)			MCWBR	4.4	4.0	3.7	3.9	4.0	4.2	3.7	3.7	3.9	3.6	3.9	4.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.338	0.350	0.377	0.383	0.391	0.377	0.382	0.367	0.364	0.358	0.336	0.329	(40)	
(41)		taud	2.353	2.379	2.326	2.343	2.366	2.437	2.429	2.488	2.480	2.449	2.402	2.320	(41)	
(42)		Ebn at Noon	684	780	821	860	867	882	870	869	832	763	684	628	(42)	
(43)		Edh at Noon	67	83	104	114	116	109	108	97	89	77	64	60	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.82	1.61	2.77	4.47	5.40	5.93	5.45	4.67	3.54	2.01	1.05	0.66	(44)	
(45)		RadStd	0.07	0.16	0.30	0.30	0.39	0.55	0.37	0.32	0.24	0.13	0.08	0.07	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(47) Regional (24 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Nomenclature: See separate page