

PENDENNIS POINT, United Kingdom

WMO: 038100

Lat: 50.1452N

Lon: 5.0454W

Elev: 42

StdP: 100.82

Time Zone: 0.00 (EUW)

Period: 94-07

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	1.2	2.4	-3.5	2.8	3.5	-2.3	3.1	3.6	26.1	10.2	22.6	10.3	4.6	30	0.680

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.9	21.8	17.9	20.6	17.1	19.6	16.4	18.6	20.7	17.8	19.7	17.1	18.7	4.0	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.7	12.8	19.5	17.1	12.2	18.7	16.5	11.8	18.1	52.6	20.9	50.3	19.8	48.3	18.8	24.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.7	17.8	14.9	DB	-0.3	24.6	0.8	1.9	-0.8	26.0	-1.3	27.1	-1.7	28.2	-2.2	29.6	(4)
(5)			WB	-1.4	20.2	0.7	1.5	-1.9	21.2	-2.3	22.1	-2.7	22.9	-3.2	24.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	11.7	8.0	7.4	8.2	9.8	11.9	14.5	16.4	17.0	15.4	13.0	10.3	8.3
	DBStd	3.85	2.22	2.30	2.09	1.87	1.74	1.63	1.68	1.59	1.52	1.72	1.98	2.39
	HDD10.0	314	67	73	61	26	4	0	0	0	0	2	21	61
	HDD18.3	2434	321	305	314	257	201	117	63	49	90	166	241	310
	CDD10.0	934	4	2	4	19	62	134	199	217	161	94	29	9
	CDD18.3	12	0	0	0	0	0	1	4	7	1	0	0	0
	CDH23.3	13	0	0	0	0	0	0	2	11	0	0	0	0
	CDH26.7	1	0	0	0	0	0	0	0	1	0	0	0	0
Wind	WSAvg	6.3	8.0	7.0	6.9	5.9	5.9	5.0	4.6	4.6	5.7	7.3	6.7	7.7
Precipitation	PrecAvg	1117	135	102	95	67	61	61	62	73	88	111	127	134
	PrecMax	1472	284	210	183	147	161	154	132	154	172	214	232	266
	PrecMin	885	18	4	3	14	6	4	13	4	27	16	56	36
	PrecStd	146	62	57	44	32	33	41	30	38	40	54	50	60
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.6	12.2	13.9	15.8	18.9	21.2	23.4	24.5	21.7	17.8	15.1	13.2
		MCWB	11.0	10.7	11.1	12.1	15.4	16.4	18.4	20.2	17.7	14.7	13.3	12.5
	2%	DB	11.9	11.6	12.2	14.6	17.0	19.6	21.7	22.0	19.5	16.5	14.1	12.7
		MCWB	10.9	10.3	10.1	11.3	13.5	15.8	17.7	18.6	16.4	14.3	12.9	11.9
	5%	DB	11.4	11.1	11.4	13.6	15.7	18.5	20.6	20.6	18.6	15.7	13.6	12.2
		MCWB	10.6	10.0	9.8	10.7	12.8	15.1	17.1	17.4	15.9	14.1	12.5	11.4
	10%	DB	10.9	10.6	10.8	12.6	14.7	17.5	19.4	19.6	17.8	15.2	13.1	11.7
		MCWB	10.1	9.5	9.6	10.3	12.2	14.5	16.5	16.5	15.6	13.9	12.0	10.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.8	11.6	11.5	13.1	15.5	17.0	19.4	20.9	18.4	15.9	14.4	12.8
		MCDB	12.0	11.9	12.6	14.9	18.5	20.1	21.6	24.1	20.2	16.7	14.6	12.9
	2%	WB	11.2	11.0	10.9	12.2	14.2	16.2	18.2	19.1	17.5	15.2	13.5	12.3
		MCDB	11.6	11.3	11.6	13.5	16.1	18.7	20.5	21.5	18.6	15.7	13.8	12.5
	5%	WB	10.7	10.4	10.4	11.5	13.4	15.6	17.6	18.2	16.7	14.8	12.9	11.7
		MCDB	11.2	10.9	11.0	12.8	14.9	17.7	19.8	20.0	17.8	15.3	13.3	12.1
	10%	WB	10.2	9.8	10.0	10.8	12.7	15.1	16.9	17.4	16.2	14.4	12.2	11.0
		MCDB	10.8	10.4	10.6	12.1	14.1	16.9	18.8	18.9	17.3	15.0	12.9	11.5
Mean Daily Temperature Range	5% DB	MDBR	3.3	3.8	3.7	4.6	4.7	4.9	4.8	4.9	4.7	3.7	3.4	3.4
		MCDBR	3.2	3.8	4.3	5.9	6.0	6.4	6.5	6.5	5.8	4.3	3.7	3.4
		MCWBR	3.2	3.7	3.1	3.9	3.8	3.9	3.6	3.7	3.4	3.2	3.3	3.6
	5% WB	MCDBR	3.1	3.4	3.8	5.1	5.1	5.8	5.6	5.7	4.7	3.6	3.1	3.1
		MCWBR	3.5	3.8	3.2	3.8	3.6	3.9	3.6	3.8	3.6	3.2	3.4	3.8
Clear-Sky Solar Irradiance	taub	0.339	0.352	0.380	0.386	0.393	0.380	0.384	0.369	0.366	0.360	0.337	0.331	
	taud	2.354	2.375	2.316	2.329	2.352	2.420	2.416	2.475	2.468	2.443	2.404	2.320	
	Ebn at Noon	684	779	819	857	865	878	868	866	830	761	684	628	
	Edh at Noon	68	84	105	115	118	111	110	99	90	78	64	61	
All-Sky Solar Radiation	RadAvg	0.83	1.62	2.77	4.49	5.42	5.95	5.47	4.70	3.56	2.03	1.06	0.67	
	RadStd	0.07	0.16	0.30	0.30	0.39	0.55	0.37	0.33	0.24	0.13	0.08	0.07	

Historical Trends

		Heating		Cooling		Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
(46) Station Only	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47) Regional (33 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page