

LEE-ON-SOLENT, United Kingdom

WMO: 038740

Lat: 50.807N

Lon: 1.209W

Elev: 13

StdP: 101.17

Time Zone: 0.00 (EUW)

Period: 94-15

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-2.0	-0.7	-5.7	2.3	0.8	-4.3	2.6	1.3	20.0	9.4	18.7	9.4	4.3	30	0.690

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.7	25.2	18.7	23.5	18.0	22.1	17.3	19.9	23.1	18.9	22.1	18.2	21.0	4.8	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.7	13.5	21.2	17.7	12.7	20.3	17.0	12.2	19.5	56.8	23.1	53.7	22.2	51.3	21.1	26.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.2	15.0	13.4	-4.0	28.2	1.6	1.6	-5.2	29.4	-6.1	30.3	-7.0	31.2	-8.1	32.4		
(5)			-4.7	22.2	1.5	2.5	-5.8	24.0	-6.6	25.4	-7.5	26.8	-8.6	28.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	11.6	6.1	6.1	7.7	10.0	13.0	15.7	17.9	18.0	15.8	12.9	9.3	6.4		
	DBStd	5.07	2.98	2.66	2.49	2.75	2.56	2.11	2.09	1.91	2.01	2.59	2.89	3.25		
	HDD10.0	514	121	109	77	32	4	0	0	0	0	7	46	117		
	HDD18.3	2502	378	342	330	251	167	82	34	28	78	167	272	372		
	CDD10.0	1102	1	1	6	32	96	172	244	248	175	98	24	4		
	CDD18.3	47	0	0	0	0	1	4	20	18	3	0	0	0		
	CDH23.3	169	0	0	0	1	7	24	78	53	5	1	0	0		
	CDH26.7	19	0	0	0	0	0	2	9	8	0	0	0	0		
(14) Wind	WSAvg	6.1	7.2	6.7	6.0	5.6	5.8	5.7	5.7	5.6	5.6	6.4	6.3	6.7		
(15) Precipitation	PrecAvg	813	94	65	53	53	48	53	47	55	59	94	98	92		
	PrecMax	1098	218	161	140	136	113	139	116	136	139	170	201	182		
	PrecMin	628	18	5	5	0	9	11	11	5	4	30	26	27		
	PrecStd	126	45	42	27	34	28	34	27	34	35	39	50	46		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.1	12.3	16.2	21.1	24.3	26.2	28.0	27.7	24.0	20.1	15.8	13.0		
		MCWB	10.7	10.0	11.2	13.7	16.4	18.9	19.2	19.9	18.9	15.7	14.4	11.9		
	2%	DB	11.3	11.1	13.8	17.7	21.1	23.2	25.5	24.6	21.8	18.1	14.6	12.2		
		MCWB	10.2	9.5	10.1	12.4	15.5	17.2	18.6	18.7	17.2	15.5	13.1	11.2		
	5%	DB	10.7	10.4	12.3	15.7	19.1	21.2	23.6	22.9	20.5	17.2	13.9	11.6		
		MCWB	9.7	8.9	9.4	11.2	14.6	16.4	18.1	18.2	16.5	15.2	12.5	10.5		
	10%	DB	10.0	9.6	11.1	14.0	17.2	19.7	21.9	21.6	19.3	16.5	13.2	10.9		
		MCWB	8.9	8.3	8.9	10.5	13.3	15.6	17.6	17.4	15.9	14.7	11.8	9.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.3	11.5	11.9	14.8	18.2	21.4	20.9	22.1	19.6	17.3	14.6	12.3		
		MCDB	11.7	11.7	14.5	19.2	22.2	22.9	25.0	24.2	21.9	18.6	15.2	12.7		
	2%	WB	10.6	10.1	10.8	13.0	16.3	18.4	19.6	19.9	18.2	16.4	13.6	11.5		
		MCDB	11.1	10.7	12.7	16.3	19.8	21.6	23.5	23.1	20.5	17.4	14.3	12.0		
	5%	WB	9.9	9.2	10.1	11.9	15.0	17.2	18.8	18.9	17.5	15.7	12.9	10.8		
		MCDB	10.6	9.9	11.5	14.6	18.3	20.0	22.5	21.8	19.5	16.8	13.7	11.4		
	10%	WB	9.1	8.6	9.5	11.1	13.8	16.3	18.0	18.2	16.7	15.1	12.0	10.0		
		MCDB	9.9	9.4	10.7	13.2	16.3	18.8	21.2	20.6	18.6	16.2	13.0	10.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	4.3	4.8	5.9	6.9	6.9	6.8	6.7	6.7	6.7	5.6	4.9	4.5		
		MCDBR	3.9	4.9	7.6	9.6	10.2	9.7	10.1	8.9	8.3	5.7	4.3	3.6		
	5% WB	MCWBR	3.7	3.8	5.1	5.3	5.9	5.6	5.2	5.0	5.0	4.1	3.8	3.8		
		MCWBR	3.8	4.1	6.2	7.8	9.2	8.1	8.5	7.4	7.0	4.8	3.7	3.6		
(40) Clear-Sky Solar Irradiance	taub		0.333	0.349	0.386	0.404	0.407	0.404	0.397	0.391	0.377	0.363	0.335	0.324		
		taud	2.369	2.377	2.270	2.246	2.285	2.322	2.348	2.385	2.410	2.425	2.415	2.357		
	Ebn at Noon		682	776	806	835	849	854	854	841	811	749	676	630		
		Edh at Noon	65	83	109	125	125	122	117	107	94	78	62	57		
(44) All-Sky Solar Radiation	RadAvg		0.83	1.54	2.75	4.36	5.25	5.81	5.51	4.62	3.42	1.93	1.01	0.65		
	RadStd		0.06	0.19	0.35	0.41	0.32	0.54	0.44	0.35	0.26	0.16	0.11	0.08		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (76 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page