

JERSEY, Jersey

WMO: 038950

Lat: 49.210N

Lon: 2.194W

Elev: 84

StdP: 100.32

Time Zone: 0.00 (EUW)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-0.4	0.9	-4.7	2.6	1.4	-3.3	2.9	2.4	16.4	8.0	14.8	7.8	5.7	90	0.670

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.6	25.0	18.3	23.0	17.4	21.3	16.8	19.1	23.2	18.2	21.4	17.6	20.1	4.6	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.7	12.8	20.2	17.1	12.3	19.2	16.5	11.9	18.6	54.7	23.3	51.9	21.5	49.7	20.2	24.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.9	12.3	11.1	-2.4	29.3	1.8	2.4	-3.7	31.0	-4.7	32.5	-5.7	33.8	-7.0	35.6		
(5)			-3.3	21.2	1.8	1.1	-4.6	22.0	-5.7	22.6	-6.7	23.2	-8.0	24.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	11.7	6.7	6.6	8.0	9.8	12.6	15.2	17.1	17.4	15.9	13.3	10.0	7.6
	DBStd	4.57	2.81	2.51	2.35	2.41	2.44	2.25	2.09	1.88	1.91	2.27	2.39	2.90
	HDD10.0	416	104	96	69	30	4	0	0	0	0	3	28	82
	HDD18.3	2450	361	328	321	256	180	98	49	42	78	156	249	333
	CDD10.0	1042	2	1	7	24	83	156	221	229	176	107	28	7
	CDD18.3	36	0	0	0	0	1	5	12	13	4	1	0	0
	CDH23.3	153	0	0	0	0	4	33	56	50	9	1	0	0
	CDH26.7	27	0	0	0	0	0	6	11	10	0	0	0	0
Wind	WSAvg	5.9	7.0	6.5	6.1	5.6	5.4	5.1	5.0	4.9	5.4	6.1	6.6	6.9
Precipitation	PrecAvg	850	97	72	68	53	54	46	41	48	68	89	110	106
	PrecMax	1088	184	154	126	117	127	91	104	134	166	207	195	198
	PrecMin	579	14	6	3	3	3	1	4	1	16	3	25	33
	PrecStd	131	46	41	34	25	33	24	20	33	39	51	42	45
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.2	12.6	16.4	20.8	23.5	27.3	27.9	27.7	24.8	20.1	15.9	13.4
		MCWB	11.2	10.1	11.9	13.9	16.6	19.1	19.3	19.6	18.2	16.6	14.6	12.3
	2%	DB	11.5	11.3	13.7	17.2	20.6	23.3	24.6	24.4	21.8	18.2	14.6	12.7
		MCWB	10.6	9.8	10.4	12.5	15.2	17.2	18.0	18.5	17.1	15.7	13.5	11.9
	5%	DB	10.8	10.5	12.1	14.9	18.4	20.9	22.6	22.1	20.1	17.1	13.9	12.0
		MCWB	9.9	9.4	9.9	11.3	14.1	16.2	17.2	17.5	16.4	15.2	12.7	11.2
	10%	DB	10.2	9.8	11.0	13.3	16.4	19.1	20.8	20.4	18.7	16.3	13.2	11.4
		MCWB	9.3	8.9	9.4	10.4	13.2	15.3	16.7	16.8	15.7	14.6	12.0	10.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.7	11.1	12.2	14.8	17.8	19.9	20.2	20.6	19.0	17.4	15.0	12.9
		MCDB	11.9	11.6	14.8	18.9	22.1	25.8	25.6	25.7	22.7	19.2	15.4	13.0
	2%	WB	10.9	10.3	11.2	12.9	15.8	18.1	18.8	19.2	18.0	16.4	13.8	12.1
		MCDB	11.3	10.8	12.8	16.3	19.5	22.3	23.1	22.7	20.5	17.6	14.3	12.5
	5%	WB	10.2	9.7	10.5	11.8	14.6	16.7	18.0	18.2	17.2	15.6	13.0	11.5
		MCDB	10.6	10.3	11.6	14.1	17.5	20.0	21.1	20.8	19.1	16.7	13.8	11.9
	10%	WB	9.6	9.1	9.8	10.9	13.5	15.7	17.2	17.5	16.5	15.0	12.2	10.8
		MCDB	10.1	9.7	10.8	12.7	15.8	18.3	19.8	19.6	18.2	16.0	13.1	11.3
Mean Daily Temperature Range	5% DB	MDBR	3.5	3.9	4.7	5.6	5.9	6.1	6.0	5.6	5.3	4.3	3.5	3.6
		MCDBR	3.3	4.2	6.4	8.4	9.1	9.7	9.3	8.7	7.4	4.9	3.5	3.2
		MCWBR	3.5	3.6	4.3	4.9	5.2	5.2	4.6	4.3	3.8	3.4	3.6	3.6
	5% WB	MCDBR	3.3	3.8	5.4	7.2	8.1	8.6	7.9	7.1	6.2	4.3	3.4	3.3
		MCWBR	3.7	3.8	4.0	4.6	5.0	5.1	4.4	4.0	3.9	3.6	3.7	3.8
Clear-Sky Solar Irradiance	taub	0.334	0.350	0.381	0.393	0.398	0.392	0.388	0.381	0.370	0.361	0.337	0.327	
	taud	2.414	2.399	2.322	2.315	2.352	2.398	2.409	2.453	2.461	2.464	2.446	2.380	
	Ebn at Noon	714	792	824	854	863	869	866	858	830	771	705	661	
	Edh at Noon	66	84	106	118	118	114	111	102	92	78	63	60	
All-Sky Solar Radiation	RadAvg	0.90	1.66	2.85	4.52	5.40	5.92	5.71	4.79	3.69	2.09	1.11	0.74	
	RadStd	0.07	0.20	0.30	0.40	0.41	0.60	0.33	0.36	0.26	0.16	0.11	0.09	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(47) Regional (35 neighbors)		(m)								
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page