

ENNISKILLEN, United Kingdom

WMO: 039030

Lat: 54.395N

Lon: 7.644W

Elev: 154

StdP: 14.61

Time Zone: 0.00 (EUW)

Period: 94-13

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	23.6	27.4	21.8	16.5	28.1	24.9	19.1	31.4	28.4	48.9	25.3	48.6	0.9	50	0.603

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.0	73.1	62.8	69.9	61.4	67.4	60.1	64.6	70.4	62.9	67.6	61.5	65.7	7.8	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
62.4	84.7	67.2	60.9	80.2	65.3	59.4	76.1	63.9	29.7	70.4	28.5	67.9	27.5	65.8	74.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
23.4	20.5	18.1	DB	19.5	77.8	5.1	3.3	15.9	80.2	12.9	82.2	10.1	84.0	6.4	86.4
			WB	20.0	68.1	5.5	3.0	16.0	70.3	12.8	72.1	9.8	73.8	5.8	76.0

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	49.4	40.9	41.6	43.6	47.2	51.6	56.5	59.3	55.8	50.6	45.4	40.4	(6)	
(7)		DBStd	8.42	5.75	5.18	4.94	4.86	4.80	4.20	3.60	3.72	3.88	4.86	5.50	6.66	(7)
(8)		HDD50	1382	284	238	204	109	36	2	0	0	3	53	154	299	(8)
(9)		HDD65	5706	747	655	662	533	415	257	182	183	275	447	589	761	(9)
(10)		CDD50	1162	2	3	7	26	86	197	287	287	178	71	15	3	(10)
(11)		CDD65	10	0	0	0	0	0	1	4	5	0	0	0	0	(11)
(12)		CDH74	70	0	0	0	0	3	20	22	25	0	0	0	0	(12)
(13)		CDH80	4	0	0	0	0	0	1	2	1	0	0	0	0	(13)
(14)	Wind	WSAvg	7.9	8.9	8.9	8.7	7.9	7.8	7.5	7.0	6.7	7.2	8.0	8.1	7.7	(14)
(15)	Precipitation	PrecAvg	49.6	5.2	4.0	3.7	3.5	3.2	3.5	3.4	4.1	3.9	5.1	4.9	5.1	(15)
(16)		PrecMax	60.3	8.9	9.6	6.8	5.4	6.1	6.8	5.9	8.0	6.8	9.7	10.6	11.1	(16)
(17)		PrecMin	36.0	1.1	0.8	1.1	1.1	0.6	1.5	1.3	0.7	1.8	1.1	2.2	1.5	(17)
(18)		PrecStd	7.0	2.0	2.3	1.5	1.2	1.6	1.4	1.3	1.7	1.5	2.5	1.9	2.4	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.4	55.3	59.3	65.5	73.4	76.7	76.9	77.4	70.4	63.6	58.8	55.6	(19)
(20)			MCWB	51.4	52.1	51.8	54.3	61.5	63.3	65.7	66.5	62.3	58.3	55.7	53.3	(20)
(21)		2%	DB	52.7	53.0	55.4	61.0	68.7	71.5	72.2	71.4	67.0	60.8	56.6	53.5	(21)
(22)			MCWB	50.2	50.4	50.7	52.5	58.7	60.9	63.2	62.8	60.6	57.3	54.2	51.3	(22)
(23)		5%	DB	51.1	51.3	53.3	58.0	64.1	67.6	69.0	68.3	64.6	59.2	54.9	51.6	(23)
(24)			MCWB	48.9	48.9	49.4	51.4	55.8	59.1	61.6	61.5	59.4	56.2	52.5	49.6	(24)
(25)		10%	DB	49.4	49.6	51.5	55.5	60.3	64.6	66.0	65.6	62.6	57.8	53.4	49.3	(25)
(26)			MCWB	47.3	47.0	48.0	50.2	53.7	57.5	59.9	60.1	58.0	54.8	51.1	47.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.1	52.9	53.9	56.8	62.7	65.2	67.3	67.2	64.2	59.8	56.5	53.9	(27)
(28)			MCD B	53.6	54.4	56.8	61.6	70.9	73.1	74.9	74.9	68.2	61.6	58.2	55.4	(28)
(29)		2%	WB	50.7	51.0	51.8	54.2	59.1	62.3	64.6	64.5	62.1	58.1	54.5	51.6	(29)
(30)			MCD B	52.3	52.6	54.2	58.6	66.9	69.4	70.5	69.7	65.4	60.0	56.2	53.1	(30)
(31)		5%	WB	49.2	49.3	50.2	52.4	56.7	60.0	62.6	62.7	60.4	56.6	53.0	49.7	(31)
(32)			MCD B	50.9	51.1	52.9	57.0	62.7	66.0	67.1	66.7	63.5	58.8	54.7	51.5	(32)
(33)		10%	WB	47.4	47.4	48.5	50.7	54.7	58.3	60.9	61.2	58.8	55.3	51.4	47.6	(33)
(34)			MCD B	49.3	49.4	51.1	55.0	59.2	63.4	65.1	64.8	61.8	57.5	53.2	49.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.9	10.2	11.8	13.8	14.0	13.0	12.0	12.0	10.8	9.5	9.4	(35)	
(36)			MCDBR	9.4	9.6	13.3	16.9	20.2	18.8	16.9	15.8	14.4	10.9	9.0	9.8	(36)
(37)			MCWBR	9.0	8.6	9.4	10.3	11.8	10.5	9.6	9.1	9.3	8.6	8.3	9.3	(37)
(38)		5% WB	MCDBR	9.5	9.3	11.9	14.4	17.9	16.3	14.7	13.5	12.4	10.1	8.9	9.8	(38)
(39)			MCWBR	9.3	8.8	9.4	9.8	11.2	10.1	9.4	8.9	9.3	8.8	8.6	9.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.343	0.350	0.373	0.384	0.391	0.379	0.381	0.365	0.360	0.348	0.334	0.332	(40)	
(41)		taud	2.198	2.274	2.250	2.262	2.281	2.352	2.354	2.412	2.420	2.385	2.266	2.169	(41)	
(42)		Ebn at Noon	180	229	251	266	271	275	272	271	256	229	185	156	(42)	
(43)		Edh at Noon	21	26	33	38	39	37	36	32	28	23	19	17	(43)	
(44)	All-Sky Solar Radiation	RadAvg	191	406	734	1174	1485	1517	1377	1133	828	479	235	142	(44)	
(45)		RadStd	20	36	73	118	132	152	116	95	43	42	25	15	(45)	

Historical Trends

		DBAvg		Heating		Cooling			Degree-Days			
				99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (29 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page