

ENNISKILLEN, United Kingdom

WMO: 039030

Lat: 54.395N

Lon: 7.644W

Elev: 47

StdP: 100.76

Time Zone: 0.00 (EUW)

Period: 94-13

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-4.6	-2.6	-5.7	2.4	-2.2	-3.9	2.7	-0.4	12.7	9.4	11.3	9.2	0.4	50	0.603

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.7	22.8	17.1	21.1	16.3	19.6	15.6	18.1	21.3	17.2	19.8	16.4	18.7	3.5	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.9	12.1	19.6	16.0	11.5	18.5	15.2	10.9	17.7	51.3	21.4	48.4	19.9	46.1	18.8	23.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.4	9.2	8.1	DB	-6.9	25.5	2.8	1.8	-9.0	26.8	-10.6	27.9	-12.2	28.9	-14.2	30.2	(4)
(5)			WB	-6.7	20.1	3.0	1.7	-8.9	21.3	-10.6	22.3	-12.3	23.2	-14.6	24.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.7	4.9	5.3	6.5	8.5	10.9	13.6	15.1	15.2	13.2	10.3	7.4	4.7	(6)	
	DBStd	4.68	3.19	2.88	2.75	2.70	2.67	2.33	2.00	2.07	2.16	2.70	3.05	3.70	(7)	
	HDD10.0	768	158	132	113	61	20	1	0	0	2	29	86	166	(8)	
	HDD18.3	3170	415	364	368	296	231	143	101	102	153	248	327	423	(9)	
	CDD10.0	646	1	2	4	14	48	109	159	159	99	39	8	2	(10)	
	CDD18.3	6	0	0	0	0	0	1	2	3	0	0	0	0	(11)	
	CDH23.3	39	0	0	0	0	2	11	12	14	0	0	0	0	(12)	
	CDH26.7	2	0	0	0	0	0	1	1	1	0	0	0	0	(13)	
(14) Wind	WSAvg	3.5	4.0	4.0	3.9	3.5	3.5	3.4	3.1	3.0	3.2	3.6	3.6	3.4	(14)	
(15) Precipitation	PrecAvg	1259	131	102	94	89	82	90	86	104	99	129	125	130	(15)	
	PrecMax	1532	225	244	173	136	154	173	149	202	172	246	269	283	(16)	
	PrecMin	914	28	21	27	28	15	38	34	19	45	27	57	39	(17)	
	PrecStd	177	52	58	39	31	41	36	33	43	37	63	48	62	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.5	12.9	15.2	18.6	23.0	24.8	24.9	25.2	21.3	17.6	14.9	13.1	(19)	
		MCWB	10.8	11.2	11.0	12.4	16.4	17.4	18.7	19.2	16.8	14.6	13.2	11.8	(20)	
	2%	DB	11.5	11.7	13.0	16.1	20.4	21.9	22.4	21.9	19.5	16.0	13.7	12.0	(21)	
		MCWB	10.1	10.2	10.4	11.4	14.8	16.0	17.3	17.1	15.9	14.0	12.3	10.7	(22)	
	5%	DB	10.6	10.7	11.9	14.5	17.8	19.8	20.6	20.2	18.1	15.1	12.7	10.9	(23)	
		MCWB	9.4	9.4	9.7	10.8	13.2	15.0	16.4	16.4	15.2	13.4	11.4	9.8	(24)	
	10%	DB	9.7	9.8	10.8	13.0	15.7	18.1	18.9	18.7	17.0	14.3	11.9	9.6	(25)	
		MCWB	8.5	8.3	8.9	10.1	12.1	14.1	15.5	15.6	14.4	12.7	10.6	8.5	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.2	11.6	12.2	13.8	17.0	18.5	19.6	19.6	17.9	15.4	13.6	12.2	(27)	
		MCDB	12.0	12.4	13.8	16.5	21.6	22.8	23.8	23.8	20.1	16.4	14.6	13.0	(28)	
	2%	WB	10.4	10.6	11.0	12.4	15.0	16.8	18.1	18.0	16.7	14.5	12.5	10.9	(29)	
		MCDB	11.3	11.5	12.3	14.8	19.4	20.8	21.4	20.9	18.5	15.5	13.4	11.7	(30)	
	5%	WB	9.6	9.6	10.1	11.3	13.7	15.6	17.0	17.1	15.8	13.7	11.7	9.9	(31)	
		MCDB	10.5	10.6	11.6	13.9	17.1	18.9	19.5	19.3	17.5	14.9	12.6	10.8	(32)	
	10%	WB	8.6	8.5	9.2	10.4	12.6	14.6	16.1	16.2	14.9	12.9	10.8	8.6	(33)	
		MCDB	9.6	9.7	10.6	12.8	15.1	17.5	18.4	18.2	16.5	14.2	11.8	9.6	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	4.9	5.7	6.5	7.6	7.8	7.2	6.7	6.7	6.7	6.0	5.3	5.2	(35)	
		MCDBR	5.2	5.4	7.4	9.4	11.2	10.4	9.4	8.8	8.0	6.1	5.0	5.5	(36)	
	5% WB	MCWBR	5.0	4.8	5.2	5.7	6.6	5.8	5.3	5.0	5.2	4.8	4.6	5.2	(37)	
		MCWBR	5.3	5.1	6.6	8.0	10.0	9.0	8.2	7.5	6.9	5.6	4.9	5.4	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.343	0.350	0.373	0.384	0.391	0.379	0.381	0.365	0.360	0.348	0.334	0.332	(40)	
		taud	2.198	2.274	2.250	2.262	2.281	2.352	2.354	2.412	2.420	2.385	2.266	2.169	(41)	
	Ebn at Noon		569	722	792	840	853	868	859	853	807	722	583	491	(42)	
		Edh at Noon	65	83	105	119	123	116	114	101	89	73	59	54	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.60	1.28	2.31	3.70	4.68	4.78	4.34	3.57	2.61	1.51	0.74	0.45	(44)	
	RadStd		0.06	0.12	0.23	0.37	0.42	0.48	0.37	0.30	0.14	0.13	0.08	0.05	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (29 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page