

BANGOR HARBOUR, United KingdomWMO: **039270**Lat: **54.664N**Lon: **5.668W**Elev: **36**StdP: **14.68**Time Zone: **0.00 (EUW)**Period: **94-07**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	33.6	35.3	25.0	19.1	38.1	27.2	21.2	38.0	45.6	43.0	41.7	43.0	13.0	270	0.733

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.7	73.7	64.4	70.7	62.6	67.9	61.2	65.3	72.1	63.6	69.3	62.1	66.8	12.3	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.5	84.8	68.8	61.0	80.2	66.7	59.7	76.7	64.9	30.2	72.1	28.9	69.5	27.8	67.0	73.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 36.1	31.9	28.6	DB	29.7	79.7	2.3	3.3	28.0	82.0	26.7	83.9	25.4	85.8	23.7	88.1	(4)
(5)			WB	28.5	70.2	2.1	2.3	27.0	71.9	25.8	73.2	24.6	74.5	23.1	76.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	51.5	43.6	43.6	45.4	48.7	53.1	57.6	60.9	61.5	58.1	52.9	48.0	44.5	(6)
(7)		DBStd	7.62	3.89	4.02	4.23	4.32	3.95	4.25	3.94	3.68	3.49	3.94	4.03	4.29	(7)
(8)		HDD50	903	200	184	152	74	14	1	0	0	0	18	84	176	(8)
(9)		HDD65	4948	662	600	608	489	369	225	141	123	209	375	510	637	(9)
(10)		CDD50	1461	2	4	9	35	110	228	337	355	244	108	24	5	(10)
(11)		CDD65	31	0	0	0	0	0	3	13	13	2	0	0	0	(11)
(12)		CDH74	79	0	0	0	0	0	11	38	28	2	0	0	0	(12)
(13)		CDH80	4	0	0	0	0	0	2	1	1	0	0	0	0	(13)
(14)	Wind	WSAvg	14.7	17.3	17.6	16.2	14.9	12.7	12.3	11.1	11.4	13.1	16.3	16.3	17.1	(14)
(15)	Precipitation	PrecAvg	35.7	3.5	2.7	2.4	2.4	2.6	2.6	2.8	3.0	2.6	3.7	3.9	3.5	(15)
(16)		PrecMax	48.1	7.0	5.6	4.9	4.3	7.0	7.8	6.5	7.2	6.1	7.2	8.5	7.0	(16)
(17)		PrecMin	27.6	0.9	0.6	0.7	0.6	0.3	0.8	0.7	0.2	0.0	1.1	1.6	1.8	(17)
(18)		PrecStd	4.6	1.6	1.3	1.1	1.0	1.5	1.7	1.2	1.6	1.6	1.8	1.7	1.3	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.2	56.7	58.2	65.5	69.4	74.6	78.1	77.5	72.1	63.3	59.0	57.4	(19)
(20)			MCWB	51.6	53.2	53.7	56.0	59.6	63.7	66.2	67.1	64.5	59.0	55.7	54.9	(20)
(21)		2%	DB	53.1	53.8	55.4	59.9	64.9	69.7	74.3	73.2	68.3	61.2	57.2	54.1	(21)
(22)			MCWB	50.3	50.7	51.4	53.5	56.9	60.8	64.4	64.7	61.9	57.7	54.6	51.5	(22)
(23)		5%	DB	51.4	51.9	53.5	57.1	61.5	66.8	70.6	70.0	65.5	59.9	55.6	52.5	(23)
(24)			MCWB	48.9	49.2	49.8	51.9	55.3	59.7	62.6	63.0	60.3	56.8	52.9	49.9	(24)
(25)		10%	DB	49.8	49.9	51.8	54.9	58.9	63.9	67.1	67.1	63.2	58.8	54.1	50.9	(25)
(26)			MCWB	47.6	47.1	48.7	50.3	53.6	58.1	61.0	61.4	58.9	56.0	51.4	48.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.1	53.7	54.3	57.0	61.0	64.7	67.7	68.1	66.0	60.0	56.8	55.1	(27)
(28)			MCDWB	54.2	56.2	57.9	63.0	67.5	71.0	75.2	76.4	70.7	62.7	58.5	57.3	(28)
(29)		2%	WB	50.8	51.2	52.1	54.6	58.0	62.1	65.0	65.5	62.9	58.6	54.9	52.2	(29)
(30)			MCDWB	52.7	53.2	54.8	59.3	63.6	68.8	73.2	71.7	67.2	60.7	56.7	53.8	(30)
(31)		5%	WB	49.5	49.4	50.4	52.5	55.9	60.1	63.1	63.9	61.0	57.5	53.4	50.5	(31)
(32)			MCDWB	51.2	51.7	53.0	56.5	60.5	65.5	69.4	68.8	64.2	59.6	55.3	52.2	(32)
(33)		10%	WB	48.0	47.5	48.9	50.6	54.2	58.6	61.5	62.2	59.5	56.5	51.9	49.0	(33)
(34)			MCDWB	49.6	49.7	51.5	54.0	58.2	63.3	66.3	66.3	62.5	58.6	54.0	50.7	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.2	7.1	7.6	8.8	9.6	9.6	9.9	9.7	8.7	6.9	6.6	6.3	(35)
(36)			MCDBR	8.3	8.9	9.8	12.7	14.4	14.8	15.8	14.7	12.3	8.0	8.0	8.1	(36)
(37)			MCWBR	7.9	8.4	7.7	8.0	8.7	8.6	8.4	8.0	7.9	6.6	7.8	8.1	(37)
(38)		5% WB	MCDBR	7.7	8.5	9.7	12.3	13.1	13.9	14.7	13.3	11.0	7.5	7.5	8.0	(38)
(39)			MCWBR	7.6	8.2	8.2	8.4	8.4	8.6	8.3	8.1	8.1	6.9	7.8	8.2	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.335	0.347	0.371	0.387	0.391	0.384	0.385	0.370	0.364	0.348	0.328	0.324	(40)	
(41)		taud	2.250	2.330	2.304	2.300	2.338	2.390	2.391	2.448	2.457	2.431	2.320	2.215	(41)	
(42)		Ebn at Noon	185	231	252	266	271	274	271	269	255	230	188	160	(42)	
(43)		Edh at Noon	19	25	32	36	37	36	35	31	27	22	18	16	(43)	
(44)	All-Sky Solar Radiation	RadAvg	175	391	761	1230	1572	1584	1504	1239	864	476	225	130	(44)	
(45)		RadStd	19	39	61	95	135	155	128	93	55	51	23	13	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (41 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page