

CLAREMORRIS, Ireland

WMO: 039700

Lat: 53.717N

Lon: 8.983W

Elev: 226

StdP: 14.58

Time Zone: 1.00 (IRL)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	26.0	29.0	23.2	17.7	29.1	25.9	20.1	31.8	31.2	44.0	28.5	44.9	5.2	90	0.642

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.8	72.7	62.9	69.2	61.3	66.4	59.8	64.8	70.0	62.8	66.8	61.3	64.9	7.7	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.7	86.0	67.3	61.1	81.1	64.8	59.7	77.0	63.1	29.9	70.2	28.4	66.9	27.4	65.1	76.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 25.3	22.1	19.5	DB	21.6	78.2	5.5	4.7	17.6	81.6	14.4	84.4	11.3	87.1	7.2	90.5	(4)
(5)			WB	21.1	68.2	5.5	3.2	17.1	70.5	13.9	72.4	10.8	74.2	6.8	76.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	49.2	41.4	41.5	43.6	47.1	51.6	56.0	58.6	58.2	55.2	50.2	45.2	41.7	(6)
(7)		DBStd	7.85	5.20	4.72	4.68	4.30	4.49	4.26	3.66	3.47	3.74	4.55	4.92	6.14	(7)
(8)		HDD50	1330	268	240	204	106	33	3	0	0	4	54	156	262	(8)
(9)		HDD65	5766	733	659	664	536	415	272	201	214	295	458	595	724	(9)
(10)		CDD50	1051	1	2	5	20	83	183	268	254	159	61	11	4	(10)
(11)		CDD65	9	0	0	0	0	0	2	4	3	0	0	0	0	(11)
(12)		CDH74	91	0	0	0	0	2	31	35	23	0	0	0	0	(12)
(13)		CDH80	11	0	0	0	0	0	5	4	2	0	0	0	0	(13)
(14)	Wind	WSAvg	9.6	10.8	10.8	10.8	10.0	9.9	8.9	8.3	8.4	8.7	9.4	9.5	10.3	(14)
(15)	Precipitation	PrecAvg	45.1	4.8	3.5	3.7	2.6	3.0	2.8	2.8	3.7	3.9	4.8	4.8	4.8	(15)
(16)		PrecMax	55.0	8.1	10.0	6.7	4.4	6.9	5.4	5.0	10.2	8.8	9.3	8.0	8.5	(16)
(17)		PrecMin	34.8	0.7	0.1	1.2	0.7	0.4	0.9	0.4	0.3	0.3	1.7	2.3	1.6	(17)
(18)		PrecStd	5.0	2.0	2.0	1.5	1.0	1.7	1.1	1.3	2.0	1.8	2.1	1.5	1.7	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.7	54.3	60.6	65.2	72.8	78.1	78.9	77.5	69.6	63.4	57.6	55.6	(19)
(20)			MCWB	51.9	51.3	52.1	54.9	62.0	65.0	67.8	68.1	61.1	59.3	55.5	54.1	(20)
(21)		2%	DB	51.9	52.3	55.1	60.5	67.4	71.8	71.8	70.1	66.1	60.5	55.6	53.6	(21)
(22)			MCWB	50.4	50.1	50.0	52.1	58.3	61.4	63.4	63.2	60.4	57.4	53.9	52.1	(22)
(23)		5%	DB	50.7	50.7	52.8	57.3	63.1	67.7	68.2	66.6	63.7	58.9	54.1	52.0	(23)
(24)			MCWB	49.2	48.7	49.0	51.0	55.2	59.5	61.4	60.7	58.9	56.3	52.5	50.7	(24)
(25)		10%	DB	49.4	49.2	51.1	54.8	59.8	64.1	65.3	64.3	61.8	57.4	52.8	50.5	(25)
(26)			MCWB	47.9	47.3	47.9	49.8	53.4	57.7	59.8	59.4	57.9	54.8	51.2	49.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.5	52.3	53.3	56.7	63.3	65.5	68.3	68.7	63.7	60.2	56.3	54.6	(27)
(28)			MCDWB	53.2	53.4	57.0	62.5	71.3	76.0	77.7	76.1	66.5	62.0	57.0	55.2	(28)
(29)		2%	WB	50.9	50.6	51.4	53.9	59.0	62.5	64.9	64.5	61.8	58.4	54.4	52.5	(29)
(30)			MCDWB	51.7	51.9	54.0	57.7	65.9	69.8	69.9	68.4	64.3	60.0	55.3	53.3	(30)
(31)		5%	WB	49.7	49.3	50.0	52.2	56.5	60.3	62.7	62.3	60.2	57.0	52.9	51.0	(31)
(32)			MCDWB	50.6	50.6	52.2	55.9	61.2	66.1	66.4	65.1	62.7	58.5	53.9	52.0	(32)
(33)		10%	WB	48.1	47.6	48.5	50.6	54.6	58.4	60.9	60.7	58.7	55.4	51.5	49.3	(33)
(34)			MCDWB	49.3	49.1	50.8	54.2	58.6	63.1	64.5	63.3	61.1	57.0	52.7	50.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	9.2	10.5	12.2	13.9	14.4	13.8	12.6	12.7	11.6	10.0	9.0	(35)	
(36)			MCDBR	9.2	10.2	13.8	17.4	20.1	20.3	17.3	15.7	14.9	11.7	9.4	9.4	(36)
(37)			MCWBR	9.2	8.8	9.7	10.9	11.8	11.5	10.1	9.5	9.8	9.3	8.7	9.3	(37)
(38)		5% WB	MCDWB	9.3	9.5	12.6	15.0	17.3	17.6	15.8	13.6	12.3	10.3	9.0	9.2	(38)
(39)			MCWBR	9.5	8.9	10.1	10.4	11.0	10.8	10.1	9.6	9.4	9.2	8.9	9.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.336	0.345	0.364	0.378	0.388	0.371	0.375	0.359	0.357	0.340	0.332	0.326	(40)	
(41)		taud	2.232	2.308	2.298	2.284	2.297	2.378	2.377	2.430	2.429	2.424	2.277	2.197	(41)	
(42)		Ebn at Noon	190	235	257	269	272	279	275	273	258	236	191	166	(42)	
(43)		Edh at Noon	21	26	32	37	38	36	35	32	28	23	19	17	(43)	
(44)	All-Sky Solar Radiation	RadAvg	203	420	776	1236	1545	1603	1420	1201	872	509	249	150	(44)	
(45)		RadStd	20	40	70	111	128	136	99	96	58	41	22	19	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(46)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (17 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page