

CLAREMORRIS, Ireland

WMO: 039700

Lat: 53.717N

Lon: 8.983W

Elev: 69

StdP: 100.50

Time Zone: 1.00 (IRL)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-3.3	-1.6	-4.9	2.5	-1.6	-3.4	2.9	-0.1	13.9	6.7	12.7	7.1	2.3	90	0.642

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.1	22.6	17.2	20.7	16.3	19.1	15.4	18.2	21.1	17.1	19.4	16.3	18.3	3.4	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.1	12.3	19.6	16.2	11.6	18.2	15.4	11.0	17.3	51.6	21.2	48.3	19.4	45.8	18.4	24.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.3	9.9	8.7	DB	-5.8	25.7	3.1	2.6	-8.0	27.6	-9.8	29.1	-11.5	30.6	-13.8	32.5	(4)
(5)			WB	-6.1	20.1	3.1	1.8	-8.3	21.4	-10.1	22.4	-11.8	23.4	-14.0	24.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	9.6	5.2	5.3	6.4	8.4	10.9	13.3	14.8	14.5	12.9	10.1	7.3	5.4
	DBStd	4.36	2.89	2.62	2.60	2.39	2.50	2.37	2.03	1.93	2.08	2.53	2.73	3.41
	HDD10.0	739	149	133	113	59	18	2	0	0	2	30	87	146
	HDD18.3	3203	407	366	369	298	231	151	112	119	164	254	331	402
	CDD10.0	584	1	1	3	11	46	102	149	141	88	34	6	2
	CDD18.3	5	0	0	0	0	0	1	2	2	0	0	0	0
	CDH23.3	51	0	0	0	0	1	17	19	13	0	0	0	0
	CDH26.7	6	0	0	0	0	0	3	2	1	0	0	0	0
Wind	WSAvg	4.3	4.8	4.8	4.8	4.5	4.4	4.0	3.7	3.7	3.9	4.2	4.3	4.6
Precipitation	PrecAvg	1146	122	90	95	65	75	71	71	95	100	121	122	122
	PrecMax	1397	205	253	170	112	175	138	127	259	224	236	203	216
	PrecMin	885	17	2	31	19	9	22	9	7	7	43	59	41
	PrecStd	127	52	51	37	26	44	29	34	50	46	53	38	44
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.1	12.4	15.9	18.4	22.6	25.6	26.0	25.3	20.9	17.5	14.2	13.1
		MCWB	11.1	10.7	11.2	12.7	16.7	18.3	19.9	20.1	16.2	15.2	13.0	12.3
	2%	DB	11.1	11.3	12.9	15.8	19.7	22.1	22.1	21.2	18.9	15.8	13.1	12.0
		MCWB	10.2	10.1	10.0	11.2	14.6	16.3	17.5	17.3	15.8	14.1	12.1	11.2
	5%	DB	10.4	10.4	11.6	14.0	17.3	19.8	20.1	19.2	17.6	15.0	12.3	11.1
		MCWB	9.6	9.3	9.4	10.6	12.9	15.3	16.4	16.0	15.0	13.5	11.4	10.4
	10%	DB	9.7	9.6	10.6	12.6	15.4	17.8	18.5	17.9	16.6	14.1	11.5	10.3
		MCWB	8.8	8.5	8.8	9.9	11.9	14.3	15.5	15.2	14.4	12.7	10.6	9.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.4	11.3	11.8	13.7	17.4	18.6	20.1	20.4	17.6	15.7	13.5	12.6
		MCDB	11.8	11.9	13.9	17.0	21.8	24.4	25.4	24.5	19.2	16.7	13.9	12.9
	2%	WB	10.5	10.3	10.8	12.2	15.0	16.9	18.3	18.1	16.6	14.7	12.4	11.4
		MCDB	10.9	11.0	12.2	14.3	18.8	21.0	21.1	20.2	17.9	15.5	12.9	11.8
	5%	WB	9.8	9.6	10.0	11.2	13.6	15.7	17.0	16.8	15.7	13.9	11.6	10.6
		MCDB	10.3	10.3	11.2	13.3	16.2	18.9	19.1	18.4	17.0	14.7	12.2	11.1
	10%	WB	9.0	8.7	9.2	10.3	12.5	14.7	16.1	16.0	14.8	13.0	10.8	9.6
		MCDB	9.6	9.5	10.4	12.3	14.8	17.3	18.1	17.4	16.2	13.9	11.5	10.2
Mean Daily Temperature Range	5% DB	MDBR	5.1	5.8	6.8	7.7	8.0	7.7	7.1	7.0	7.0	6.4	5.5	5.0
		MCDBR	5.1	5.7	7.7	9.7	11.2	11.3	9.6	8.7	8.3	6.5	5.2	5.2
		MCWBR	5.1	4.9	5.4	6.1	6.6	6.4	5.6	5.3	5.5	5.2	4.8	5.2
	5% WB	MCDBR	5.1	5.3	7.0	8.3	9.6	9.8	8.8	7.6	6.9	5.7	5.0	5.1
		MCWBR	5.3	5.0	5.6	5.8	6.1	6.0	5.6	5.3	5.2	5.1	5.0	5.2
Clear-Sky Solar Irradiance	taub	0.336	0.345	0.364	0.378	0.388	0.371	0.375	0.359	0.357	0.340	0.332	0.326	
	taud	2.232	2.308	2.298	2.284	2.297	2.378	2.377	2.430	2.429	2.424	2.277	2.197	
	Ebn at Noon	600	742	811	849	859	878	867	862	814	744	602	524	
	Edh at Noon	65	82	101	117	121	113	111	100	89	72	61	55	
All-Sky Solar Radiation	RadAvg	0.64	1.32	2.44	3.90	4.87	5.05	4.48	3.79	2.75	1.61	0.78	0.47	
	RadStd	0.06	0.13	0.22	0.35	0.40	0.43	0.31	0.30	0.18	0.13	0.07	0.06	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (17 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page