

STYKKISHOLMUR, Iceland

WMO: **040130**Lat: **65.0740N**Lon: **22.7339W**Elev: **26**StdP: **14.68**Time Zone: **0.00 (E00)**Period: **01-19**WBAN: **99999**

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	17.7	20.6	8.4	8.5	19.2	11.9	10.1	21.3	50.3	38.1	41.8	36.5	11.8	20	0.818

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.0	60.1	54.5	58.3	53.4	56.9	52.5	55.7	58.8	54.3	57.3	53.1	56.1	9.4	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
53.8	61.7	57.3	52.3	58.3	56.0	51.2	55.9	55.1	23.7	59.1	22.8	57.6	22.1	56.2	67.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 34.0	28.3	26.9	13.7	65.0	3.0	2.5	11.5	66.8	9.8	68.2	8.1	69.7	5.9	71.5		
(5)			11.9	58.3	2.0	3.0	10.5	60.5	9.3	62.3	8.2	64.0	6.7	66.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	40.7	32.7	32.5	33.7	37.8	42.5	49.0	51.9	51.3	47.0	40.4	35.6	33.2
	DBStd	8.82	5.83	6.24	5.67	5.36	4.80	3.42	3.04	3.15	4.56	5.40	5.79	6.47
	HDD50	3588	535	489	505	368	235	57	14	22	110	298	433	522
	HDD65	8874	1000	909	970	817	696	479	406	425	541	761	883	987
	CDD50	189	0	0	0	1	3	28	73	62	20	2	0	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	12.1	13.9	14.3	13.6	12.4	11.3	9.8	9.3	9.4	11.5	12.8	13.7	13.6
Precipitation	PrecAvg	27.8	2.8	3.0	2.8	1.9	1.4	1.5	1.5	2.0	2.2	2.9	2.7	2.8
	PrecMax	40.7	8.3	6.9	7.8	4.1	3.2	3.1	3.9	5.6	4.1	8.0	10.5	6.0
	PrecMin	19.3	0.5	0.0	0.1	0.4	0.2	0.1	0.2	0.3	0.6	0.4	0.7	0.7
	PrecStd	5.9	1.7	1.5	1.6	1.0	0.9	0.7	0.8	1.1	0.8	1.6	1.7	1.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	47.7	47.6	49.0	54.2	57.2	61.1	63.5	61.8	60.1	54.8	50.6	49.7
		MCWB	45.6	45.0	45.4	48.0	50.1	53.3	57.0	57.6	54.4	50.3	47.7	46.8
	2%	DB	45.8	45.7	46.7	49.7	53.4	57.9	60.6	59.1	56.5	52.0	48.2	47.3
		MCWB	43.5	43.1	44.0	45.1	47.6	51.7	55.0	54.5	52.6	48.1	45.6	45.1
	5%	DB	43.7	43.9	44.6	47.5	51.2	56.1	58.6	57.6	54.7	50.2	45.8	45.2
		MCWB	41.4	41.4	42.1	43.5	46.3	50.9	53.6	53.6	51.2	47.0	43.0	42.9
	10%	DB	40.9	41.4	41.9	45.5	49.5	54.6	57.0	56.2	53.2	48.3	43.3	42.7
		MCWB	38.4	39.1	39.2	41.8	45.3	50.0	52.6	52.5	50.0	45.6	40.8	40.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.4	46.0	46.2	48.6	50.7	54.7	57.8	58.7	55.1	51.3	48.2	47.3
		MCDB	47.7	47.1	48.0	53.5	55.9	58.8	62.2	61.0	58.6	53.8	50.2	48.8
	2%	WB	43.8	43.3	44.1	45.7	48.5	52.8	55.7	55.8	53.2	48.8	45.7	45.2
		MCDB	45.4	45.2	46.4	49.2	52.3	56.6	59.5	58.0	55.8	51.3	47.8	47.1
	5%	WB	41.5	41.5	42.1	43.8	47.0	51.5	54.4	54.3	51.9	47.3	43.2	43.1
		MCDB	43.6	43.8	44.5	47.1	50.6	55.2	57.8	56.7	54.4	49.9	45.6	45.1
	10%	WB	38.6	39.3	39.4	42.1	45.6	50.4	53.1	53.0	50.4	45.7	41.0	40.5
		MCDB	40.6	41.1	41.7	45.1	49.0	54.0	56.4	55.6	52.9	48.2	43.2	42.6
Mean Daily Temperature Range	5% DB	MDBR	6.5	6.7	6.8	8.0	8.3	8.2	8.0	7.5	6.9	6.3	6.3	6.9
		MCDBR	8.4	8.9	8.8	10.1	10.3	10.2	10.4	8.7	7.6	7.6	8.3	8.7
		MCWBR	8.0	8.2	8.0	7.3	6.8	6.6	6.7	6.0	5.8	6.5	8.2	8.1
	5% WB	MCDBR	8.5	8.7	8.7	9.7	9.3	8.8	9.2	7.6	7.2	7.6	8.4	8.7
		MCWBR	8.2	8.3	8.2	7.6	6.5	6.2	6.3	5.9	6.1	7.0	8.5	8.6
Clear-Sky Solar Irradiance	taub	0.389	0.300	0.331	0.352	0.364	0.351	0.354	0.349	0.339	0.297	0.361	0.377	
	taud	2.479	2.187	2.262	2.325	2.354	2.452	2.479	2.501	2.441	2.302	2.627	2.604	
	Ebn at Noon	72	183	234	259	266	274	270	260	233	185	87	32	
	Edh at Noon	8	18	26	31	33	31	29	26	22	16	7	4	
All-Sky Solar Radiation	RadAvg	28	145	472	998	1491	1724	1491	1132	622	242	49	9	
	RadStd	2	25	66	90	166	224	146	96	59	21	4	1	