

BERGSTADIR, Iceland

WMO: 040530

Lat: 65.700N

Lon: 19.617W

Elev: 43

StdP: 100.81

Time Zone: 0.00 (E00)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-12.6	-10.4	-15.1	1.0	-12.1	-12.7	1.3	-10.0	26.3	3.9	23.9	2.4	2.8	160	0.920

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.9	17.3	12.6	15.9	11.8	14.9	11.2	13.4	16.4	12.5	15.2	11.7	14.2	7.0	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.7	8.6	14.6	10.9	8.1	13.7	10.1	7.7	13.0	37.7	16.6	35.4	15.3	33.4	14.2	17.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.9	18.2	15.5	DB	-14.2	20.5	2.1	1.2	-15.7	21.3	-17.0	22.1	-18.1	22.7	-19.6	23.6	(4)
(5)			WB	-14.9	15.0	1.9	1.4	-16.2	16.0	-17.3	16.9	-18.4	17.7	-19.7	18.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	3.8	-0.5	-1.2	-0.5	2.3	5.6	8.5	10.7	10.2	7.4	2.8	0.4	-0.9	(6)	
	DBStd	5.66	4.04	4.47	4.09	3.59	3.26	2.81	2.68	2.49	3.42	3.57	3.70	4.68	(7)	
	HDD10.0	2394	327	315	327	231	142	61	24	28	91	223	289	337	(8)	
	HDD18.3	5321	585	548	585	480	396	294	238	252	328	481	539	596	(9)	
	CDD10.0	115	0	0	0	1	4	17	45	34	13	1	0	0	(10)	
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)	
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)	
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
(14) Wind	WSAvg	6.8	7.9	7.8	7.6	6.9	6.6	6.1	5.5	5.6	6.7	6.5	7.4	7.8	(14)	
(15) Precipitation	PrecAvg	519	41	43	46	30	27	29	38	47	61	50	54	52	(15)	
	PrecMax	643	80	91	110	51	70	116	121	86	145	114	93	105	(16)	
	PrecMin	448	0	18	19	8	7	5	8	13	25	15	21	13	(17)	
	PrecStd	57	20	18	20	10	16	23	23	20	29	24	21	22	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.8	9.0	10.0	13.4	16.3	18.1	19.7	18.3	17.4	12.7	10.6	10.1	(19)	
		MCWB	6.4	7.0	7.1	9.1	10.1	12.1	13.8	13.5	12.3	9.5	8.3	7.6	(20)	
	2%	DB	7.6	7.5	8.0	11.0	13.6	15.9	17.7	16.2	15.1	11.1	8.5	8.2	(21)	
		MCWB	5.2	5.3	5.6	7.4	9.0	11.2	13.0	12.2	11.4	8.5	6.0	5.8	(22)	
	5%	DB	6.4	6.5	6.7	9.3	12.0	14.5	16.2	15.2	13.8	9.7	7.0	6.7	(23)	
		MCWB	4.3	4.5	4.5	6.3	8.2	10.2	12.1	11.7	10.4	7.4	5.0	4.4	(24)	
	10%	DB	5.1	5.0	5.2	7.9	10.6	13.2	14.9	14.2	12.6	8.1	5.5	5.3	(25)	
		MCWB	3.2	3.2	3.2	5.4	7.4	9.5	11.5	11.1	9.7	6.2	3.7	3.3	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.8	7.5	7.3	9.5	10.8	13.7	14.7	14.4	12.9	9.9	8.4	7.6	(27)	
		MCDB	8.5	8.7	9.6	12.6	15.1	17.6	18.3	17.0	16.5	12.1	10.5	9.7	(28)	
	2%	WB	5.5	5.6	5.8	7.7	9.5	11.7	13.6	13.1	11.7	8.6	6.3	6.0	(29)	
		MCDB	7.3	7.2	7.9	10.4	13.0	14.7	16.9	15.6	14.4	10.8	8.2	8.0	(30)	
	5%	WB	4.4	4.5	4.6	6.5	8.5	10.6	12.7	12.2	10.8	7.5	5.0	4.6	(31)	
		MCDB	6.2	6.3	6.6	9.0	11.6	13.7	15.5	14.6	13.4	9.5	6.9	6.5	(32)	
	10%	WB	3.3	3.3	3.3	5.5	7.6	9.8	11.9	11.3	9.9	6.3	3.9	3.5	(33)	
		MCDB	5.1	4.9	5.0	7.8	10.3	12.7	14.4	13.5	12.3	8.0	5.3	5.2	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	4.7	4.6	4.9	5.3	5.2	5.1	4.9	5.1	4.9	4.4	4.5	4.9	(35)	
		MCDBR	5.2	5.2	5.8	7.0	7.4	7.2	7.2	6.4	6.2	5.8	6.1	5.5	(36)	
	5% WB	MCWBR	4.5	4.5	4.6	4.7	4.5	4.5	4.2	4.2	4.2	4.6	5.3	4.6	(37)	
		MCWBR	5.3	5.4	5.7	6.7	6.8	6.5	6.4	5.8	5.8	5.7	6.2	5.5	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.390	0.289	0.317	0.349	0.351	0.350	0.352	0.338	0.325	0.293	0.380	0.398	(40)	
		taud	2.555	2.112	2.199	2.186	2.300	2.411	2.450	2.494	2.456	2.211	2.618	2.578	(41)	
	Ebn at Noon		218	560	740	806	849	861	848	826	748	552	226	60	(42)	
		Edh at Noon	23	57	85	110	109	100	94	82	67	51	21	12	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.08	0.47	1.60	3.39	4.75	5.50	4.58	3.51	1.96	0.74	0.16	0.02	(44)	
	RadStd		0.01	0.05	0.15	0.32	0.33	0.53	0.35	0.28	0.11	0.07	0.01	0.00	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (11 neighbors)		+0.49	+0.78	+1.20	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page