

AKUREYRI 1, Iceland

WMO: 040630

Lat: 65.6856N

Lon: 18.1002W

Elev: 23

StdP: 101.05

Time Zone: 0.00 (E00)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-14.9	-12.1	-17.6	0.8	-14.6	-15.0	1.0	-11.7	17.6	4.8	14.8	3.0	2.3	190	0.774

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.2	18.9	13.1	17.2	12.2	16.1	11.6	13.9	17.7	12.9	16.3	12.1	15.4	5.0	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.0	8.8	15.3	11.0	8.2	14.2	10.1	7.7	13.4	39.2	17.9	36.5	16.4	34.4	15.3	21.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.9	11.0	9.5	DB	-19.5	22.3	3.3	1.4	-21.8	23.3	-23.8	24.1	-25.6	24.9	-27.9	25.9	(4)
(5)			WB	-19.8	16.8	3.1	1.5	-22.1	17.9	-23.9	18.7	-25.7	19.6	-28.0	20.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	3.9	-1.1	-1.3	-0.4	2.4	5.9	9.4	11.3	10.6	7.9	3.0	0.1	-1.2	(6)
(7)		DBStd	6.18	4.80	4.93	4.60	4.01	3.44	2.94	2.59	2.61	3.57	4.05	4.45	5.27	(7)
(8)		HDD10.0	2377	344	317	322	229	133	46	16	23	82	218	298	347	(8)
(9)		HDD18.3	5266	602	551	580	478	386	268	219	240	313	474	548	606	(9)
(10)		CDD10.0	153	0	0	0	2	6	28	54	42	19	2	1	0	(10)
(11)		CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)
(12)		CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)
(13)		CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	3.9	4.2	4.3	4.2	4.2	3.9	3.6	3.5	3.7	3.5	3.8	4.2	(14)	
(15)	Precipitation	PrecAvg	517	56	44	46	28	22	23	34	37	45	64	64	59	(15)
(16)		PrecMax	743	130	128	127	66	62	72	73	109	141	176	141	158	(16)
(17)		PrecMin	320	1	1	7	5	1	2	9	5	4	4	14	13	(17)
(18)		PrecStd	96	29	27	22	13	15	15	15	21	27	34	30	31	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.0	10.2	11.9	14.9	17.2	20.1	21.2	20.3	18.4	14.2	12.9	11.2	(19)
(20)			MCWB	7.2	6.7	7.6	8.9	11.0	13.6	14.9	13.9	13.0	10.1	9.3	7.3	(20)
(21)		2%	DB	8.9	8.7	9.8	12.2	15.0	17.9	19.0	18.1	16.3	12.6	9.8	9.0	(21)
(22)			MCWB	5.9	5.6	6.4	7.7	9.6	11.7	13.3	13.1	11.8	9.1	7.0	6.2	(22)
(23)		5%	DB	7.2	7.1	8.0	10.3	13.1	16.0	17.2	16.6	15.0	11.0	7.8	7.2	(23)
(24)			MCWB	4.4	4.4	4.9	6.5	8.6	11.0	12.5	12.2	11.0	8.0	5.3	4.6	(24)
(25)		10%	DB	5.7	5.6	6.1	8.9	11.5	14.5	15.9	15.1	13.5	9.1	6.1	5.8	(25)
(26)			MCWB	3.2	3.1	3.4	5.5	7.4	10.2	11.9	11.5	9.9	6.6	4.0	3.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.7	7.1	8.1	9.7	11.5	14.2	15.9	15.1	13.7	10.7	9.5	7.7	(27)
(28)			MCDWB	10.3	9.7	11.3	13.9	16.4	19.2	20.1	18.7	17.4	13.6	12.5	10.4	(28)
(29)		2%	WB	5.9	5.6	6.3	8.0	10.0	12.4	14.1	13.6	12.2	9.4	7.0	6.2	(29)
(30)			MCDWB	8.6	8.2	9.4	11.7	14.4	16.5	17.8	17.1	15.8	12.3	9.2	8.8	(30)
(31)		5%	WB	4.5	4.5	4.9	6.7	8.9	11.3	13.0	12.7	11.1	8.1	5.3	4.8	(31)
(32)			MCDWB	7.1	7.0	7.7	10.0	12.6	15.0	16.4	15.8	14.5	10.7	7.3	7.1	(32)
(33)		10%	WB	3.2	3.2	3.5	5.5	7.8	10.5	12.1	11.8	10.2	6.9	4.1	3.5	(33)
(34)			MCDWB	5.4	5.4	5.9	8.5	10.9	13.9	15.2	14.8	13.0	8.7	5.8	5.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.2	6.3	6.1	6.4	6.6	6.7	6.2	6.5	6.5	5.6	5.8	6.5	(35)
(36)			MCDBR	7.0	7.4	7.8	8.7	9.5	9.7	9.1	9.2	8.4	7.7	7.7	7.4	(36)
(37)			MCWBR	5.9	6.0	6.0	6.0	5.8	5.8	5.5	5.8	5.6	6.0	6.5	6.0	(37)
(38)		5% WB	MCDWB	6.9	7.2	7.8	8.6	8.8	8.7	8.1	8.3	8.1	7.2	7.4	7.3	(38)
(39)			MCWBR	5.9	6.0	6.1	6.1	5.7	5.6	5.3	5.7	5.8	5.9	6.4	6.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.255	0.306	0.330	0.364	0.372	0.382	0.367	0.351	0.333	0.294	N/A	0.249	(40)	
(41)		taud	1.881	2.007	2.074	2.038	2.114	2.253	2.367	2.413	2.364	2.147	N/A	1.857	(41)	
(42)		Ebn at Noon	168	515	710	781	821	824	830	807	729	538	N/A	18	(42)	
(43)		Edh at Noon	23	64	96	128	131	117	102	88	73	53	N/A	6	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.09	0.51	1.71	3.56	4.96	5.66	4.67	3.56	2.02	0.79	0.17	0.02	(44)	
(45)		RadStd	0.01	0.05	0.14	0.28	0.28	0.51	0.36	0.27	0.11	0.06	0.01	0.00	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(47) Regional (8 neighbors)		+0.32	N/A	+0.91	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Nomenclature: See separate page