

RAUFARHOFN, Iceland

WMO: 040770

Lat: 66.456N

Lon: 15.953W

Elev: 33

StdP: 14.68

Time Zone: 0.00 (E00)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	11.7	15.0	3.1	6.5	12.4	7.0	7.9	15.4	48.0	25.2	44.2	26.9	15.7	230	0.911

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.8	61.7	54.2	58.3	52.5	55.9	51.1	55.1	60.3	53.1	57.6	51.6	55.1	13.0	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
52.0	57.6	57.7	50.4	54.4	55.2	49.2	51.9	53.4	23.3	60.5	22.1	57.9	21.2	55.3	63.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 39.3	32.9	29.0	DB	3.9	69.2	3.3	3.7	1.5	71.9	-0.5	74.0	-2.3	76.1	-4.8	78.7	(4)
(5)			WB	2.6	59.0	3.4	2.1	0.1	60.5	-1.9	61.7	-3.9	62.9	-6.4	64.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	37.5	30.2	29.4	30.1	33.9	38.2	44.3	48.4	48.7	44.3	37.5	32.9	31.3
	DBStd	9.16	6.19	6.81	7.04	6.34	5.33	5.13	4.58	4.08	5.60	6.02	6.42	6.75
	HDD50	4671	615	578	618	484	366	185	85	75	185	387	514	579
	HDD65	10047	1080	998	1083	934	830	622	513	506	622	851	964	1044
	CDD50	103	0	0	0	1	2	13	37	35	14	1	0	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	14.3	18.0	17.4	16.4	13.7	12.6	12.1	11.3	11.3	12.6	15.1	15.0	16.0
Precipitation	PrecAvg	25.6	2.4	2.0	2.2	1.6	1.3	1.5	1.9	2.0	2.6	3.1	2.8	2.3
	PrecMax	34.1	3.9	4.3	4.2	2.4	2.8	4.0	4.5	3.9	5.1	5.2	4.7	4.9
	PrecMin	18.3	0.9	0.8	0.7	0.5	0.2	0.2	0.6	0.3	0.7	0.5	1.2	0.9
	PrecStd	3.9	0.9	1.0	0.9	0.4	0.7	0.9	1.1	1.1	1.3	1.3	0.8	1.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	45.4	46.2	48.5	56.1	57.6	65.2	66.7	66.0	61.8	55.5	51.1	50.0
		MCWB	41.9	43.1	44.2	48.6	49.6	54.7	56.6	55.0	54.6	49.7	47.7	45.0
	2%	DB	42.2	43.1	44.4	49.7	52.7	58.5	61.2	60.2	57.5	51.2	44.8	45.5
		MCWB	39.2	40.3	40.5	44.6	47.1	51.2	54.1	54.4	51.6	47.2	42.0	41.9
	5%	DB	40.2	40.6	41.4	45.4	49.2	54.6	57.6	57.3	54.6	48.0	42.6	42.0
		MCWB	37.9	38.2	38.5	41.6	44.8	49.2	52.6	52.7	49.8	45.6	40.8	39.6
	10%	DB	38.3	38.7	39.2	42.3	46.3	51.9	55.0	54.9	51.8	45.7	41.3	40.1
		MCWB	36.5	36.7	36.7	39.6	43.1	47.7	51.0	51.3	48.7	43.8	39.7	38.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	42.3	43.4	44.3	48.6	50.6	55.4	57.6	57.0	55.9	50.3	47.8	45.0
		MCDB	44.3	45.8	48.5	55.2	56.9	62.8	64.5	62.8	60.8	54.6	51.3	49.2
	2%	WB	39.6	40.4	40.8	44.6	47.5	51.9	55.0	54.9	52.2	47.5	42.7	42.0
		MCDB	41.7	42.8	43.6	49.4	52.0	57.2	60.3	59.4	56.2	50.5	44.2	44.8
	5%	WB	38.0	38.4	38.8	41.8	45.0	49.5	52.9	53.0	50.5	45.8	41.1	40.1
		MCDB	39.9	40.3	41.4	44.9	48.6	54.0	56.9	56.8	54.0	47.9	42.3	42.0
	10%	WB	36.6	36.8	36.9	39.8	43.2	47.8	51.2	51.5	48.7	43.9	39.9	38.3
		MCDB	38.2	38.5	38.9	42.2	46.1	51.6	54.6	54.4	51.5	45.6	41.2	39.9
Mean Daily Temperature Range	5% DB	MDBR	7.9	8.5	8.2	8.1	7.6	7.9	7.3	7.8	8.1	7.0	7.5	8.3
		MCDBR	9.2	10.2	10.4	13.4	13.7	14.6	13.5	13.0	12.4	10.8	8.8	10.4
		MCWBR	8.3	9.7	8.9	10.3	9.9	9.0	8.1	8.8	8.5	8.5	8.4	9.6
	5% WB	MCDBR	8.6	9.9	10.0	12.1	13.0	13.5	12.3	11.8	11.7	9.9	7.7	10.0
		MCWBR	8.1	9.5	8.7	9.5	9.7	8.8	7.8	8.2	8.4	7.8	7.6	9.3
Clear-Sky Solar Irradiance	taub	0.377	0.296	0.322	0.351	0.355	0.344	0.348	0.342	0.333	0.301	0.370	0.382	
	taud	2.536	2.173	2.303	2.312	2.385	2.485	2.505	2.530	2.463	2.233	2.523	2.551	
	Ebn at Noon	58	171	233	256	268	275	270	260	232	166	54	10	
	Edh at Noon	6	16	24	31	32	30	28	25	21	15	6	3	
All-Sky Solar Radiation	RadAvg	18	114	402	870	1269	1540	1310	990	559	186	35	2	
	RadStd	2	15	53	85	121	139	117	81	40	19	4	0	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(47) Regional (7 neighbors)	+0.67	+1.87	N/A	N/A	N/A	N/A	N/A	-212	N/A	N/A	N/A

Nomenclature: See separate page