

HORNAFJORDUR AP, IcelandWMO: **040820**Lat: **64.296N**Lon: **15.227W**Elev: **7**StdP: **101.24**Time Zone: **0.00 (E00)**Period: **94-18**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-8.2	-6.6	-16.0	0.9	-7.6	-13.8	1.1	-6.0	21.8	2.3	19.5	2.2	5.9	340	0.807

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.4	15.7	12.0	14.4	11.5	13.6	11.1	13.0	14.5	12.3	13.6	11.7	12.9	4.9	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.2	8.8	13.4	11.6	8.5	12.8	11.0	8.2	12.3	36.5	14.6	35.0	13.7	33.6	13.0	18.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.6	15.1	12.9	-10.2	19.3	1.8	2.2	-11.5	20.9	-12.6	22.2	-13.6	23.4	-14.9	25.0		
(5)			-11.3	14.7	1.8	1.3	-12.6	15.7	-13.7	16.5	-14.7	17.2	-16.0	18.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	5.1	0.9	0.8	1.5	3.6	6.3	9.2	10.9	10.9	8.6	5.2	2.4	1.0
	DBStd	4.74	3.31	3.48	3.40	3.14	2.38	1.94	1.51	1.55	2.34	2.96	3.34	3.53
	HDD10.0	1873	282	257	264	193	114	36	8	8	52	149	229	281
	HDD18.3	4822	540	491	523	443	372	273	231	232	293	407	479	539
	CDD10.0	93	0	0	0	0	1	12	36	34	9	1	0	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	5.3	6.0	6.2	6.1	5.7	5.3	4.6	3.9	3.8	5.0	5.4	5.9	6.0
Precipitation	PrecAvg	1397	152	137	118	91	81	74	84	103	134	169	127	146
	PrecMax	2063	380	277	257	267	234	186	232	233	332	353	350	324
	PrecMin	850	38	4	2	13	14	6	16	6	24	39	28	34
	PrecStd	256	74	66	60	52	51	42	53	53	69	79	74	70
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.5	8.2	8.9	11.7	13.4	17.2	17.6	18.1	15.1	11.7	9.5	8.9
		MCWB	7.2	7.1	7.0	8.3	9.4	11.9	13.0	14.0	11.5	10.2	8.4	8.0
	2%	DB	7.1	7.3	7.8	9.7	11.6	14.4	15.4	15.4	13.2	10.7	8.7	7.9
		MCWB	6.2	6.6	6.7	7.4	8.6	10.9	12.2	12.2	10.9	9.5	7.8	7.2
	5%	DB	6.2	6.5	7.0	8.7	10.6	13.1	14.3	14.2	12.4	10.1	8.0	7.1
		MCWB	5.3	5.8	5.9	6.9	8.1	10.3	11.7	11.5	10.5	9.1	7.1	6.3
	10%	DB	5.5	5.8	6.2	7.9	9.8	12.1	13.5	13.3	11.7	9.4	7.2	6.1
		MCWB	4.5	5.0	4.9	6.4	7.7	9.7	11.3	11.1	10.1	8.4	6.2	5.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.8	7.8	8.0	9.2	10.5	12.7	14.3	14.5	12.6	10.7	8.7	8.5
		MCDB	8.6	8.0	8.4	10.6	12.4	15.8	16.6	17.4	13.6	11.0	9.0	8.6
	2%	WB	6.6	6.8	7.1	8.1	9.4	11.5	13.0	13.0	11.7	10.1	8.1	7.4
		MCDB	7.0	7.1	7.6	9.0	10.7	13.4	14.4	14.4	12.5	10.4	8.6	7.7
	5%	WB	5.7	6.0	6.2	7.4	8.7	10.8	12.3	12.3	11.1	9.4	7.4	6.5
		MCDB	6.2	6.4	6.8	8.3	9.9	12.4	13.6	13.5	12.0	9.9	7.9	6.9
	10%	WB	4.7	5.0	5.2	6.6	8.1	10.2	11.7	11.7	10.6	8.6	6.5	5.2
		MCDB	5.3	5.7	6.0	7.7	9.3	11.6	13.0	12.8	11.4	9.2	7.2	6.0
Mean Daily Temperature Range	5% DB	MDBR	4.0	4.2	4.5	4.9	4.8	4.5	4.4	4.8	4.3	3.9	4.0	4.2
		MCDBR	4.5	4.1	4.9	5.6	5.8	6.0	5.9	6.2	5.1	3.7	4.2	4.6
		MCWBR	4.4	4.5	4.4	4.2	4.0	3.7	3.8	4.1	3.5	3.3	4.3	4.7
	5% WB	MCDBR	4.4	4.1	4.5	4.7	5.0	5.2	5.2	5.3	4.3	3.3	4.1	4.5
		MCWBR	4.6	4.6	4.5	3.9	3.7	3.5	3.6	3.7	3.4	3.4	4.5	5.0
Clear-Sky Solar Irradiance	taub	0.224	0.314	0.335	0.375	0.367	0.365	0.368	0.357	0.353	0.316	0.393	0.401	
	taud	2.092	2.109	2.188	2.120	2.253	2.340	2.372	2.406	2.313	2.185	2.493	2.432	
	Ebn at Noon	353	563	734	785	838	849	835	810	716	553	248	93	
	Edh at Noon	24	64	90	121	116	109	103	91	80	58	27	16	
All-Sky Solar Radiation	RadAvg	0.12	0.55	1.71	3.35	4.61	5.00	4.45	3.48	2.00	0.80	0.19	0.05	
	RadStd	0.01	0.08	0.13	0.39	0.41	0.45	0.31	0.27	0.16	0.08	0.02	0.00	