

EGILSSTADIR, Iceland

WMO: 040890

Lat: 65.283N

Lon: 14.402W

Elev: 76

StdP: 14.66

Time Zone: 0.00 (E00)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	6.8	10.8	2.9	6.4	7.5	6.9	7.8	12.4	38.4	36.6	33.3	36.8	3.7	140	0.800

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.1	66.5	56.4	64.0	54.9	61.0	53.3	57.5	65.0	55.5	62.1	53.7	59.8	11.1	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
53.3	60.6	62.2	51.6	56.8	59.1	50.0	53.5	57.2	24.8	65.5	23.5	62.3	22.4	59.9	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 29.6	25.0	21.9	DB	1.0	74.2	4.3	3.8	-2.2	77.0	-4.7	79.2	-7.1	81.3	-10.3	84.1	(4)
(5)			WB	0.9	61.7	3.9	2.8	-1.9	63.7	-4.2	65.3	-6.4	66.9	-9.2	68.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	38.9	30.3	30.0	31.1	35.6	41.4	47.6	51.7	50.8	46.3	38.6	32.9	30.0		
	DBStd	10.60	7.85	8.12	7.91	7.21	6.17	5.42	4.77	4.68	6.05	6.76	7.67	8.44		
	HDD50	4288	611	560	587	434	274	108	35	47	141	357	514	620		
	HDD65	9525	1075	980	1052	883	732	522	412	441	561	818	964	1085		
	CDD50	237	0	0	0	1	7	36	88	71	30	4	0	0		
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH74	7	0	0	0	0	0	1	3	3	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
(14) Wind	WSAvg	9.8	10.6	10.8	10.5	10.2	10.3	9.6	9.0	8.5	9.5	9.4	9.2	10.2		
(15) Precipitation	PrecAvg	45.1	5.4	4.0	3.6	2.7	1.9	2.0	2.0	2.7	4.4	6.5	5.4	4.5		
	PrecMax	69.7	10.1	7.2	7.8	6.8	5.2	3.9	5.3	6.2	9.5	11.1	20.1	8.0		
	PrecMin	36.9	1.3	1.3	1.7	1.1	0.4	0.5	0.3	0.6	0.9	0.9	0.8	2.0		
	PrecStd	7.0	2.4	1.8	1.4	1.4	1.3	1.1	1.1	1.6	2.3	3.0	4.3	1.9		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.3	48.6	52.1	56.9	64.4	69.6	71.8	70.0	64.6	57.3	53.4	51.4		
		MCWB	45.3	43.3	46.1	48.1	53.1	56.5	59.8	59.6	55.0	50.8	47.2	46.9		
	2%	DB	46.5	46.5	48.1	52.1	58.9	64.0	67.7	64.8	60.9	54.0	49.6	48.1		
		MCWB	42.4	42.0	43.0	45.7	49.5	53.6	57.9	55.9	53.6	48.1	45.5	43.9		
	5%	DB	43.2	44.5	44.9	49.8	55.2	60.6	64.2	62.4	57.6	52.1	46.4	44.8		
		MCWB	39.5	40.4	40.5	44.3	47.3	51.8	55.5	54.8	51.4	46.9	42.8	41.0		
	10%	DB	41.1	42.4	42.5	46.7	51.9	57.4	60.9	59.3	55.6	49.7	43.2	41.8		
		MCWB	37.8	38.7	38.4	41.8	45.5	50.0	54.0	52.8	50.1	45.6	40.0	38.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	44.8	44.1	46.4	48.9	53.5	57.2	60.3	60.8	56.3	51.0	47.6	47.4		
		MCDB	48.3	47.7	51.5	55.4	63.4	67.5	68.7	69.2	62.4	55.9	51.5	51.2		
	2%	WB	41.6	41.9	42.8	46.3	50.2	54.2	58.3	56.9	54.0	49.1	44.7	43.5		
		MCDB	45.1	45.6	47.0	51.4	58.0	62.1	66.0	63.9	59.7	53.7	47.7	47.2		
	5%	WB	39.6	40.2	40.6	44.2	47.8	52.0	56.0	54.7	52.2	47.3	42.3	41.0		
		MCDB	42.7	43.9	44.6	48.8	54.3	59.2	62.6	60.8	57.3	51.5	44.9	44.4		
	10%	WB	37.6	38.3	38.4	42.1	45.4	50.4	54.0	52.7	50.7	45.2	39.8	38.3		
		MCDB	40.4	41.8	42.0	46.5	50.8	56.9	60.0	58.1	55.4	48.4	42.1	41.3		
(35) Mean Daily Temperature Range	5% DB	MDBR	11.4	11.4	11.6	11.6	12.4	13.4	13.1	13.3	12.3	9.9	10.5	11.5		
		MCDBR	13.2	13.4	14.9	15.8	18.9	20.0	20.4	18.8	15.8	13.1	13.5	13.7		
		MCWBR	11.0	11.1	11.7	11.2	11.8	12.1	12.4	11.6	10.5	10.2	11.3	11.9		
	5% WB	MCDBR	12.8	12.8	13.9	14.8	18.1	18.7	18.3	17.4	14.2	12.3	12.5	14.0		
		MCWBR	10.9	11.0	11.4	10.9	11.6	11.6	11.6	11.0	9.9	9.9	10.6	12.0		
(40) Clear-Sky Solar Irradiance	taub		0.399	0.297	0.323	0.347	0.355	0.350	0.354	0.338	0.336	0.304	0.385	0.400		
	taud		2.547	2.101	2.171	2.197	2.323	2.446	2.462	2.523	2.445	2.232	2.521	2.521		
	Ebn at Noon		73	177	233	258	269	274	269	264	234	175	69	21		
	Edh at Noon		8	19	28	35	34	31	30	25	22	16	7	4		
(44) All-Sky Solar Radiation	RadAvg		31	163	545	1088	1480	1615	1391	1057	621	238	55	9		
	RadStd		3	28	51	98	124	160	114	86	52	23	5	0		

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	+2.59	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (6 neighbors)	+0.74	+1.94	+1.51	N/A	N/A	N/A	-212	N/A	N/A	N/A

Nomenclature: See separate page