

EGILSSTADIR, Iceland

WMO: 040890

Lat: 65.283N

Lon: 14.402W

Elev: 23

StdP: 101.05

Time Zone: 0.00 (E00)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-14.0	-11.8	-16.2	0.9	-13.6	-14.0	1.1	-10.9	17.2	2.5	14.9	2.7	1.7	140	0.800

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.3	19.2	13.6	17.8	12.7	16.1	11.8	14.2	18.4	13.1	16.7	12.0	15.4	5.0	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.8	8.7	16.8	10.9	8.1	15.1	10.0	7.6	14.0	39.8	18.6	36.9	16.9	34.1	15.5	20.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 13.2	11.2	9.8		-17.2	23.5	2.4	2.1	-19.0	25.0	-20.4	26.2	-21.7	27.4	-23.5	28.9	
(5)			DB	-17.3	16.5	2.2	1.6	-18.8	17.6	-20.1	18.5	-21.3	19.4	-22.9	20.5	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	3.8	-0.9	-1.1	-0.5	2.0	5.2	8.7	10.9	10.4	7.9	3.7	0.5	-1.1
	DBStd	5.89	4.36	4.51	4.39	4.01	3.43	3.01	2.65	2.60	3.36	3.76	4.26	4.69
	HDD10.0	2382	339	311	326	241	152	60	19	26	78	198	286	344
	HDD18.3	5292	597	544	584	491	407	290	229	245	312	454	536	603
	CDD10.0	132	0	0	0	1	4	20	49	39	17	2	0	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	4	0	0	0	0	0	1	2	2	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
(14) Wind	WSAvg	4.4	4.7	4.8	4.7	4.6	4.6	4.3	4.0	3.8	4.2	4.2	4.1	4.6
(15) Precipitation	PrecAvg	1146	136	102	92	69	49	52	51	68	111	164	137	115
	PrecMax	1770	257	184	199	172	131	99	134	157	241	282	511	204
	PrecMin	937	34	32	42	27	10	13	7	16	22	24	20	50
	PrecStd	179	60	45	35	36	32	27	29	41	58	76	110	47
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.1	9.2	11.2	13.8	18.0	20.9	22.1	21.1	18.1	14.0	11.9	10.8
		MCWB	7.4	6.3	7.8	8.9	11.7	13.6	15.5	15.3	12.8	10.4	8.4	8.3
	2%	DB	8.1	8.0	9.0	11.1	15.0	17.8	19.8	18.2	16.0	12.2	9.8	8.9
		MCWB	5.8	5.5	6.1	7.6	9.7	12.0	14.4	13.3	12.0	9.0	7.5	6.6
	5%	DB	6.2	7.0	7.2	9.9	12.9	15.9	17.9	16.9	14.2	11.2	8.0	7.1
		MCWB	4.2	4.7	4.7	6.8	8.5	11.0	13.0	12.6	10.8	8.3	6.0	5.0
	10%	DB	5.1	5.8	5.8	8.2	11.1	14.1	16.1	15.2	13.1	9.8	6.2	5.4
		MCWB	3.2	3.7	3.5	5.5	7.5	10.0	12.2	11.6	10.1	7.5	4.4	3.5
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.1	6.7	8.0	9.4	11.9	14.0	15.7	16.0	13.5	10.6	8.6	8.6
		MCDB	9.1	8.7	10.8	13.0	17.5	19.7	20.4	20.6	16.9	13.3	10.8	10.6
	2%	WB	5.3	5.5	6.0	8.0	10.1	12.3	14.6	13.9	12.2	9.5	7.1	6.4
		MCDB	7.3	7.6	8.4	10.8	14.4	16.7	18.9	17.7	15.4	12.0	8.7	8.5
	5%	WB	4.2	4.6	4.8	6.8	8.8	11.1	13.3	12.6	11.2	8.5	5.7	5.0
		MCDB	5.9	6.6	7.0	9.3	12.4	15.1	17.0	16.0	14.0	10.8	7.2	6.9
	10%	WB	3.1	3.5	3.5	5.6	7.5	10.2	12.2	11.5	10.4	7.3	4.3	3.5
		MCDB	4.7	5.4	5.6	8.0	10.5	13.8	15.6	14.5	13.0	9.1	5.6	5.1
(35) Mean Daily Temperature Range	5% DB	MDBR	6.3	6.3	6.4	6.4	6.9	7.4	7.3	7.4	6.8	5.5	5.9	6.4
		MCDBR	7.3	7.4	8.3	8.8	10.5	11.1	11.4	10.5	8.8	7.3	7.5	7.6
		MCWBR	6.1	6.2	6.5	6.2	6.6	6.7	6.9	6.4	5.8	5.6	6.3	6.6
	5% WB	MCDBR	7.1	7.1	7.7	8.2	10.1	10.4	10.2	9.7	7.9	6.9	6.9	7.8
		MCWBR	6.1	6.1	6.3	6.1	6.4	6.4	6.5	6.1	5.5	5.5	5.9	6.7
(40) Clear-Sky Solar Irradiance	taub		0.399	0.297	0.323	0.347	0.355	0.350	0.354	0.338	0.336	0.304	0.385	0.400
	taud		2.547	2.101	2.171	2.197	2.323	2.446	2.462	2.523	2.445	2.232	2.521	2.521
	Ebn at Noon		229	558	734	812	848	864	848	831	738	553	216	67
	Edh at Noon		25	60	88	110	107	97	93	80	69	52	23	13
(44) All-Sky Solar Radiation	RadAvg		0.10	0.52	1.72	3.43	4.67	5.09	4.38	3.33	1.96	0.75	0.17	0.03
	RadStd		0.01	0.09	0.16	0.31	0.39	0.50	0.36	0.27	0.16	0.07	0.02	0.00

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	+1.44	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (6 neighbors)	+0.41	+1.08	+0.84	N/A	N/A	N/A	-118	N/A	N/A	N/A

Nomenclature: See separate page