

DALATANGI, Iceland

WMO: 040970

Lat: 65.268N

Lon: 13.576W

Elev: 36

StdP: 14.68

Time Zone: 0.00 (E00)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	18.7	21.4	4.8	7.0	23.7	8.4	8.5	25.1	47.4	41.8	42.2	40.7	12.0	340	0.866

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.4	58.0	50.2	55.5	49.4	53.7	48.7	52.1	55.5	50.8	53.7	49.9	52.2	10.9	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
50.4	54.2	52.0	49.4	52.3	51.1	48.6	50.6	50.5	21.5	55.7	20.8	53.8	20.3	52.4	64.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
41.5	34.8	30.4	15.5	65.3	3.7	3.8	12.8	68.1	10.7	70.3	8.6	72.5	5.9	75.3
			12.8	55.6	3.1	2.9	10.5	57.6	8.7	59.3	7.0	60.9	4.7	63.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	40.1	35.2	34.5	34.2	36.0	39.5	44.2	47.9	48.7	46.7	41.3	37.6	35.5
	DBStd	7.27	5.72	6.22	6.07	5.46	4.37	3.73	3.07	2.72	4.26	5.09	5.65	6.36
	HDD50	3650	459	434	489	420	324	177	80	56	115	272	374	450
	HDD65	9070	923	854	954	870	789	623	530	504	550	735	823	915
	CDD50	54	1	0	0	0	0	4	14	17	15	2	1	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
	WSAvg	12.9	14.4	14.1	13.5	12.7	12.2	10.9	10.7	10.8	13.0	14.4	13.8	14.7
	PrecAvg	58.7	6.1	4.3	4.4	3.7	3.4	3.0	3.5	4.5	5.8	7.9	6.5	5.6
(15) Precipitation	PrecMax	74.8	11.0	8.5	8.5	7.9	12.4	7.4	8.8	14.0	11.7	16.3	15.3	11.9
	PrecMin	48.6	2.0	1.5	1.1	1.5	0.4	0.5	0.3	1.0	1.3	1.4	1.8	2.4
	PrecStd	7.6	2.3	1.6	1.8	1.5	2.4	2.0	1.9	3.1	2.8	3.3	2.9	2.2
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.2	52.2	51.4	52.1	54.3	59.6	61.4	61.4	60.9	55.3	54.2	52.6
		MCWB	45.6	42.3	42.4	44.0	46.3	49.9	52.4	53.1	50.8	48.1	47.7	44.2
	2%	DB	47.4	47.7	47.1	48.1	50.2	54.4	56.5	56.4	56.7	51.7	49.2	48.4
		MCWB	41.5	42.2	41.2	42.2	44.7	48.5	50.5	50.7	49.2	46.5	43.3	42.8
	5%	DB	45.1	45.1	44.6	45.3	47.7	51.5	54.1	54.1	54.3	49.5	46.7	45.9
		MCWB	40.1	40.5	39.5	40.6	43.6	47.0	49.6	49.8	48.7	45.3	42.2	41.4
	10%	DB	42.5	42.8	42.3	43.0	45.5	49.6	52.2	52.5	52.2	47.8	44.8	43.5
		MCWB	38.6	39.0	37.9	39.6	42.1	46.1	48.8	49.1	48.0	44.8	41.9	40.0
	0.4%	WB	46.2	45.7	44.8	45.9	48.6	51.7	54.2	54.6	53.0	50.0	48.3	46.7
		MCDB	52.0	49.6	49.3	50.1	51.8	55.9	58.9	59.4	56.8	53.3	53.2	51.0
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	43.0	43.1	42.2	43.5	45.9	49.2	51.6	51.9	51.2	47.9	45.3	44.1
		MCDB	46.5	46.4	45.6	46.7	49.0	52.9	54.8	55.0	54.5	49.7	47.2	46.9
	5%	WB	41.1	41.4	40.5	42.0	44.2	47.7	50.3	50.7	50.0	46.8	44.0	42.5
		MCDB	43.8	44.5	43.6	44.4	46.9	50.5	52.8	53.0	52.6	48.5	45.5	44.8
	10%	WB	39.5	39.7	38.7	40.4	42.6	46.4	49.4	49.9	48.9	45.7	42.4	40.8
		MCDB	42.0	42.6	41.5	42.3	44.9	48.7	51.5	51.7	51.2	47.3	44.1	43.1
(35) Mean Daily Temperature Range	5% DB	MDBR	6.7	7.0	7.1	6.4	6.1	6.2	5.9	5.4	5.9	5.7	6.5	6.8
		MCDBR	10.9	10.9	11.4	10.4	10.5	10.8	10.0	8.9	10.1	9.0	11.0	11.0
		MCWBR	9.0	8.9	9.0	7.9	7.1	6.8	6.4	5.8	6.9	7.2	8.9	9.2
	5% WB	MCDBR	9.5	10.0	10.2	9.2	9.6	10.0	8.3	7.6	8.0	7.2	9.0	9.4
		MCWBR	8.5	8.7	8.9	7.5	7.0	6.7	5.9	5.4	6.1	6.5	8.2	8.7
(40) Clear-Sky Solar Irradiance	taub		0.387	0.296	0.329	0.356	0.357	0.353	0.358	0.343	0.347	0.311	0.379	0.390
	taud		2.523	2.208	2.259	2.267	2.374	2.459	2.477	2.529	2.410	2.240	2.468	2.489
	Ebn at Noon		74	184	233	256	269	273	268	262	229	173	66	21
	Edh at Noon		8	17	26	33	32	30	29	25	23	16	7	4
(44) All-Sky Solar Radiation	RadAvg		26	138	453	915	1327	1525	1349	1030	603	222	44	7
	RadStd		3	18	43	84	134	144	95	84	51	19	6	0

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+1.04	+2.68	N/A	N/A	N/A	+0.97	-340	-335	N/A	N/A
(47) Regional (4 neighbors)		+0.86	+2.48	+1.73	N/A	N/A	N/A	-263	-243	N/A	N/A

Nomenclature: See separate page