

GUFUSKALAR, Iceland

WMO: 041040

Lat: 64.9041N

Lon: 23.9346W

Elev: 23

StdP: 14.68

Time Zone: 0.00 (E00)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	20.3	22.6	10.4	9.4	22.2	13.3	10.8	24.4	47.8	35.3	44.1	33.7	14.6	100	0.929

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.7	59.3	53.6	57.7	52.7	56.4	51.8	54.7	57.9	53.6	56.8	52.5	55.5	12.9	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
52.8	59.3	56.6	51.5	56.7	55.4	50.5	54.5	54.5	23.0	58.0	22.4	56.9	21.8	55.7	62.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 42.6	37.5	33.2	DB	16.0	63.1	2.9	2.9	13.9	65.3	12.3	67.0	10.6	68.6	8.5	70.7	(4)
(5)			WB	14.1	56.7	2.6	2.3	12.2	58.4	10.7	59.7	9.3	61.1	7.4	62.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	40.8	33.6	33.3	33.7	37.7	42.6	48.1	51.8	50.6	47.1	40.7	36.7	33.7
	DBStd	8.20	5.29	5.56	5.05	5.04	4.34	3.29	2.98	2.95	4.27	4.96	5.05	5.75
	HDD50	3499	509	468	504	371	232	74	15	27	107	290	398	504
	HDD65	8820	974	888	969	820	696	507	410	446	538	755	848	969
	CDD50	156	0	0	0	1	2	17	70	46	19	1	0	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	16.4	18.3	18.6	18.6	16.8	14.9	12.8	12.0	13.1	15.3	17.8	19.0	19.1
Precipitation	PrecAvg	49.6	4.4	3.9	4.1	2.8	2.8	2.1	2.7	3.5	4.9	4.4	5.1	4.4
	PrecMax	61.3	9.4	7.6	13.4	6.1	5.7	7.0	4.4	7.9	10.6	9.5	13.0	9.0
	PrecMin	35.0	2.1	0.6	0.2	0.3	0.4	0.0	1.5	1.1	0.8	1.8	0.8	0.7
	PrecStd	7.1	2.0	2.0	2.7	1.4	1.8	1.6	0.9	1.6	2.0	1.9	2.9	2.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	48.1	47.7	48.0	53.4	55.2	58.9	62.6	60.3	59.5	53.2	50.7	48.8
		MCWB	45.6	45.5	44.4	47.6	48.7	51.6	55.2	55.0	54.4	49.4	47.9	46.4
	2%	DB	46.0	45.7	45.6	49.5	52.7	56.4	59.9	58.2	56.6	51.3	48.0	46.7
		MCWB	44.2	43.6	43.4	45.6	47.5	50.5	53.9	53.6	52.8	48.2	45.5	44.7
	5%	DB	43.5	43.8	43.1	46.7	50.8	54.8	58.4	56.6	54.6	49.7	46.0	44.8
		MCWB	41.5	41.8	40.9	43.1	46.4	49.8	53.1	52.3	51.3	47.0	43.8	42.7
	10%	DB	41.0	41.6	41.0	44.9	49.1	53.4	57.0	55.4	53.1	48.1	43.7	42.4
		MCWB	38.7	39.6	38.6	41.8	45.4	49.0	52.4	51.4	50.2	45.5	41.4	40.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.4	45.9	45.5	48.2	49.8	53.5	56.6	56.3	55.4	50.2	48.5	46.8
		MCDB	47.8	47.1	47.0	52.9	53.1	56.6	61.0	59.0	58.8	52.4	50.0	48.1
	2%	WB	44.4	43.8	43.5	45.7	48.3	51.6	54.8	54.5	53.2	48.6	45.7	45.0
		MCDB	45.9	45.3	45.3	49.0	51.4	54.9	58.3	57.2	55.9	50.9	47.5	46.5
	5%	WB	41.8	42.0	41.2	43.8	47.2	50.5	53.8	53.2	51.9	47.2	43.7	42.8
		MCDB	43.6	43.7	43.0	46.3	50.1	53.9	57.3	56.0	54.1	49.5	45.7	44.6
	10%	WB	39.0	39.6	38.7	42.3	45.9	49.4	52.8	52.1	50.6	45.7	41.8	40.3
		MCDB	40.8	41.5	40.9	44.6	48.7	52.8	56.2	54.7	52.9	48.0	43.7	42.4
Mean Daily Temperature Range	5% DB	MDBR	6.6	6.6	7.0	7.6	7.9	7.6	7.7	7.4	7.2	6.4	6.7	7.0
		MCDBR	8.7	7.7	8.7	8.8	9.6	10.0	9.8	8.3	7.4	7.7	8.9	8.5
		MCWBR	8.5	7.2	7.9	6.8	6.6	6.2	6.1	5.7	5.5	6.8	8.5	8.2
	5% WB	MCDBR	8.8	7.3	8.3	8.5	8.5	8.6	8.8	7.2	6.8	7.7	8.8	8.7
		MCWBR	8.7	7.3	8.3	7.0	6.3	5.9	5.9	5.3	5.8	7.1	8.7	8.7
Clear-Sky Solar Irradiance	taub	0.381	0.311	0.335	0.367	0.359	0.346	0.353	0.351	0.345	0.303	0.361	0.375	
	taud	2.454	2.209	2.320	2.295	2.404	2.488	2.503	2.510	2.427	2.298	2.597	2.570	
	Ebn at Noon	75	181	234	253	269	276	270	259	232	183	87	33	
	Edh at Noon	8	18	25	32	32	30	29	26	23	16	7	4	
All-Sky Solar Radiation	RadAvg	29	145	462	981	1479	1676	1476	1114	626	244	49	10	
	RadStd	2	24	60	95	167	221	151	88	58	21	4	1	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (7 neighbors)		+0.95	+2.12	+2.30	+0.88	N/A	N/A	-263	-324	+58	N/A	

Nomenclature: See separate page