

DYNJANDIHEIDI, Iceland

WMO: 041150

Lat: 65.700N

Lon: 23.083W

Elev: 621

StdP: 94.08

Time Zone: 0.00 (E00)

Period: 06-17

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-7.0	-5.7	-12.1	1.4	-5.3	-10.5	1.6	-4.7	18.4	2.9	16.0	4.6	4.8	120	0.817

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.7	15.6	12.0	14.6	11.3	13.7	10.9	12.6	14.8	11.9	14.0	11.3	13.2	4.2	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
11.3	9.0	13.8	10.6	8.6	13.2	10.0	8.2	12.6	37.4	14.9	35.6	14.0	34.0	13.3	15.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.3	13.3	11.5	-9.4	18.2	2.0	1.0	-10.8	18.9	-12.0	19.5	-13.2	20.1	-14.6	20.9		
(5)			-10.4	13.6	2.1	1.2	-11.9	14.4	-13.2	15.1	-14.4	15.8	-16.0	16.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	4.8	0.6	0.4	0.7	2.9	6.1	9.4	11.1	10.6	8.3	4.9	1.9	0.5
	DBStd	4.82	2.91	3.17	2.86	2.61	2.56	1.88	1.73	1.73	2.53	2.86	3.14	3.38
	HDD10.0	1999	292	270	289	213	122	32	8	13	61	161	243	294
	HDD18.3	4939	550	503	547	463	379	267	225	241	299	418	493	553
	CDD10.0	102	0	0	0	1	2	15	41	31	12	1	0	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	5.5	5.9	6.1	6.2	5.4	5.1	4.5	4.2	4.4	5.3	5.8	6.3	6.3
Precipitation	PrecAvg	1063	114	101	101	55	70	43	51	66	109	106	113	130
	PrecMax	1501	338	193	309	101	164	149	87	124	227	262	259	229
	PrecMin	726	49	21	12	10	4	0	23	19	36	38	35	22
	PrecStd	209	67	46	65	28	53	43	15	30	53	49	65	63
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.2	8.5	8.9	11.7	13.9	15.9	17.5	16.5	16.0	12.1	10.4	9.2
		MCWB	6.9	6.8	7.0	8.5	10.0	11.3	12.8	13.2	12.6	9.2	8.5	8.1
	2%	DB	7.4	7.3	7.6	9.4	12.0	14.2	16.0	14.9	13.9	11.1	9.0	8.2
		MCWB	6.1	5.5	6.0	6.9	8.7	10.3	12.3	11.7	11.5	8.9	7.3	6.9
	5%	DB	6.1	6.4	6.2	7.8	10.8	13.2	14.9	14.0	12.8	10.1	7.6	7.2
		MCWB	4.7	4.8	4.6	5.3	7.9	9.8	11.6	11.3	10.5	8.2	6.0	5.7
	10%	DB	4.6	5.0	4.8	6.8	9.7	12.4	13.9	13.2	11.9	9.1	6.2	5.6
		MCWB	3.2	3.5	3.0	4.7	7.4	9.4	11.1	10.7	9.8	7.4	4.8	4.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.1	7.3	7.4	9.1	10.4	12.0	13.7	13.7	12.8	10.2	8.9	8.1
		MCDB	7.9	8.4	8.6	11.7	13.0	14.0	16.5	16.0	15.4	11.3	10.1	8.8
	2%	WB	6.1	5.8	6.0	7.4	9.2	11.0	12.6	12.5	11.8	9.3	7.5	6.9
		MCDB	7.2	7.1	7.5	9.2	11.5	13.2	15.0	14.5	13.7	10.7	8.8	7.9
	5%	WB	4.4	4.9	4.5	5.9	8.5	10.3	11.9	11.8	10.9	8.4	6.1	5.6
		MCDB	5.7	6.4	5.9	7.6	10.5	12.6	14.1	13.7	12.4	10.0	7.6	7.0
	10%	WB	3.1	3.5	3.0	4.9	7.7	9.7	11.3	11.1	10.1	7.6	5.0	4.0
		MCDB	4.3	4.8	4.5	6.7	9.5	12.0	13.4	12.8	11.7	9.2	6.3	5.4
Mean Daily Temperature Range	5% DB	MDBR	3.9	3.7	4.1	4.8	4.6	4.8	4.7	4.4	4.1	3.8	3.9	4.3
		MCDBR	5.2	5.0	5.8	6.1	5.8	5.9	5.9	5.0	4.3	4.2	4.9	5.4
		MCWBR	4.7	4.6	5.4	4.7	3.8	3.4	3.4	3.2	3.2	3.7	4.6	5.3
	5% WB	MCDBR	5.4	5.0	5.9	6.1	5.4	5.1	4.9	4.6	4.1	4.4	4.8	5.4
		MCWBR	4.9	4.6	5.5	5.1	3.8	3.3	3.2	3.2	3.6	4.1	4.7	5.4
Clear-Sky Solar Irradiance	taub	0.383	0.264	0.295	0.315	0.320	0.313	0.320	0.316	0.307	0.264	0.357	0.371	
	taud	2.685	2.212	2.330	2.378	2.453	2.521	2.530	2.559	2.512	2.324	2.797	2.785	
	Ebn at Noon	258	620	783	857	887	903	885	854	776	620	295	112	
	Edh at Noon	22	51	74	91	93	90	86	76	63	45	20	12	
All-Sky Solar Radiation	RadAvg	0.07	0.41	1.43	3.03	4.54	5.45	4.62	3.51	1.87	0.68	0.13	0.02	
	RadStd	0.01	0.07	0.19	0.24	0.49	0.68	0.45	0.34	0.17	0.06	0.01	0.00	

Historical Trends

		Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (9 neighbors)		+0.54	+1.14	+1.36	+0.48	N/A	N/A	-146	-180	+32	N/A

Nomenclature: See separate page