

BLONDUOS, Iceland

WMO: 041450

Lat: 65.6580N

Lon: 20.2925W

Elev: 22

StdP: 101.06

Time Zone: 0.00 (E00)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-11.7	-10.0	-15.6	1.0	-11.1	-13.7	1.1	-9.3	20.3	1.9	17.9	2.0	3.7	90	0.832

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.6	16.7	12.4	15.4	11.7	14.3	11.0	13.2	16.0	12.2	14.7	11.5	13.8	5.4	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.6	8.5	14.4	10.7	8.0	13.5	10.0	7.6	12.7	37.2	16.1	34.8	14.8	32.9	13.9	16.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.0	12.9	11.3	-14.4	19.7	1.9	1.6	-15.8	20.8	-16.9	21.8	-18.0	22.7	-19.4	23.9
			-15.3	14.7	2.0	0.9	-16.7	15.4	-17.8	15.9	-18.9	16.4	-20.4	17.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	3.8	-0.5	-0.6	-0.1	2.4	5.5	8.6	10.3	9.5	7.7	3.5	0.5	-1.3
	DBStd	5.38	3.87	4.26	3.47	3.41	3.10	2.52	2.20	2.42	3.17	3.68	3.83	4.39
	HDD10.0	2347	324	297	313	229	143	57	24	39	83	202	285	349
	HDD18.3	5300	583	530	572	479	398	293	250	274	319	459	535	608
	CDD10.0	89	0	0	0	1	3	14	32	23	14	1	0	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	5.2	5.9	5.9	5.6	5.1	4.8	4.6	4.1	4.3	4.9	5.1	5.5	6.3
Precipitation	PrecAvg	552	50	48	49	29	30	36	40	52	58	57	50	52
	PrecMax	676	98	74	112	56	65	94	68	84	92	148	94	96
	PrecMin	454	17	17	16	3	5	6	15	13	26	22	11	9
	PrecStd	64	21	15	26	12	18	21	13	23	21	29	20	24
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.0	9.1	9.2	13.4	15.5	17.1	18.9	17.9	17.2	13.6	11.7	9.5
		MCWB	5.8	5.8	6.3	8.8	9.8	11.8	13.3	13.5	12.6	9.4	8.7	7.0
	2%	DB	7.9	7.7	7.5	10.5	13.2	15.1	16.7	16.1	15.1	12.1	8.6	7.7
		MCWB	5.5	5.1	5.3	6.4	8.6	11.1	12.5	12.6	11.4	8.4	6.0	5.5
	5%	DB	6.4	6.7	6.2	8.9	11.8	13.8	15.3	14.7	13.8	10.7	7.1	6.4
		MCWB	4.4	4.5	4.1	5.5	8.1	10.4	12.0	11.4	10.6	7.7	5.1	4.6
	10%	DB	4.8	5.5	4.8	7.5	10.4	12.6	14.0	13.4	12.5	9.2	5.7	4.8
		MCWB	2.8	3.6	2.9	4.8	7.4	9.7	11.2	10.7	9.8	6.8	4.0	3.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.4	6.7	6.7	7.7	10.4	12.9	14.3	14.2	13.3	10.1	8.9	7.5
		MCDB	8.4	8.1	8.9	10.8	14.2	14.9	17.4	17.0	16.4	13.0	11.9	9.6
	2%	WB	5.3	5.4	5.5	6.4	9.2	11.8	13.4	12.9	11.9	8.8	6.1	5.8
		MCDB	7.4	7.4	7.4	8.8	12.3	14.2	16.3	15.5	14.6	11.5	8.0	7.6
	5%	WB	4.1	4.5	4.3	5.4	8.5	10.9	12.4	11.9	11.0	8.0	4.7	4.6
		MCDB	6.0	6.5	6.0	7.7	11.4	13.4	14.9	14.4	13.5	10.6	6.2	6.3
	10%	WB	2.9	3.6	3.1	4.5	7.6	10.0	11.5	11.0	10.1	7.1	3.6	3.0
		MCDB	4.5	5.5	4.8	6.8	10.3	12.2	13.7	13.1	12.5	9.2	5.0	4.5
Mean Daily Temperature Range	5% DB	MDBR	5.6	5.6	5.8	6.3	6.1	5.9	5.6	5.6	5.8	5.5	5.2	5.8
		MCDBR	6.2	6.2	6.9	8.0	7.9	7.8	8.6	7.5	6.8	7.1	6.1	6.3
		MCWBR	4.9	5.1	5.5	5.3	4.8	4.9	5.3	4.7	4.7	5.3	5.1	5.4
	5% WB	MCDBR	5.7	5.7	6.5	6.9	7.1	6.7	7.3	6.5	6.4	6.8	5.8	6.2
		MCWBR	4.7	4.8	5.4	5.1	4.6	4.6	4.6	4.3	4.6	5.4	5.1	5.4
Clear-Sky Solar Irradiance	taub	0.389	0.289	0.316	0.346	0.351	0.340	0.346	0.335	0.327	0.291	0.372	0.390	
	taud	2.544	2.156	2.261	2.276	2.364	2.468	2.492	2.529	2.476	2.263	2.630	2.600	
	Ebn at Noon	217	570	748	815	852	873	856	832	748	566	236	68	
	Edh at Noon	23	55	80	101	102	95	90	79	66	48	21	11	
All-Sky Solar Radiation	RadAvg	0.08	0.46	1.56	3.22	4.55	5.30	4.42	3.37	1.87	0.70	0.14	0.02	
	RadStd	0.01	0.06	0.18	0.31	0.39	0.57	0.38	0.29	0.13	0.07	0.01	0.00	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (11 neighbors)		+0.52	+0.96	+1.10	N/A	N/A	N/A	-121	-148	N/A	N/A	

Nomenclature: See separate page