

VESTMANNAEYJABAER, Iceland

WMO: 041460

Lat: 63.4359N

Lon: 20.2758W

Elev: 131

StdP: 14.63

Time Zone: 0.00 (E00)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	23.8	25.8	9.1	8.8	27.7	12.6	10.5	28.7	41.0	39.1	37.2	38.7	9.3	0	0.769

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.7	59.3	51.9	57.4	51.8	56.1	51.5	54.5	56.7	53.6	55.5	52.8	54.9	8.4	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
53.3	60.7	55.2	52.3	58.5	54.6	51.5	56.8	54.1	22.9	56.8	22.4	55.7	22.0	55.0	60.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
36.5	31.0	26.8	19.7	64.0	3.4	3.3	17.2	66.4	15.2	68.3	13.3	70.2	10.8	72.7		
			16.8	56.7	3.3	2.3	14.4	58.4	12.5	59.7	10.6	61.0	8.2	62.7		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	43.2	36.7	37.2	37.1	40.9	44.5	49.4	52.8	52.4	48.7	43.0	39.3	36.5	
	DBStd	7.23	5.01	5.12	4.50	3.76	3.40	2.35	2.52	2.11	3.15	4.45	4.96	5.54	
	HDD50	2680	412	359	400	274	171	37	5	4	59	219	322	418	
	HDD65	7946	877	779	865	724	636	467	379	391	490	683	772	883	
	CDD50	210	0	0	0	0	0	20	90	79	20	1	0	0	
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	
Wind	WSAvg	11.2	12.8	13.3	12.4	12.8	11.0	9.1	9.0	8.9	10.8	11.5	11.7	11.4	
Precipitation	PrecAvg	61.9	5.9	5.4	5.5	4.3	3.9	3.9	3.8	5.3	5.5	6.1	5.7	5.8	
	PrecMax	80.1	10.6	11.9	11.9	8.5	9.7	7.6	8.1	10.6	11.5	11.1	13.0	9.3	
	PrecMin	47.2	1.8	1.0	0.4	1.5	0.4	0.5	1.5	0.2	1.7	2.0	1.1	2.2	
	PrecStd	7.9	2.2	2.3	2.3	1.5	2.0	1.9	1.5	2.6	2.2	2.1	2.5	1.9	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	48.0	47.8	47.4	49.1	53.4	58.3	63.1	61.3	56.6	52.6	49.4	48.6	
		MCWB	46.5	46.3	45.5	45.1	46.5	50.0	54.0	52.7	51.6	48.4	47.4	46.9	
	2%	DB	46.8	46.6	46.3	47.6	51.2	55.9	60.1	58.5	55.1	51.3	48.4	47.4	
		MCWB	45.4	45.1	44.6	44.7	45.4	49.6	52.4	51.6	52.2	48.5	46.7	45.9	
	5%	DB	45.5	45.6	45.2	46.8	49.8	54.4	58.2	56.8	54.1	50.3	47.5	46.2	
		MCWB	44.1	43.9	43.3	44.2	45.9	49.4	52.2	51.6	51.1	48.2	45.8	44.6	
	10%	DB	44.0	44.4	43.8	46.0	48.8	53.1	56.7	55.8	53.0	49.2	46.2	44.8	
		MCWB	42.2	42.3	41.5	43.6	45.4	49.0	52.1	51.3	50.1	47.2	44.2	43.1	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.5	46.9	46.3	46.9	48.6	53.1	56.4	55.9	54.3	50.4	48.4	47.7
			MCDB	48.1	47.1	46.7	47.5	50.7	54.9	59.6	58.0	54.9	51.0	48.9	48.2
2%		WB	45.7	45.4	45.0	46.1	47.7	51.8	54.7	54.5	53.2	49.4	47.3	46.5	
		MCDB	46.6	46.1	45.9	47.0	49.5	53.8	57.7	56.4	54.3	50.5	48.1	47.5	
5%		WB	44.3	44.1	43.6	45.3	47.1	50.6	53.8	53.3	52.3	48.5	46.2	44.9	
		MCDB	45.4	45.3	45.0	46.5	48.8	53.1	56.0	55.5	53.5	50.1	47.4	46.0	
10%		WB	42.4	42.7	41.7	44.1	46.4	49.7	53.0	52.5	51.2	47.5	44.8	43.3	
		MCDB	43.9	44.1	43.6	45.8	48.1	52.3	55.3	54.9	52.7	49.3	46.2	44.9	
Mean Daily Temperature Range	5% DB	MDBR	6.6	6.4	6.7	6.4	6.1	5.6	5.7	5.9	5.5	5.6	5.9	6.5	
		MCDBR	7.3	6.1	6.6	6.2	7.4	7.9	8.9	7.8	6.0	5.4	5.0	6.0	
		MCWBR	8.2	7.0	7.1	5.5	4.8	5.0	5.1	4.7	4.8	5.4	5.9	6.7	
	5% WB	MCDBR	7.3	6.0	6.5	5.0	5.4	5.9	6.1	5.4	4.2	4.9	4.8	5.9	
		MCWBR	8.4	7.2	7.7	5.6	4.2	4.4	4.2	4.1	4.5	5.7	5.8	6.8	
Clear-Sky Solar Irradiance	taub	0.411	0.316	0.335	0.366	0.364	0.357	0.360	0.345	0.347	0.309	0.375	0.374		
	taud	2.631	2.218	2.321	2.279	2.365	2.447	2.471	2.518	2.435	2.320	2.747	2.567		
	Ebn at Noon	102	191	240	257	269	274	270	265	236	193	117	57		
	Edh at Noon	10	19	26	33	33	31	30	26	23	17	9	6		
All-Sky Solar Radiation	RadAvg	43	181	499	1030	1505	1590	1459	1165	675	290	70	21		
	RadStd	5	30	70	124	150	194	120	83	68	29	11	1		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (5 neighbors)	+0.92	+1.87	+2.38	+1.15	N/A	N/A	-288	-347	+67	N/A

Nomenclature: See separate page