

HVERAVELLIR, Iceland

WMO: 041560

Lat: 64.8668N

Lon: 19.5622W

Elev: 2103

StdP: 13.61

Time Zone: 0.00 (E00)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	0.9	4.6	-4.8	4.6	1.7	-1.0	5.6	5.3	60.1	29.8	55.8	27.8	9.6	340	1.062

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.4	60.9	50.8	57.4	49.1	54.6	47.9	52.5	58.3	50.6	55.4	49.0	53.2	12.1	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
49.4	56.5	54.4	47.9	53.4	52.3	46.5	50.5	50.7	22.4	58.2	21.3	55.6	20.4	53.3	60.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 49.6	43.4	38.0	DB	-4.9	66.3	2.9	4.9	-6.9	69.8	-8.6	72.6	-10.2	75.4	-12.3	78.9	(4)
(5)			WB	-5.4	56.1	2.9	2.6	-7.4	58.0	-9.1	59.5	-10.8	61.0	-12.9	62.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	32.1	22.8	21.6	22.5	28.2	35.3	43.2	47.0	45.4	39.1	30.8	25.8	23.3
	DBStd	11.45	7.92	8.37	8.03	7.06	5.83	5.25	4.65	4.28	6.09	6.98	7.66	8.58
	HDD50	6559	844	795	854	655	455	210	115	152	328	596	726	829
	HDD65	11994	1309	1215	1319	1105	920	655	557	607	776	1061	1176	1294
	CDD50	40	0	0	0	0	0	5	24	10	1	0	0	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	17.0	19.7	20.2	20.0	17.6	15.5	14.2	13.6	13.8	16.4	16.6	17.5	19.6
Precipitation	PrecAvg	68.4	7.3	7.3	6.3	4.7	3.5	3.3	3.9	5.0	6.1	6.6	6.5	7.9
	PrecMax	85.0	13.6	13.3	11.1	10.0	6.7	7.0	7.0	10.2	9.9	15.7	12.6	12.3
	PrecMin	40.6	3.5	2.9	2.2	1.6	0.4	0.9	1.9	2.7	3.6	3.2	1.8	3.5
	PrecStd	11.2	2.9	2.5	2.5	1.9	1.3	1.5	1.4	1.9	1.6	2.4	2.5	2.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	39.4	38.9	39.3	46.4	53.6	62.3	68.0	65.0	54.8	48.3	42.8	40.8
		MCWB	37.3	37.1	37.2	42.4	44.7	49.8	54.4	53.1	49.5	45.4	40.7	38.7
	2%	DB	36.9	36.7	37.0	40.9	49.6	58.2	62.3	59.1	51.3	45.0	40.2	38.5
		MCWB	35.1	35.1	35.4	38.6	43.3	48.4	52.1	50.6	47.3	42.6	38.4	36.7
	5%	DB	35.2	35.2	35.5	38.5	46.4	55.2	58.2	55.5	49.2	42.9	38.0	36.4
		MCWB	33.7	33.9	34.2	36.4	41.6	47.0	49.9	48.7	46.1	40.8	36.3	34.7
	10%	DB	33.6	33.5	33.7	36.9	43.5	52.4	55.0	52.7	47.3	40.8	36.1	34.6
		MCWB	32.5	32.5	32.5	35.0	40.0	45.6	48.6	47.6	44.7	38.9	34.5	33.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	38.1	37.5	37.6	42.5	46.2	52.5	56.5	55.0	50.7	46.0	41.4	39.1
		MCDB	39.1	38.7	38.7	45.9	51.9	59.8	66.3	60.1	53.7	48.0	42.8	39.9
	2%	WB	35.5	35.4	35.7	38.9	44.1	49.7	53.0	51.9	48.3	42.9	38.7	37.1
		MCDB	36.5	36.4	36.8	40.7	48.5	55.6	59.5	56.4	50.2	44.5	40.0	38.4
	5%	WB	34.0	34.0	34.2	36.8	42.2	48.0	51.2	50.0	46.6	41.0	36.4	34.9
		MCDB	35.0	35.1	35.2	38.3	45.7	53.8	56.6	54.2	48.7	42.7	37.8	36.1
	10%	WB	32.4	32.5	32.6	35.3	40.3	46.3	49.4	48.3	44.9	39.0	34.7	33.3
		MCDB	33.4	33.5	33.6	36.6	43.1	51.2	53.8	51.9	47.2	40.6	36.0	34.6
Mean Daily Temperature Range	5% DB	MDBR	9.5	9.8	9.9	9.4	9.9	12.4	11.4	11.1	8.7	8.0	8.3	8.9
		MCDBR	8.7	9.0	8.7	8.7	14.2	17.6	17.6	16.5	10.3	9.5	8.5	8.4
		MCWBR	7.9	8.4	8.0	7.0	9.1	9.8	9.1	9.3	7.4	8.2	7.5	7.4
	5% WB	MCDBR	8.5	8.6	8.6	8.1	12.8	15.1	14.6	13.1	9.2	9.2	8.3	8.2
		MCWBR	8.0	8.1	8.0	6.8	8.7	9.3	8.3	8.3	7.3	8.3	7.5	7.6
Clear-Sky Solar Irradiance	taub	0.203	0.264	0.297	0.318	0.326	0.328	0.329	0.310	0.301	0.266	0.190	0.199	
	taud	1.863	2.083	2.125	2.159	2.245	2.339	2.387	2.440	2.397	2.198	1.892	1.840	
	Ebn at Noon	92	196	244	268	279	281	277	273	248	195	95	22	
	Edh at Noon	8	19	29	36	36	34	32	27	23	16	7	3	
All-Sky Solar Radiation	RadAvg	41	207	641	1285	1743	1863	1580	1229	698	295	71	14	
	RadStd	2	23	47	97	119	134	109	70	42	18	4	1	

Historical Trends

		Heating			Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+1.10	+1.76	+3.24	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (13 neighbors)		+0.83	+1.58	+2.05	+0.83	N/A	N/A	-241	-290	+47	N/A

Nomenclature: See separate page