

PITUFFIK THULE AB, Greenland

WMO: 042020

Lat: 76.533N

Lon: 68.750W

Elev: 251

StdP: 14.56

Time Zone: -4.00 (NAA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-31.1	-28.5	-33.1	0.9	-29.0	-30.6	1.0	-26.5	43.1	9.5	35.8	2.7	9.0	90	1.038

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.3	53.7	44.9	51.4	44.1	48.9	43.3	46.2	51.1	44.9	49.6	43.6	48.1	11.8	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
43.0	41.2	46.8	41.2	38.5	45.7	39.6	36.1	44.5	18.3	51.3	17.7	50.1	17.1	48.5	51.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 34.5	27.9	22.8	DB	-33.5	59.1	4.4	3.1	-36.7	61.4	-39.3	63.2	-41.7	64.9	-44.9	67.2	(4)
(5)			WB	-33.0	47.9	4.1	2.0	-35.9	49.3	-38.3	50.5	-40.6	51.6	-43.5	53.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	13.8	-10.0	-11.9	-10.3	4.4	24.2	37.3	43.1	40.6	29.3	15.8	5.1	-3.7		
	DBStd	21.76	10.34	11.04	11.18	10.37	7.87	5.42	4.87	4.79	6.69	9.09	9.66	10.96		
	HDD50	13218	1859	1733	1869	1367	799	384	219	294	621	1062	1347	1664		
	HDD65	18684	2324	2153	2334	1817	1264	832	678	758	1071	1527	1797	2129		
	CDD50	8	0	0	0	0	0	1	6	1	0	0	0	0		
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	9.0	9.9	9.7	9.0	8.0	7.4	8.1	8.6	8.0	8.4	10.5	10.7	10.2		
	PrecAvg	4.4	0.2	0.2	0.2	0.2	0.3	0.3	0.7	0.9	0.4	0.5	0.3	0.4		
	PrecMax	6.7	0.9	0.7	0.9	0.7	0.6	1.0	2.5	3.6	1.1	1.2	0.9	1.9		
(15) Precipitation	PrecMin	0.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
	PrecStd	1.7	0.2	0.2	0.2	0.2	0.2	0.3	0.6	0.9	0.3	0.4	0.2	0.4		
	DB	25.6	26.6	31.8	34.0	44.8	55.8	59.0	55.4	45.9	39.0	35.4	32.0	32.0		
	MCWB	22.6	24.5	27.5	30.8	39.3	44.9	46.7	45.6	39.1	34.8	32.8	30.3	30.3		
	2% DB	16.0	17.3	19.6	28.7	40.6	51.4	54.9	51.6	42.4	35.3	28.6	24.7	24.7		
(21) Mean Coincident Wet Bulb Temperatures	MCWB	14.6	15.6	17.9	26.5	36.0	43.3	45.4	43.8	37.6	32.6	26.8	22.5	22.5		
	5% DB	10.5	9.7	10.5	24.7	37.3	48.3	52.2	49.2	39.5	32.0	23.8	17.8	17.8		
	MCWB	9.3	8.5	9.1	22.6	33.6	41.8	44.7	43.6	35.9	29.9	22.4	16.2	16.2		
	10% DB	5.2	3.9	5.3	20.1	34.2	45.1	50.2	47.5	37.7	28.5	19.5	12.5	12.5		
	MCWB	4.2	3.1	4.3	18.3	31.1	39.9	44.1	42.8	34.6	26.7	18.0	11.3	11.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	23.7	24.4	27.1	31.0	39.9	46.2	48.0	47.7	40.1	35.6	32.5	30.1	30.1		
	MCDB	26.1	26.3	31.2	33.5	43.9	53.2	55.7	51.6	44.0	38.3	34.7	31.8	31.8		
	2% WB	14.4	15.2	18.2	26.6	36.1	43.7	46.5	45.8	38.2	32.5	27.0	22.4	22.4		
	MCDB	15.9	16.5	19.8	28.4	39.7	50.1	52.2	49.0	40.8	34.9	28.5	24.3	24.3		
	5% WB	9.3	8.4	9.2	22.4	33.7	41.8	45.5	44.3	36.7	30.0	22.3	16.4	16.4		
(31) Mean Daily Temperature Range	MCDB	10.5	9.3	10.5	24.5	36.8	47.3	50.7	47.7	39.3	32.0	23.8	17.7	17.7		
	10% WB	4.3	3.1	4.5	18.4	31.5	40.2	44.4	42.9	34.9	26.8	18.1	11.5	11.5		
	MCDB	5.2	3.8	5.4	20.3	34.0	44.9	49.3	46.4	37.5	28.2	19.5	12.6	12.6		
	5% DB	13.1	13.1	13.3	14.5	9.9	8.2	8.3	7.6	9.2	11.2	13.0	13.3	13.3		
	MCDBR	18.8	20.0	18.2	14.9	12.3	12.6	11.0	10.1	9.3	10.2	15.9	17.4	17.4		
(36) Clear-Sky Solar Irradiance	MCWBR	17.4	18.7	16.8	13.1	8.8	7.1	5.4	5.5	6.5	8.5	14.9	16.2	16.2		
	5% WB	19.0	20.0	18.0	14.2	11.5	11.8	9.8	8.6	8.5	10.3	15.9	17.6	17.6		
	MCWBR	17.7	18.8	16.8	12.6	8.4	7.3	5.5	5.3	6.2	8.7	15.0	16.5	16.5		
	taub	N/A	0.145	0.220	0.267	0.284	0.303	0.299	0.284	0.247	N/A	N/A	N/A	N/A		
	taud	N/A	1.877	2.095	2.120	2.204	2.303	2.418	2.438	2.291	N/A	N/A	N/A	N/A		
(42) All-Sky Solar Radiation	Ebn at Noon	0	62	211	254	272	271	268	253	206	N/A	0	0	0		
	Edh at Noon	0	3	17	29	32	30	26	22	15	N/A	0	0	0		
	RadAvg	0	19	370	1197	1898	2036	1656	997	429	59	0	0	0		
(45)	RadStd	0	2	17	58	124	209	132	123	39	8	0	0	0		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+1.76	N/A	N/A	N/A	N/A	N/A	-637	-650	N/A	N/A
(47)	Regional (2 neighbors)	+1.76	N/A	N/A	N/A	N/A	N/A	-637	-650	N/A	N/A

Nomenclature: See separate page