

KITSISSUT CAREY OER, Greenland

WMO: 042030

Lat: 76.633N

Lon: 73.000W

Elev: 36

StdP: 14.68

Time Zone: -4.00 (NAA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	-19.6	-16.7	-25.9	1.3	-18.5	-21.7	1.7	-15.4	42.7	3.9	39.6	8.2	10.6	200	1.101

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.9	47.3	43.6	45.4	42.3	43.6	41.1	44.1	46.1	42.7	44.9	41.4	43.3	10.5	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
42.5	40.2	44.4	41.1	38.0	43.0	39.7	36.0	42.2	17.2	46.4	16.5	45.0	15.9	43.4	50.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 37.9	32.6	29.3	-20.4	51.6	3.9	3.6	-23.2	54.1	-25.5	56.2	-27.7	58.3	-30.6	60.9		
(5)			-20.1	44.9	4.2	2.6	-23.1	46.8	-25.6	48.3	-27.9	49.8	-31.0	51.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	18.5	2.0	-0.9	-1.9	10.8	24.8	33.4	39.5	38.1	31.5	23.1	13.1	6.8
	DBStd	16.08	8.48	9.10	10.11	7.72	5.48	3.63	3.82	3.43	3.74	5.78	6.62	8.07
	HDD50	11505	1487	1425	1610	1176	781	497	327	368	554	835	1106	1339
	HDD65	16980	1952	1845	2075	1626	1246	947	792	833	1004	1300	1556	1804
	CDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
	WSAvg	13.0	13.4	14.0	12.8	12.4	11.3	11.6	11.8	12.0	13.2	15.1	14.2	14.0
	PrecAvg	11.1	0.4	0.4	0.4	0.3	0.5	1.0	1.7	2.2	1.4	1.6	0.6	0.6
(15) Precipitation	PrecMax	20.7	1.3	1.0	0.9	0.9	1.0	3.1	4.0	4.4	3.7	6.3	1.5	1.7
	PrecMin	4.6	0.0	0.0	0.0	0.1	0.1	0.2	0.5	0.7	0.4	0.2	0.1	0.1
	PrecStd	3.4	0.3	0.3	0.2	0.2	0.2	0.6	0.8	1.1	0.7	1.1	0.4	0.4
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.1	23.3	29.9	28.9	36.6	45.4	50.9	47.7	45.0	35.6	31.8	40.8
		MCWB	21.6	21.9	26.4	27.9	33.7	40.5	45.1	43.3	43.1	33.3	31.0	40.8
	2%	DB	20.5	19.5	18.8	25.9	33.9	42.7	48.3	45.8	40.3	33.0	27.0	26.3
		MCWB	19.1	17.8	17.6	24.9	31.6	39.1	44.2	42.9	38.3	31.3	25.7	25.1
	5%	DB	17.2	15.7	14.6	23.8	32.0	40.6	46.7	44.2	38.2	31.4	24.8	21.3
		MCWB	16.0	14.9	13.4	22.6	30.3	37.8	43.2	42.0	36.1	29.8	23.5	20.2
	10%	DB	13.5	11.7	11.0	21.5	30.5	38.7	44.8	42.7	36.6	30.1	22.2	17.1
		MCWB	12.6	11.0	10.2	20.4	29.0	36.5	41.8	41.0	34.7	28.8	20.8	16.2
	0.4%	WB	22.0	22.1	25.2	28.4	34.3	41.2	47.6	44.7	44.1	33.9	31.0	28.3
		MCDB	23.0	22.9	28.0	29.1	35.8	44.4	49.2	46.2	44.6	34.9	32.2	29.2
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	19.2	18.1	16.9	25.1	31.8	39.5	45.0	43.4	38.9	31.6	26.1	23.0
		MCDB	20.5	19.2	17.9	25.6	33.2	42.1	47.1	44.9	40.5	32.6	26.9	23.9
	5%	WB	16.1	14.8	13.2	22.7	30.4	38.2	43.3	42.4	36.5	30.3	23.4	19.1
		MCDB	17.2	15.7	14.2	23.7	31.6	40.4	46.1	43.8	37.7	31.1	24.6	19.9
	10%	WB	12.6	10.9	10.0	20.4	29.2	36.7	42.0	41.3	35.0	28.9	21.0	15.7
		MCDB	13.3	11.6	10.8	21.4	30.3	38.5	44.5	42.5	36.3	30.0	22.2	16.4
	5% DB	MDBR	6.6	6.3	6.4	6.3	4.9	5.1	5.9	4.5	3.6	4.4	6.0	6.8
		MCDBR	9.5	9.7	8.5	8.2	6.5	7.9	8.2	6.5	4.6	4.3	8.0	14.5
		MCWBR	9.1	9.4	7.2	7.8	5.2	5.3	4.9	4.8	3.9	4.1	7.9	9.4
		MCWBR	9.3	9.7	7.6	8.1	6.2	7.5	7.5	5.8	4.5	4.3	8.0	9.3
(35) Mean Daily Temperature Range	5% WB	MCWBR	9.0	9.5	7.2	7.9	5.5	5.5	5.0	4.8	4.0	4.1	7.9	9.0
(40) Clear-Sky Solar Irradiance	taub		N/A	0.147	0.214	0.270	0.301	0.306	0.310	0.303	0.260	0.345	N/A	N/A
	taud		N/A	1.876	2.129	2.148	2.307	2.510	2.575	2.566	2.436	2.915	N/A	N/A
	Ebn at Noon		0	58	217	253	266	272	266	249	207	66	0	0
	Edh at Noon		0	3	16	28	29	25	23	19	13	4	0	0
(44) All-Sky Solar Radiation	RadAvg		0	19	356	1131	1677	1843	1548	955	404	51	0	0
	RadStd		0	2	27	81	172	200	157	136	48	8	0	0

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (2 neighbors)	+1.76	N/A	N/A	N/A	N/A	N/A	-637	-650	N/A	N/A

Nomenclature: See separate page