

KITSISSUT CAREY OER, Greenland

WMO: 042030

Lat: 76.633N

Lon: 73.000W

Elev: 11

StdP: 101.19

Time Zone: -4.00 (NAA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	-28.6	-27.1	-32.2	0.2	-28.1	-29.8	0.2	-26.3	19.1	-15.6	17.7	-13.2	4.8	200	1.101

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	3.3	8.5	6.4	7.4	5.7	6.4	5.1	6.7	7.8	5.9	7.2	5.2	6.3	4.7	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5.9	5.7	6.9	5.0	5.4	6.1	4.3	5.1	5.7	22.1	8.0	20.5	7.2	19.1	6.4	10.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.9	14.6	13.1	DB	-29.1	10.9	2.2	2.0	-30.7	12.3	-32.0	13.5	-33.2	14.6	-34.8	16.0	(4)
(5)			WB	-28.9	7.2	2.3	1.4	-30.6	8.2	-32.0	9.1	-33.3	9.9	-35.0	10.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-7.5	-16.6	-18.3	-18.9	-11.8	-4.0	0.8	4.1	3.4	-0.3	-5.0	-10.5	-14.0
	DBStd	8.94	4.71	5.06	5.62	4.29	3.05	2.02	2.12	1.90	2.08	3.21	3.68	4.48
	HDD10.0	6392	826	792	894	653	434	276	182	204	308	464	614	744
	HDD18.3	9433	1084	1025	1153	903	692	526	440	463	558	722	864	1002
	CDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	5.8	6.0	6.2	5.7	5.5	5.1	5.2	5.3	5.4	5.9	6.8	6.3	6.3
Precipitation	PrecAvg	281	10	9	9	8	12	26	44	57	36	40	15	14
	PrecMax	525	33	26	24	24	26	79	101	112	95	159	38	43
	PrecMin	117	0	0	1	2	2	6	13	18	11	4	2	2
	PrecStd	86	7	7	5	6	6	14	21	28	17	28	9	10
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-4.4	-4.9	-1.2	-1.7	2.6	7.4	10.5	8.7	7.2	2.0	-0.1	4.9
		MCWB	-5.8	-5.6	-3.1	-2.3	1.0	4.7	7.3	6.3	6.2	0.7	-0.6	4.9
	2%	DB	-6.4	-6.9	-7.4	-3.4	1.0	6.0	9.1	7.7	4.6	0.5	-2.8	-3.2
		MCWB	-7.1	-7.9	-8.0	-4.0	-0.2	4.0	6.8	6.0	3.5	-0.4	-3.5	-3.8
	5%	DB	-8.2	-9.1	-9.7	-4.6	0.0	4.8	8.1	6.8	3.4	-0.4	-4.0	-6.0
		MCWB	-8.9	-9.5	-10.3	-5.2	-0.9	3.2	6.2	5.6	2.3	-1.2	-4.7	-6.6
	10%	DB	-10.3	-11.3	-11.7	-5.8	-0.8	3.7	7.1	5.9	2.6	-1.0	-5.4	-8.3
		MCWB	-10.8	-11.7	-12.1	-6.4	-1.7	2.5	5.4	5.0	1.5	-1.8	-6.2	-8.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-5.6	-5.5	-3.8	-2.0	1.3	5.1	8.6	7.0	6.7	1.0	-0.5	-2.0
		MCDB	-5.0	-5.0	-2.2	-1.6	2.1	6.9	9.5	7.9	7.0	1.6	0.1	-1.6
	2%	WB	-7.1	-7.7	-8.4	-3.9	-0.1	4.2	7.2	6.3	3.8	-0.2	-3.3	-5.0
		MCDB	-6.4	-7.1	-7.8	-3.5	0.7	5.6	8.4	7.1	4.7	0.3	-2.8	-4.5
	5%	WB	-8.8	-9.5	-10.4	-5.2	-0.9	3.4	6.3	5.8	2.5	-0.9	-4.8	-7.2
		MCDB	-8.2	-9.1	-9.9	-4.6	-0.2	4.7	7.8	6.6	3.2	-0.5	-4.1	-6.7
	10%	WB	-10.8	-11.7	-12.2	-6.5	-1.6	2.6	5.5	5.2	1.7	-1.7	-6.1	-9.1
		MCDB	-10.4	-11.3	-11.8	-5.9	-0.9	3.6	7.0	5.8	2.4	-1.1	-5.5	-8.6
Mean Daily Temperature Range	5% DB	MDBR	3.7	3.5	3.5	3.5	2.7	2.8	3.3	2.5	2.0	2.5	3.3	3.8
		MCDBR	5.3	5.4	4.7	4.6	3.6	4.4	4.6	3.6	2.6	2.4	4.5	8.1
		MCWBR	5.1	5.2	4.0	4.3	2.9	3.0	2.7	2.7	2.1	2.3	4.4	5.2
	5% WB	MCDBR	5.2	5.4	4.2	4.5	3.4	4.2	4.1	3.2	2.5	2.4	4.5	5.2
		MCWBR	5.0	5.3	4.0	4.4	3.0	3.1	2.8	2.7	2.2	2.3	4.4	5.0
Clear-Sky Solar Irradiance	taub	N/A	0.147	0.214	0.270	0.301	0.306	0.310	0.303	0.260	0.345	N/A	N/A	
	taud	N/A	1.876	2.129	2.148	2.307	2.510	2.575	2.566	2.436	2.915	N/A	N/A	
	Ebn at Noon	0	183	683	798	840	859	840	785	652	207	0	0	
	Edh at Noon	0	9	52	88	92	79	72	61	42	13	0	0	
All-Sky Solar Radiation	RadAvg	0.00	0.06	1.12	3.56	5.29	5.81	4.88	3.01	1.27	0.16	0.00	0.00	
	RadStd	0.00	0.01	0.09	0.26	0.54	0.63	0.49	0.43	0.15	0.02	0.00	0.00	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (2 neighbors)	+0.98	N/A	N/A	N/A	N/A	N/A	-354	-361	N/A	N/A

Nomenclature: See separate page