

QAANAAQ AP, Greenland

WMO: 042050

Lat: 77.486N

Lon: 69.376W

Elev: 52

StdP: 14.67

Time Zone: -4.00 (NAA)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-25.0	-22.4	-36.3	0.7	-23.0	-33.3	0.8	-20.4	50.1	-0.5	28.9	14.8	2.2	160	0.977

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.1	55.0	45.4	52.2	44.5	50.2	43.8	46.9	51.9	45.6	50.5	44.4	49.0	10.9	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
43.7	42.1	47.6	42.3	39.9	46.9	40.7	37.5	46.1	18.6	52.3	18.0	50.7	17.4	49.3	53.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
28.7	22.6	18.3	-27.6	60.1	4.6	3.6	-31.0	62.7	-33.7	64.8	-36.3	66.8	-39.6	69.5
			-28.6	48.1	4.5	2.2	-31.8	49.7	-34.4	51.0	-37.0	52.2	-40.2	53.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	16.5	-6.2	-8.5	-7.2	6.7	25.1	37.7	44.1	42.1	31.9	19.9	9.8	1.0	(6)
(7)		DBStd	20.37	9.52	9.84	9.52	9.01	7.35	4.80	4.83	4.85	5.25	7.21	7.86	9.84	(7)
(8)		HDD50	12233	1743	1637	1772	1300	773	370	192	245	543	933	1207	1518	(8)
(9)		HDD65	17698	2208	2057	2237	1750	1238	819	649	709	993	1398	1657	1983	(9)
(10)		CDD50	11	0	0	0	0	0	1	8	2	0	0	0	0	(10)
(11)		CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)
(12)		CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)
(13)		CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	5.2	3.7	3.8	3.4	3.5	4.4	5.4	6.0	6.3	6.9	7.4	6.7	4.5	(14)
(15)	Precipitation	PrecAvg	8.9	0.4	0.4	0.4	0.4	0.4	0.7	1.3	1.7	0.9	1.2	0.6	0.6	(15)
(16)		PrecMax	14.3	1.5	1.0	1.4	1.1	1.6	2.4	3.1	3.5	2.3	3.7	1.9	1.7	(16)
(17)		PrecMin	4.5	0.0	0.0	0.0	0.0	0.0	0.1	0.2	0.3	0.3	0.1	0.0	0.1	(17)
(18)		PrecStd	2.6	0.3	0.3	0.3	0.3	0.3	0.4	0.7	0.9	0.5	0.7	0.4	0.4	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.8	26.6	26.4	33.5	44.8	55.9	59.9	55.8	46.8	42.7	37.5	33.5	(19)
(20)			MCWB	20.5	22.0	22.5	28.5	37.4	44.3	45.9	44.3	39.1	36.5	31.8	29.6	(20)
(21)		2%	DB	16.6	16.3	17.2	28.0	40.0	51.1	56.0	53.0	43.0	34.9	29.3	25.7	(21)
(22)			MCWB	14.3	14.7	15.3	24.8	34.4	42.0	46.0	44.2	36.4	30.2	25.0	22.6	(22)
(23)		5%	DB	11.9	10.6	10.6	23.6	37.2	47.4	53.7	50.8	40.9	31.9	23.8	19.4	(23)
(24)			MCWB	10.0	9.2	8.7	20.8	32.7	40.4	45.6	43.7	35.1	27.9	20.6	17.2	(24)
(25)		10%	DB	6.8	5.3	6.0	20.3	35.0	44.4	51.6	48.6	39.0	29.1	20.0	14.8	(25)
(26)			MCWB	5.2	4.1	4.6	17.7	31.3	38.9	44.8	42.8	34.0	25.7	17.3	12.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.6	21.7	22.5	29.0	38.3	45.7	49.5	47.3	39.8	36.6	31.5	29.5	(27)
(28)			MCD B	24.3	25.8	25.3	32.5	43.2	53.3	52.9	51.0	43.9	42.4	35.0	33.4	(28)
(29)		2%	WB	14.3	14.9	15.3	24.8	35.1	42.7	47.8	45.8	37.7	30.4	25.0	22.3	(29)
(30)			MCD B	16.6	16.5	17.0	27.4	38.6	49.1	53.0	49.5	41.3	33.6	29.2	25.7	(30)
(31)		5%	WB	9.8	9.2	8.8	21.0	33.3	40.9	46.6	44.9	36.0	28.2	20.7	17.2	(31)
(32)			MCD B	11.8	10.6	10.6	23.4	36.5	46.4	52.0	48.7	39.7	31.4	23.8	19.4	(32)
(33)		10%	WB	5.2	4.2	4.5	17.7	31.4	39.3	45.4	43.7	34.4	25.8	17.4	12.9	(33)
(34)			MCD B	6.8	5.4	6.0	20.2	34.5	43.7	50.6	47.7	38.2	28.8	19.8	14.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	9.8	10.7	12.7	14.9	12.0	9.1	9.1	7.6	7.1	6.6	7.7	9.0	(35)
(36)			MCDBR	15.4	17.6	17.0	17.8	14.4	14.0	13.0	11.0	9.2	8.5	12.4	13.4	(36)
(37)			MCWBR	13.3	15.8	15.1	14.6	10.2	8.0	6.5	6.0	6.2	6.6	10.6	11.5	(37)
(38)		5% WB	MCD BR	15.3	17.3	16.7	17.0	12.7	13.2	11.3	9.3	7.8	8.2	12.2	13.7	(38)
(39)			MCWBR	13.3	15.5	15.0	14.1	9.3	8.0	6.3	5.7	5.7	6.6	10.6	12.0	(39)
(40)	Clear-Sky Solar Irradiance	taub		N/A	0.148	0.208	0.268	0.291	0.320	0.308	0.290	0.244	0.160	N/A	N/A	(40)
(41)		taud		N/A	1.883	2.144	2.144	2.230	2.317	2.425	2.457	2.288	1.922	N/A	N/A	(41)
(42)		Ebn at Noon		0	35	213	251	267	263	262	248	200	21	0	0	(42)
(43)		Edh at Noon		0	2	15	27	31	30	26	21	14	1	0	0	(43)
(44)	All-Sky Solar Radiation	RadAvg		0	13	337	1218	2010	2237	1905	1161	468	54	0	0	(44)
(45)		RadStd		0	1	15	51	87	141	109	100	34	4	0	0	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (2 neighbors)	+1.76	N/A	N/A	N/A	N/A	N/A	-637	-650	N/A	N/A

Nomenclature: See separate page