

HALL LAND, Greenland

WMO: 042070

Lat: 81.683N

Lon: 59.933W

Elev: 105

StdP: 100.07

Time Zone: -3.00 (GRL)

Period: 83-00

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-45.7	-44.5	-47.3	0.0	-45.3	-46.2	0.0	-44.4	17.9	-21.3	14.9	-24.9	1.7	350	1.203

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	3.8	12.0	7.8	10.4	6.7	9.0	5.9	8.1	10.9	7.0	10.3	5.9	8.8	4.8	40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6.1	5.9	10.1	4.2	5.2	7.9	3.2	4.8	6.5	25.4	10.8	22.9	10.5	20.6	8.9	15.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.4	11.4	10.2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			DB													
			WB	-47.5	9.5	2.5	1.4	-49.3	10.6	-50.7	11.4	-52.1	12.2	-53.9	13.3	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-18.9	-35.3	-36.1	-34.4	-25.2	-11.6	0.7	5.2	2.2	-9.6	-22.6	-28.0	-33.1		
	DBStd	15.99	5.25	5.40	6.30	7.24	5.26	3.57	2.83	3.63	6.60	5.84	7.72	5.58		
	HDD10.0	10546	1403	1292	1376	1056	670	280	152	243	587	1012	1139	1336		
	HDD18.3	13584	1662	1525	1634	1306	928	530	408	501	837	1271	1389	1594		
	CDD10.0	3	0	0	0	0	0	0	2	1	0	0	0	0		
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0		
(14) Wind	WSAvg	4.0	3.4	3.2	3.0	3.6	4.8	5.5	5.6	4.8	3.7	3.3	3.3	3.4		
(15) Precipitation	PrecAvg	137	7	7	8	9	8	10	22	22	16	11	9	9		
	PrecMax	203	15	18	18	30	22	24	55	54	37	21	21	30		
	PrecMin	82	2	1	2	1	2	1	6	5	4	5	1	4		
	PrecStd	29	3	4	4	8	5	5	12	13	7	4	5	6		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-18.8	-17.9	-9.8	7.5	0.5	11.8	13.9	13.6	8.3	-6.4	6.9	-13.5		
		MCWB	-18.9	-18.1	-10.6	6.3	-0.9	7.3	8.6	9.0	7.6	-6.6	5.9	-13.8		
	2%	DB	-22.0	-21.4	-16.7	-3.7	-1.7	9.9	12.3	11.0	4.5	-10.1	-2.9	-18.6		
		MCWB	-22.2	-21.6	-17.1	-4.6	-2.4	6.0	7.8	7.2	3.0	-10.5	-3.9	-18.9		
	5%	DB	-24.9	-25.8	-21.6	-12.0	-3.1	8.1	11.1	9.3	1.7	-12.2	-9.7	-21.8		
		MCWB	-25.0	-25.9	-21.8	-12.4	-3.9	5.1	7.0	6.6	0.6	-12.5	-10.2	-22.0		
	10%	DB	-27.5	-28.4	-25.2	-16.0	-4.6	5.6	9.8	7.1	-1.1	-14.0	-17.1	-24.8		
		MCWB	-27.6	-28.5	-25.5	-16.2	-5.3	3.6	6.3	4.6	-1.9	-14.2	-17.5	-25.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-19.0	-18.2	-10.5	6.4	-0.8	7.6	9.5	10.4	7.8	-6.7	4.6	-14.0		
		MCDB	-18.8	-18.1	-9.6	7.6	0.4	11.5	12.7	12.6	8.0	-6.6	5.7	-13.6		
	2%	WB	-22.2	-21.6	-17.0	-4.6	-2.4	6.2	8.2	8.2	3.0	-10.5	-4.3	-18.9		
		MCDB	-22.0	-21.5	-16.6	-3.7	-1.8	9.7	11.7	10.5	4.4	-10.2	-3.4	-18.6		
	5%	WB	-25.0	-25.9	-21.8	-12.5	-3.9	5.0	7.2	6.3	0.4	-12.5	-10.4	-22.1		
		MCDB	-24.9	-25.8	-21.7	-12.1	-3.2	8.0	10.7	9.6	1.7	-12.3	-10.0	-21.8		
	10%	WB	-27.7	-28.5	-25.4	-16.2	-5.3	3.7	6.3	4.7	-1.9	-14.2	-17.5	-25.0		
		MCDB	-27.6	-28.5	-25.2	-16.0	-4.7	5.6	9.4	7.0	-1.3	-14.0	-17.2	-24.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	5.6	5.5	6.0	6.5	5.0	3.5	3.8	4.0	5.6	6.5	6.4	5.8		
		MCDBR	7.9	8.1	8.6	10.2	6.0	6.3	5.5	6.0	5.4	7.6	13.6	9.4		
		MCWBR	7.9	8.1	8.4	10.0	5.4	4.5	3.3	3.7	4.1	7.5	11.1	9.2		
	5% WB	MCDBR	7.9	8.4	8.5	10.2	6.0	5.7	5.3	5.9	4.6	7.5	11.4	9.3		
		MCWBR	7.9	8.4	8.3	10.0	5.5	4.1	3.5	3.8	4.0	7.5	11.1	9.1		
(40) Clear-Sky Solar Irradiance	taub	N/A	N/A	0.185	0.259	0.277	0.309	0.308	0.301	0.216	N/A	N/A	N/A	N/A		
	taud	N/A	N/A	1.995	2.099	2.170	2.226	2.360	2.310	2.081	N/A	N/A	N/A	N/A		
	Ebn at Noon	0	0	527	737	817	804	789	696	484	0	0	0	0		
	Edh at Noon	0	0	35	78	93	95	79	65	34	0	0	0	0		
(44) All-Sky Solar Radiation	RadAvg	0.00	0.00	0.62	3.51	6.61	7.45	6.24	3.62	1.08	0.00	0.00	0.00	0.00		
	RadStd	0.00	0.00	0.06	0.16	0.32	0.29	0.41	0.32	0.06	0.00	0.00	0.00	0.00		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page