

NUUSSUAQ, Greenland

WMO: 042140

Lat: 70.683N

Lon: 54.617W

Elev: 89

StdP: 14.65

Time Zone: -3.00 (GRL)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	-19.9	-14.8	-24.8	1.4	-18.7	-20.4	1.8	-13.5	38.6	18.6	33.8	18.4	7.5	340	0.962

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.4	53.5	46.0	51.4	45.2	49.3	44.3	47.2	51.3	46.0	49.5	45.0	48.1	7.6	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
44.9	44.2	47.2	43.9	42.5	46.2	43.0	41.0	45.4	18.8	51.7	18.2	49.9	17.7	48.4	54.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 36.4	30.9	26.7	DB	-17.2	59.2	4.7	2.1	-20.6	60.7	-23.4	61.9	-26.1	63.1	-29.5	64.6	(4)
(5)			WB	-17.0	50.0	9.4	2.5	-23.7	51.8	-29.2	53.3	-34.5	54.7	-41.3	56.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	25.6	11.9	6.6	5.8	17.4	29.7	38.4	43.4	43.0	37.5	29.8	23.7	18.7	
	DBStd	15.34	10.86	12.89	13.36	10.16	5.94	5.07	4.64	3.44	3.83	5.58	6.72	8.29	
	HDD50	8909	1180	1216	1370	978	631	348	211	217	375	626	788	969	
	HDD65	14377	1645	1636	1835	1428	1096	797	671	681	825	1091	1238	1434	
	CDD50	6	0	0	0	0	0	1	4	1	0	0	0	0	
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	
Wind	WSAvg	10.8	11.7	10.5	10.6	10.4	9.4	9.0	8.7	8.5	9.6	12.4	14.0	14.3	
Precipitation	PrecAvg	17.0	1.5	1.0	0.9	0.9	0.9	0.9	1.1	1.8	1.7	1.9	2.1	2.1	
	PrecMax	25.2	5.6	2.2	3.0	2.7	2.7	2.7	2.8	3.8	3.9	4.4	5.4	4.3	
	PrecMin	8.7	0.1	0.1	0.1	0.0	0.1	0.1	0.1	0.6	0.4	0.5	0.2	0.3	
	PrecStd	4.2	1.1	0.7	0.7	0.6	0.6	0.6	0.6	0.9	0.8	1.0	1.1	1.0	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	37.6	37.8	37.3	42.9	48.3	55.6	57.1	54.9	50.2	47.0	42.6	43.8	
		MCWB	32.1	32.8	34.0	35.8	42.1	46.0	47.5	46.4	41.8	38.8	36.5	35.9	
	2%	DB	33.7	33.0	33.0	38.4	43.2	51.1	54.1	52.4	46.1	42.5	39.0	36.5	
		MCWB	29.7	29.0	30.5	33.5	39.2	44.4	46.4	45.8	40.5	36.9	33.8	32.3	
	5%	DB	30.6	29.5	29.1	34.8	39.8	48.2	52.0	50.4	43.9	39.4	36.3	33.2	
		MCWB	26.9	26.2	26.5	31.5	36.3	43.1	45.8	44.8	39.6	35.2	32.2	29.9	
	10%	DB	26.5	24.8	24.0	31.4	37.3	45.8	49.9	48.4	42.2	37.2	33.0	29.5	
		MCWB	23.2	22.2	22.1	29.3	34.6	42.0	44.9	44.1	38.6	33.8	29.8	26.7	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	32.8	33.3	35.0	36.7	43.7	47.3	49.3	48.7	43.9	40.1	38.5	36.7
			MCDB	35.5	37.5	37.2	40.8	46.9	53.4	53.8	51.9	47.2	45.0	42.0	41.7
2%		WB	30.1	29.3	31.1	34.0	39.7	45.0	47.6	46.8	41.9	38.0	34.5	32.9	
		MCDB	33.8	32.5	32.8	37.8	42.4	49.6	51.9	50.2	44.6	41.2	37.9	36.0	
5%		WB	26.7	26.2	26.6	31.8	36.9	43.6	46.5	45.7	40.5	35.9	32.2	30.1	
		MCDB	30.5	29.7	29.0	34.6	39.2	47.4	50.3	48.8	43.0	38.9	35.9	33.0	
10%		WB	23.4	22.2	22.1	29.3	34.9	42.2	45.5	44.7	39.3	33.8	30.0	26.7	
		MCDB	26.5	24.8	24.1	31.5	36.8	45.4	48.8	47.5	41.4	36.7	33.1	29.3	
Mean Daily Temperature Range		5% DB	MDBR	7.3	8.2	8.6	8.2	6.6	7.4	7.4	5.9	4.7	4.6	5.4	6.2
			MCDBR	11.2	13.3	12.1	11.5	10.9	12.3	10.7	9.2	7.4	6.7	9.0	9.7
	MCWBR		8.7	10.8	10.1	8.5	7.2	6.6	5.4	4.9	4.6	4.9	6.9	7.6	
	5% WB	MCDBR	12.5	13.6	11.8	10.5	10.4	11.5	9.5	7.8	6.3	6.5	8.9	9.4	
		MCWBR	10.4	11.4	10.5	8.0	7.4	6.7	5.4	5.0	4.5	5.4	7.1	7.9	
Clear-Sky Solar Irradiance	taub	N/A	0.191	0.246	0.286	0.319	0.327	0.329	0.321	0.279	0.211	N/A	N/A		
	taud	N/A	2.037	2.197	2.165	2.288	2.476	2.522	2.539	2.526	2.127	N/A	N/A		
	Ebn at Noon	0	171	243	266	272	275	270	258	238	155	0	0		
	Edh at Noon	0	11	22	32	33	28	26	23	16	10	0	0		
All-Sky Solar Radiation	RadAvg	0	95	554	1283	1786	1930	1767	1172	601	173	0	0		
	RadStd	0	12	42	102	119	130	162	101	48	14	0	0		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page