

AASIAAT EGEDESMINDE, GreenlandWMO: **042200**Lat: **68.7081N**Lon: **52.8517W**Elev: **41**StdP: **100.83**Time Zone: **-3.00 (GRL)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-27.9	-25.7	-31.3	0.2	-27.7	-28.8	0.3	-25.3	16.1	-8.2	13.6	-9.1	2.5	190	0.910

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.4	12.1	8.3	11.0	7.9	10.1	7.5	9.1	10.8	8.4	10.3	7.8	9.7	3.1	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8.2	6.8	9.2	7.3	6.4	8.7	6.6	6.1	8.2	27.3	10.9	25.9	10.4	24.5	9.8	13.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.0	11.0	9.4	DB	-27.3	15.6	4.4	2.1	-30.4	17.1	-33.0	18.3	-35.4	19.5	-38.6	21.0	(4)
(5)			WB	-27.5	10.4	4.3	1.2	-30.6	11.3	-33.1	12.1	-35.5	12.8	-38.6	13.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	-3.2	-10.9	-13.7	-13.9	-7.2	-0.5	4.4	7.0	6.5	3.2	-1.4	-4.8	-7.4	(6)
(7)		DBStd	8.39	5.69	6.76	6.78	5.11	3.03	2.71	2.51	1.86	2.05	2.92	3.51	4.10	(7)
(8)		HDD10.0	4807	648	664	741	516	324	167	96	108	203	354	444	540	(8)
(9)		HDD18.3	7843	907	898	999	766	583	417	350	366	453	613	694	798	(9)
(10)		CDD10.0	6	0	0	0	0	0	1	4	1	0	0	0	0	(10)
(11)		CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)
(12)		CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)
(13)		CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	4.1	5.1	4.5	4.2	3.9	3.5	3.3	3.1	3.0	3.8	4.5	5.0	5.4	(14)
(15)	Precipitation	PrecAvg	294	23	16	17	18	16	21	22	38	33	31	33	28	(15)
(16)		PrecMax	452	64	67	100	49	52	79	58	133	130	92	97	71	(16)
(17)		PrecMin	144	2	2	0	0	1	1	0	0	3	4	7	5	(17)
(18)		PrecStd	70	15	14	15	13	13	17	14	25	27	21	20	15	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	2.2	2.8	1.5	4.4	8.6	12.7	14.5	12.6	9.4	7.4	4.6	4.1	(19)
(20)			MCWB	0.1	-0.6	0.4	1.6	4.7	7.6	9.2	8.6	6.0	3.7	2.0	0.6	(20)
(21)		2%	DB	0.0	-0.3	-0.8	2.3	6.2	10.7	12.7	11.0	7.6	4.6	2.9	1.7	(21)
(22)			MCWB	-1.5	-1.9	-2.0	0.4	3.8	7.2	8.6	7.9	5.2	2.8	0.7	-0.2	(22)
(23)		5%	DB	-1.6	-2.3	-2.3	0.7	4.7	9.6	11.7	10.1	6.6	3.2	1.5	-0.2	(23)
(24)			MCWB	-3.0	-3.6	-3.3	-0.5	2.7	6.6	8.2	7.6	4.8	1.8	0.0	-1.6	(24)
(25)		10%	DB	-3.3	-4.6	-4.4	-0.5	3.3	8.4	10.7	9.2	5.9	2.2	0.1	-1.9	(25)
(26)			MCWB	-4.5	-5.8	-5.4	-1.5	1.8	6.0	8.0	7.3	4.4	1.0	-0.9	-3.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	0.7	0.2	0.6	2.1	5.3	8.6	10.4	9.7	6.8	4.5	2.7	1.5	(27)
(28)			MCDB	1.7	1.9	1.4	3.8	7.9	10.9	12.2	10.7	8.1	5.9	4.4	3.4	(28)
(29)		2%	WB	-1.5	-1.8	-1.8	0.7	4.0	7.6	9.5	8.7	5.9	3.0	1.2	-0.1	(29)
(30)			MCDB	-0.3	-0.3	-0.9	1.8	5.9	10.0	11.4	9.9	6.9	4.3	2.3	1.6	(30)
(31)		5%	WB	-2.9	-3.6	-3.4	-0.3	2.9	6.9	8.8	8.1	5.2	2.1	0.1	-1.5	(31)
(32)			MCDB	-1.8	-2.3	-2.5	0.7	4.2	9.2	10.8	9.5	6.2	3.0	1.2	-0.3	(32)
(33)		10%	WB	-4.5	-5.8	-5.4	-1.5	2.0	6.1	8.3	7.5	4.6	1.1	-0.9	-3.0	(33)
(34)			MCDB	-3.3	-4.7	-4.4	-0.5	3.1	8.3	10.3	8.9	5.6	2.1	0.3	-1.9	(34)
(35)	Mean Daily Temperature Range		MDBR	4.5	5.0	4.9	4.8	3.8	4.3	4.4	3.5	2.8	2.8	3.4	3.8	(35)
(36)		5% DB	MCDBR	5.7	7.1	6.3	6.2	5.3	6.1	5.8	4.8	3.7	3.9	4.9	4.9	(36)
(37)			MCWBR	4.9	6.2	5.8	5.1	3.5	3.4	3.2	3.0	2.6	3.3	4.3	4.1	(37)
(38)			5% WB	MCDBR	5.5	7.1	6.3	5.8	5.0	5.8	5.2	4.4	3.3	3.7	4.7	5.0
(39)		MCWBR		4.9	6.3	5.9	4.9	3.5	3.6	3.4	3.1	2.7	3.3	4.3	4.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	N/A	0.214	0.256	0.308	0.327	0.328	0.329	0.327	0.288	0.238	0.353	N/A	(40)	
(41)		taud	N/A	2.126	2.271	2.230	2.407	2.512	2.534	2.526	2.557	2.236	2.858	N/A	(41)	
(42)		Ebn at Noon	N/A	596	791	833	864	875	861	820	769	548	139	0	(42)	
(43)		Edh at Noon	N/A	41	70	99	94	88	84	75	55	36	11	0	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.02	0.39	1.83	3.83	5.26	5.85	5.31	3.58	1.97	0.64	0.07	0.00	(44)	
(45)		RadStd	0.00	0.06	0.18	0.41	0.38	0.51	0.52	0.27	0.17	0.06	0.01	0.00	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.96	+3.17	N/A	+0.55	+0.39	+0.83	-295	-304	N/A	N/A
(47) Regional (3 neighbors)		+1.00	+3.29	N/A	+0.70	N/A	N/A	-295	-304	N/A	N/A

Nomenclature: See separate page