

KITSISSUT ATTU, Greenland

WMO: 042280

Lat: 67.784N

Lon: 53.965W

Elev: 39

StdP: 14.68

Time Zone: -3.00 (GRL)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-11.1	-7.8	-15.1	2.4	-10.8	-11.2	3.0	-7.4	41.4	18.2	34.4	15.5	11.6	340	1.015

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.2	48.3	45.0	46.5	44.0	45.0	43.0	45.7	47.4	44.4	45.9	43.4	44.6	11.0	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
44.5	43.4	46.2	43.3	41.4	45.0	42.2	39.7	43.9	18.0	47.7	17.4	46.1	16.9	44.8	50.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 38.0	31.6	27.5	DB	-10.6	53.7	5.2	2.7	-14.3	55.6	-17.3	57.1	-20.2	58.6	-24.0	60.5	(4)
(5)			WB	-10.7	47.9	4.9	2.3	-14.2	49.6	-17.1	50.9	-19.8	52.2	-23.3	53.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	26.7	14.2	10.3	11.2	20.1	30.0	35.6	40.3	41.8	38.4	31.8	25.7	20.1
	DBStd	12.76	9.64	10.85	10.51	8.08	4.22	3.34	3.49	2.64	2.96	4.48	5.42	7.04
	HDD50	8500	1111	1111	1204	898	620	433	301	254	347	564	729	928
	HDD65	13975	1576	1531	1669	1348	1085	883	766	719	797	1029	1179	1393
	CDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	13.0	13.8	12.7	13.1	13.6	11.7	11.2	10.7	11.3	12.9	14.0	15.8	15.5
Precipitation	PrecAvg	21.9	2.0	1.1	1.1	1.2	1.1	1.2	1.5	2.3	2.5	2.4	2.8	2.6
	PrecMax	31.0	6.4	2.4	2.8	3.4	2.6	3.0	3.1	5.1	5.9	5.0	5.9	6.4
	PrecMin	12.2	0.1	0.3	0.1	0.2	0.1	0.2	0.5	0.9	0.8	0.6	0.7	0.8
	PrecStd	4.5	1.3	0.6	0.7	0.8	0.7	0.7	0.7	1.1	1.0	1.1	1.4	1.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	36.0	37.2	36.6	39.4	41.2	48.7	51.7	50.9	46.1	43.9	40.9	37.4
		MCWB	32.8	33.2	33.7	34.6	37.4	45.2	46.1	46.9	42.3	39.8	37.7	35.2
	2%	DB	33.4	33.2	33.2	34.9	37.9	43.6	48.3	48.3	44.1	41.0	37.2	34.8
		MCWB	31.1	30.4	30.8	32.9	35.9	40.6	44.8	45.4	41.8	38.8	34.9	32.9
	5%	DB	29.4	29.8	30.3	32.9	36.2	41.4	46.4	46.7	43.1	39.2	35.4	32.2
		MCWB	27.7	28.4	28.6	31.3	34.5	39.4	43.9	44.5	41.0	37.0	33.5	30.4
	10%	DB	26.4	25.3	26.7	30.8	35.0	40.0	44.7	45.4	42.2	37.5	33.2	29.5
		MCWB	24.9	23.8	25.2	29.4	33.6	38.4	42.9	43.6	40.2	35.6	31.7	28.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	34.5	33.8	34.4	35.6	38.0	45.3	47.5	47.8	44.0	40.7	38.7	36.1
		MCDB	35.5	36.8	35.9	37.7	40.4	48.4	50.0	49.5	44.8	42.0	40.7	37.3
	2%	WB	30.9	30.7	31.0	33.2	36.3	40.9	45.5	46.2	42.4	38.9	35.2	33.4
		MCDB	33.1	32.7	32.7	34.6	37.7	42.6	47.6	47.6	43.5	40.7	36.5	34.6
	5%	WB	28.0	28.2	28.8	31.5	34.9	39.6	44.1	44.9	41.4	37.4	33.7	30.6
		MCDB	29.6	30.1	30.5	32.8	35.9	41.0	45.8	46.2	42.5	39.0	35.2	31.9
	10%	WB	25.0	23.7	25.0	29.6	33.9	38.6	43.1	43.9	40.5	35.8	31.8	28.1
		MCDB	26.1	25.2	26.5	30.8	34.8	39.8	44.5	45.0	41.7	37.3	33.2	29.6
Mean Daily Temperature Range	5% DB	MDBR	7.0	7.9	7.2	6.5	4.7	4.7	5.1	4.2	3.5	4.0	5.1	6.0
		MCDBR	8.8	12.7	8.6	7.9	6.3	7.0	7.4	6.5	4.5	5.3	7.4	8.1
		MCWBR	8.0	10.7	7.6	6.8	4.7	4.9	4.8	4.2	3.5	4.6	6.9	7.5
	5% WB	MCDBR	8.5	11.8	8.5	8.0	5.8	6.4	6.8	5.8	4.1	5.0	7.4	7.6
		MCWBR	7.8	10.3	7.6	7.0	4.6	4.8	4.7	4.2	3.6	4.4	7.1	7.1
Clear-Sky Solar Irradiance	taub	0.168	0.216	0.251	0.309	0.328	0.329	0.326	0.330	0.296	0.253	0.352	N/A	
	taud	1.927	2.168	2.297	2.233	2.408	2.505	2.547	2.541	2.548	2.252	2.841	N/A	
	Ebn at Noon	49	201	259	266	275	278	276	262	244	177	61	0	
	Edh at Noon	3	14	22	32	30	28	26	24	18	13	4	0	
All-Sky Solar Radiation	RadAvg	11	146	612	1209	1581	1743	1597	1079	617	205	26	0	
	RadStd	1	23	59	133	118	167	172	86	60	19	3	0	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)		+1.64	N/A	N/A	+1.48	N/A	N/A	N/A	N/A	+14	N/A

Nomenclature: See separate page