

NUUK GODTHAAB, Greenland

WMO: 042500

Lat: 64.167N

Lon: 51.744W

Elev: 84

StdP: 100.32

Time Zone: -3.00 (GRL)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-19.1	-16.9	-23.6	0.5	-16.9	-21.3	0.6	-15.1	22.3	-0.6	19.7	-3.3	6.9	0	0.948

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.5	15.2	9.8	13.6	9.2	12.0	8.5	10.7	13.8	9.9	12.5	9.0	11.5	4.1	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.1	7.3	11.2	8.2	6.8	10.3	7.4	6.5	9.6	31.2	13.9	29.1	12.7	27.2	11.5	15.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.8	16.0	13.2	DB	-19.5	19.2	3.1	2.1	-21.7	20.7	-23.5	22.0	-25.2	23.2	-27.5	24.7	(4)
(5)			WB	-19.9	13.0	3.0	1.3	-22.0	13.9	-23.8	14.6	-25.4	15.3	-27.6	16.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	-0.4	-7.0	-7.9	-7.3	-2.5	1.7	5.6	8.0	7.6	4.4	0.3	-3.0	-5.3	(6)
(7)		DBStd	6.91	4.92	5.65	5.82	4.20	3.19	2.82	2.56	2.38	2.28	3.35	3.96	4.53	(7)
(8)		HDD10.0	3821	527	502	537	376	257	134	72	81	169	302	389	476	(8)
(9)		HDD18.3	6841	786	735	796	626	515	381	319	332	419	559	639	734	(9)
(10)		CDD10.0	23	0	0	0	0	1	3	11	7	1	1	0	0	(10)
(11)		CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)
(12)		CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)
(13)		CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	5.6	6.4	6.3	6.3	5.8	5.1	4.8	4.6	4.8	5.4	5.5	6.5	6.4	(14)
(15)	Precipitation	PrecAvg	742	46	45	45	46	53	52	72	89	87	75	69	54	(15)
(16)		PrecMax	1146	201	220	153	141	147	167	228	227	222	180	210	201	(16)
(17)		PrecMin	456	3	2	2	4	3	1	2	0	16	11	7	6	(17)
(18)		PrecStd	154	35	40	33	32	37	37	48	57	46	43	48	33	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.0	8.8	8.1	9.5	13.5	16.8	17.5	16.9	13.2	11.5	10.0	7.8	(19)
(20)			MCWB	2.3	3.1	4.1	4.1	7.8	10.3	10.8	11.4	8.0	5.9	5.4	3.0	(20)
(21)		2%	DB	3.8	5.2	4.2	6.1	9.8	13.9	15.5	14.1	9.9	7.9	6.4	4.6	(21)
(22)			MCWB	0.7	1.1	1.3	2.7	5.8	9.1	10.1	9.8	6.8	4.2	3.2	1.7	(22)
(23)		5%	DB	1.9	2.2	2.2	4.1	7.8	11.9	13.9	12.3	8.4	5.8	4.0	2.7	(23)
(24)			MCWB	-0.4	-0.5	-0.1	1.8	4.7	7.9	9.5	9.1	6.1	3.4	1.7	0.6	(24)
(25)		10%	DB	0.0	-0.2	0.6	2.6	6.0	10.1	12.2	11.0	7.3	4.2	2.1	1.0	(25)
(26)			MCWB	-1.7	-1.8	-1.0	1.0	3.8	7.1	8.7	8.5	5.4	2.4	0.5	-0.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.7	4.0	4.2	5.0	8.2	10.8	12.0	12.5	9.6	7.2	6.3	4.2	(27)
(28)			MCD B	5.9	6.6	7.0	7.2	12.3	14.6	15.5	15.5	12.1	9.6	8.5	6.0	(28)
(29)		2%	WB	1.3	1.5	1.8	3.1	6.3	9.5	10.8	10.7	7.8	5.1	3.8	2.3	(29)
(30)			MCD B	3.0	4.5	3.4	5.0	9.0	13.0	14.2	13.0	9.0	6.8	5.9	4.1	(30)
(31)		5%	WB	-0.3	-0.3	0.3	2.0	5.0	8.2	10.0	9.7	6.6	3.7	1.9	0.8	(31)
(32)			MCD B	1.4	1.8	1.9	3.7	7.0	11.2	13.1	11.6	7.7	5.3	3.6	2.3	(32)
(33)		10%	WB	-1.8	-1.8	-1.2	1.1	3.9	7.2	9.1	8.9	5.7	2.6	0.6	-0.5	(33)
(34)			MCD B	0.0	0.1	0.6	2.5	5.6	9.6	11.9	10.6	6.8	4.0	1.8	1.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.3	4.5	4.7	4.5	4.8	6.1	6.5	5.5	4.2	3.7	3.8	4.1	(35)
(36)			MCDBR	7.1	8.4	7.3	6.7	8.1	9.5	9.3	8.0	6.1	6.2	6.8	6.4	(36)
(37)			MCWBR	5.4	5.7	5.1	4.4	4.9	5.5	5.1	4.6	3.8	4.1	4.9	4.8	(37)
(38)		5% WB	MCDBR	6.9	8.2	7.1	6.3	7.4	8.7	8.3	7.2	5.6	5.6	6.7	6.2	(38)
(39)			MCWBR	5.6	6.0	5.3	4.4	4.9	5.5	5.0	4.5	4.0	4.2	5.2	4.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.197	0.245	0.274	0.317	0.340	0.345	0.343	0.345	0.306	0.268	N/A	0.350	(40)	
(41)		taud	1.950	2.294	2.360	2.301	2.353	2.424	2.475	2.489	2.523	2.375	N/A	2.904	(41)	
(42)		Ebn at Noon	373	707	833	860	870	873	864	828	794	662	N/A	253	(42)	
(43)		Edh at Noon	27	51	75	100	105	100	93	84	65	47	N/A	16	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.12	0.62	2.01	3.82	5.29	5.73	5.22	3.83	2.27	1.02	0.23	0.05	(44)	
(45)		RadStd	0.01	0.08	0.21	0.38	0.41	0.44	0.54	0.34	0.26	0.10	0.05	0.01	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.49	+1.63	N/A	+1.12	N/A	N/A	N/A	N/A	+11	N/A
(47) Regional (3 neighbors)		+0.49	+1.63	N/A	+1.12	N/A	N/A	N/A	N/A	+11	N/A

Nomenclature: See separate page