

NUNARSUIT, Greenland

WMO: 042660

Lat: 60.764N

Lon: 48.454W

Elev: 98

StdP: 14.64

Time Zone: -3.00 (GRL)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	11.1	13.5	-0.4	5.4	17.4	1.9	6.1	19.2	67.1	28.3	60.6	22.8	34.4	320	1.189

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.3	50.2	45.1	48.2	43.9	46.6	43.2	47.2	48.6	45.7	47.1	44.5	45.8	18.3	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
46.5	46.9	47.2	44.9	44.1	45.8	43.5	41.9	44.7	18.8	48.8	18.0	47.3	17.4	45.9	60.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 56.3	51.5	47.0	DB	10.5	56.1	3.1	3.5	8.3	58.6	6.5	60.6	4.7	62.6	2.5	65.1	(4)
(5)			WB	8.4	50.7	3.2	3.8	6.1	53.4	4.2	55.6	2.4	57.8	0.1	60.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	33.3	26.6	25.9	26.2	30.4	34.8	37.7	40.3	41.7	39.6	35.9	31.7	28.6	
	DBStd	7.32	6.06	6.96	6.66	4.57	3.66	3.61	3.56	3.40	2.83	4.12	4.52	5.39	
	HDD50	6082	725	674	736	587	471	369	300	258	313	437	550	662	
	HDD65	11555	1190	1094	1201	1037	936	819	765	722	763	901	1000	1127	
	CDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	
Wind	WSAvg	21.8	25.0	26.5	25.8	24.1	18.3	16.1	16.0	17.7	20.8	23.3	23.6	24.3	
Precipitation	PrecAvg	52.5	5.4	5.3	4.2	3.6	3.1	3.0	3.0	3.9	5.2	4.5	5.9	5.3	
	PrecMax	88.1	14.4	13.6	11.4	9.3	7.8	5.9	7.2	8.8	10.3	10.4	12.9	13.8	
	PrecMin	29.2	1.5	1.4	0.6	0.7	1.0	0.2	0.3	1.1	1.5	1.6	1.3	1.3	
	PrecStd	11.4	3.1	3.2	2.4	1.9	1.4	1.6	1.7	1.8	2.1	2.3	3.2	2.8	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.9	44.0	44.2	45.6	49.3	50.5	53.2	53.1	52.0	50.9	45.9	43.6	
		MCWB	38.4	37.6	39.9	39.2	40.5	43.3	46.9	46.0	46.0	44.1	39.6	37.6	
	2%	DB	40.0	40.4	40.2	41.4	45.0	46.8	49.0	49.8	46.9	45.3	42.6	40.4	
		MCWB	35.7	36.3	36.8	36.8	39.2	42.0	45.3	45.7	43.5	41.0	38.5	35.6	
	5%	DB	37.3	37.6	37.3	38.5	41.9	44.5	47.0	48.1	44.8	43.0	39.8	37.9	
		MCWB	34.2	34.0	34.3	35.9	38.3	40.2	43.9	44.5	42.6	39.5	37.4	34.6	
	10%	DB	34.7	34.8	34.9	36.5	39.6	42.6	45.5	46.5	43.6	41.0	37.6	35.9	
		MCWB	32.1	32.2	32.7	35.1	36.9	40.0	43.0	44.1	41.8	38.4	35.7	33.3	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	40.3	39.9	40.5	40.5	43.1	46.5	49.9	49.8	47.3	45.0	42.4	39.3
			MCDB	42.6	42.0	43.3	43.4	45.6	48.3	50.7	50.5	49.8	48.4	44.3	40.7
2%		WB	36.6	36.8	37.4	38.1	40.5	43.7	46.7	47.5	44.6	42.2	39.4	37.1	
		MCDB	39.0	39.6	39.4	39.6	42.9	45.6	48.0	48.6	45.6	44.3	40.7	39.2	
5%		WB	34.3	34.5	35.2	36.5	39.1	42.1	45.2	46.0	43.3	40.4	37.4	35.4	
		MCDB	36.7	37.0	36.9	37.9	41.2	43.5	46.4	47.2	44.2	42.3	39.4	37.4	
10%		WB	32.4	32.5	32.9	35.0	37.6	40.7	43.9	44.8	42.3	39.0	35.8	33.7	
		MCDB	34.3	34.5	34.3	36.4	39.3	41.9	45.0	46.0	43.2	40.6	37.7	35.6	
Mean Daily Temperature Range	5% DB	MDBR	5.5	5.7	5.7	4.8	5.1	5.9	5.9	5.3	4.3	4.4	4.7	5.1	
		MCDBR	8.5	8.4	7.9	8.0	9.4	9.4	8.7	7.8	6.7	7.5	7.6	7.5	
		MCWBR	6.3	6.1	6.1	5.7	6.6	6.8	6.4	5.5	4.7	5.1	5.8	5.7	
	5% WB	MCDBR	8.3	8.5	7.5	7.0	8.2	8.6	7.9	6.8	5.9	6.7	6.7	7.0	
		MCWBR	6.9	7.2	6.5	5.9	6.5	6.9	6.4	5.5	5.0	5.1	6.0	5.8	
Clear-Sky Solar Irradiance	taub	0.260	0.278	0.300	0.344	0.353	0.340	0.365	0.360	0.331	0.290	0.240	N/A		
	taud	2.084	2.338	2.395	2.291	2.364	2.475	2.412	2.447	2.477	2.432	2.182	N/A		
	Ebn at Noon	148	231	265	269	276	282	271	263	252	225	161	N/A		
	Edh at Noon	13	19	25	34	34	31	32	29	23	17	11	N/A		
All-Sky Solar Radiation	RadAvg	71	239	622	1101	1473	1564	1472	1103	743	404	115	42		
	RadStd	8	39	79	126	114	145	145	115	80	33	18	3		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (3 neighbors)		+1.39	+5.22	N/A	+0.95	N/A	-0.99	-490	-464	N/A	N/A	

Nomenclature: See separate page