

NARSARSUAQ, Greenland

WMO: 042700

Lat: 61.1581N

Lon: 45.4405W

Elev: 112

StdP: 14.64

Time Zone: -3.00 (GRL)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-6.1	-2.3	-21.3	1.7	-2.3	-17.4	2.1	0.7	56.4	35.7	52.2	37.0	3.5	60	0.831

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.8	65.5	49.6	63.0	49.0	60.9	47.9	52.2	61.1	50.9	59.2	49.7	57.4	16.1	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
48.4	50.4	52.2	46.7	47.4	51.0	45.4	45.1	50.4	21.6	61.4	20.8	59.3	20.1	57.6	64.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 46.9	39.2	31.0	DB	-9.0	70.6	7.1	2.6	-14.1	72.5	-18.3	74.0	-22.3	75.5	-27.5	77.4	(4)
(5)			WB	-10.0	55.1	6.6	2.4	-14.8	56.8	-18.7	58.3	-22.4	59.6	-27.2	61.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	35.4	22.2	20.9	23.8	35.1	43.0	49.5	52.1	50.0	43.2	34.9	26.9	22.5		
	DBStd	14.51	12.61	13.10	11.86	7.92	6.10	4.82	3.96	3.74	5.04	7.60	10.33	12.13		
	HDD50	5532	860	816	814	449	231	65	21	44	212	473	694	853		
	HDD65	10793	1325	1235	1279	897	681	464	400	464	653	935	1143	1317		
	CDD50	212	0	0	0	2	14	52	86	45	9	4	0	0		
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	9.4	11.7	11.5	10.2	10.1	10.2	9.5	8.0	7.2	7.5	8.0	8.6	10.1		
(15) Precipitation	PrecAvg	24.2	1.5	1.3	1.5	1.7	1.5	2.0	2.6	2.8	2.7	2.0	2.4	2.4		
	PrecMax	41.3	6.1	6.9	4.3	4.9	6.3	5.3	9.0	8.6	8.9	6.3	6.6	12.9		
	PrecMin	10.2	0.0	0.0	0.0	0.1	0.1	0.0	0.3	0.0	0.2	0.0	0.2	0.3		
	PrecStd	6.8	1.4	1.4	1.4	1.4	1.5	1.3	1.9	2.1	2.1	1.6	2.0	2.6		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.0	52.3	53.5	57.1	66.1	67.8	68.3	68.2	61.9	59.5	54.1	53.4		
		MCWB	39.4	39.8	40.7	43.9	49.1	49.5	50.4	51.7	47.8	45.0	41.2	41.7		
	2%	DB	48.3	46.8	48.3	52.6	60.1	64.2	65.5	63.2	57.4	54.2	49.4	48.4		
		MCWB	36.8	36.2	37.3	40.6	45.3	48.3	49.8	49.7	44.0	41.4	37.7	36.8		
	5%	DB	43.9	42.5	44.0	49.7	56.3	61.7	63.4	60.8	54.3	50.1	46.2	44.4		
		MCWB	33.8	33.3	34.4	38.3	42.7	47.5	49.5	48.4	42.7	38.8	36.2	34.2		
	10%	DB	39.3	39.2	40.0	46.6	53.4	59.0	61.1	58.1	51.7	46.3	42.0	40.1		
		MCWB	30.7	30.8	31.9	36.7	41.2	46.4	48.6	47.2	41.9	36.9	34.3	31.5		
	0.4%	WB	40.7	40.3	41.7	45.1	50.4	52.7	54.2	53.9	50.8	46.8	43.8	42.0		
		MCDB	49.7	47.6	50.0	54.1	63.4	62.7	62.6	63.0	56.6	54.5	49.0	51.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	37.1	37.6	38.3	42.0	47.0	50.6	52.4	52.0	47.2	42.9	39.6	37.8		
		MCDB	47.3	45.5	46.7	50.2	56.5	60.3	61.3	59.7	52.3	51.2	47.0	46.7		
	5%	WB	34.2	34.4	35.3	39.5	44.5	49.1	51.1	50.4	45.4	40.3	37.2	34.8		
		MCDB	41.7	40.9	42.1	47.4	52.6	58.3	59.8	56.9	50.1	46.8	44.0	42.5		
	10%	WB	31.7	31.6	32.7	37.6	42.5	47.6	50.0	49.1	43.9	38.4	34.9	32.4		
		MCDB	37.7	37.8	38.6	44.8	50.4	56.2	58.2	55.3	48.6	44.4	40.6	38.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	12.3	12.2	12.5	11.3	12.6	13.6	13.8	13.0	11.3	10.3	10.8	11.6		
		MCDBR	15.9	13.6	14.3	14.2	16.4	17.8	18.1	17.6	15.0	13.8	15.1	14.3		
		MCWBR	9.3	8.5	8.3	7.4	7.9	8.5	9.1	9.0	7.0	7.4	8.7	8.3		
	5% WB	MCDBR	15.4	13.5	14.0	13.6	14.4	16.7	16.2	15.0	12.0	11.7	13.4	13.7		
		MCWBR	9.6	8.8	8.7	8.0	7.7	8.8	9.5	9.1	7.4	7.2	9.0	8.6		
(40) Clear-Sky Solar Irradiance	taub		0.255	0.265	0.299	0.340	0.353	0.364	0.360	0.353	0.323	0.276	0.232	0.201		
	taud		1.924	2.123	2.099	2.025	2.094	2.182	2.227	2.263	2.255	2.194	2.009	1.865		
	Ebn at Noon		133	226	256	266	273	272	271	262	248	217	147	102		
	Edh at Noon		15	23	33	43	44	42	39	34	29	21	13	9		
(44) All-Sky Solar Radiation	RadAvg		104	375	918	1606	2051	2181	2028	1541	972	519	167	57		
	RadStd		6	22	50	62	67	109	113	109	65	34	14	3		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+1.57	+5.22	N/A	+1.10	N/A	-1.13	-490	-464	N/A	N/A
(47) Regional (5 neighbors)		+1.57	+5.22	N/A	+1.10	N/A	-1.13	-490	-464	N/A	N/A

Nomenclature: See separate page