

QAQORTOQ JULIANEHAAB, Greenland

WMO: 042720

Lat: 60.716N

Lon: 46.043W

Elev: 112

StdP: 14.64

Time Zone: -3.00 (GRL)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	2.0	4.8	-9.4	3.3	5.5	-6.1	4.0	7.3	58.0	36.0	52.2	35.6	6.1	270	0.829

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.7	59.7	49.1	57.1	48.2	54.8	47.4	52.2	56.0	50.3	54.2	48.8	52.7	12.8	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
50.2	54.0	53.4	48.2	50.2	51.3	46.7	47.3	49.9	21.6	56.2	20.5	54.4	19.7	53.0	60.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 44.5	34.6	27.0	-0.2	64.6	5.2	2.2	-3.9	66.2	-7.0	67.5	-10.0	68.8	-13.8	70.4		
(5)			-1.0	55.6	4.8	1.8	-4.4	56.9	-7.2	58.0	-9.9	59.0	-13.3	60.3	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	34.7	24.3	22.9	25.0	33.1	38.7	43.3	46.4	46.9	43.2	36.2	29.9	26.1
	DBStd	11.17	9.87	10.59	9.59	6.68	4.79	4.78	4.30	3.87	4.26	6.09	7.49	8.94
	HDD50	5622	796	758	775	506	353	209	130	113	210	429	603	740
	HDD65	11045	1261	1177	1240	956	816	652	577	561	654	893	1053	1205
	CDD50	50	0	0	0	0	2	7	18	17	5	1	0	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	6.8	9.4	9.4	7.2	7.1	5.5	5.8	4.0	4.3	5.8	6.5	8.3	9.0
Precipitation	PrecAvg	38.4	2.8	3.1	2.4	2.5	2.2	2.8	2.9	4.2	4.6	3.6	4.3	2.7
	PrecMax	58.3	8.0	9.8	7.8	6.8	5.0	5.7	7.8	10.0	9.2	8.3	11.2	7.2
	PrecMin	15.6	0.5	0.2	0.1	0.2	0.3	0.1	0.2	0.6	0.4	0.4	0.1	0.2
	PrecStd	9.4	2.2	2.4	1.9	1.6	1.1	1.8	1.9	2.1	2.4	2.6	3.0	1.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	48.4	50.2	48.1	51.9	58.3	61.1	63.6	62.8	58.3	55.9	51.1	50.6
		MCWB	38.9	40.2	39.3	44.8	47.0	48.2	51.8	52.3	48.8	44.1	41.0	41.9
	2%	DB	45.3	44.7	44.1	48.8	52.9	57.5	59.9	58.4	55.1	52.1	48.7	45.9
		MCWB	37.1	37.9	36.8	40.3	43.1	46.9	49.7	49.4	46.6	42.6	40.1	38.0
	5%	DB	41.6	41.4	41.2	45.8	49.7	54.6	57.0	55.7	51.9	48.1	44.9	42.6
		MCWB	35.1	35.2	35.1	38.1	41.9	45.7	48.9	49.2	45.2	39.8	38.1	35.8
	10%	DB	37.8	37.9	38.2	43.0	46.7	51.7	54.0	53.3	49.5	44.9	40.6	39.2
		MCWB	32.4	32.2	32.8	36.8	40.3	45.0	48.6	48.4	44.1	39.1	36.8	34.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	40.6	41.6	41.3	46.6	48.3	51.3	55.3	55.4	51.6	47.4	44.5	43.0
		MCDB	45.7	46.0	44.8	50.7	55.2	56.1	60.4	58.6	54.7	53.1	46.3	49.2
	2%	WB	38.2	38.9	38.3	41.5	45.3	48.7	52.3	52.3	48.8	43.7	41.2	39.1
		MCDB	43.6	45.0	43.3	46.0	50.5	54.4	56.3	55.5	51.9	49.5	46.1	43.4
	5%	WB	35.7	35.8	35.6	39.1	43.0	47.1	50.3	50.4	47.0	41.8	39.2	36.8
		MCDB	41.5	40.2	40.2	44.0	47.3	52.4	54.6	53.7	50.0	46.4	44.5	41.7
	10%	WB	32.9	32.6	33.3	37.5	41.3	45.6	48.6	48.9	45.2	39.9	36.7	34.4
		MCDB	37.1	36.9	37.3	41.8	45.7	50.3	52.8	52.0	48.2	43.8	40.4	38.6
Mean Daily Temperature Range	5% DB	MDBR	8.9	8.9	9.3	9.3	10.1	10.9	10.5	8.7	7.9	7.3	7.5	7.8
		MCDBR	11.0	10.0	10.9	12.2	14.7	15.3	14.4	12.2	10.6	10.0	11.8	10.1
		MCWBR	7.1	7.1	7.3	7.5	8.6	8.3	8.2	6.9	6.1	5.7	8.0	6.6
	5% WB	MCDBR	11.9	10.0	10.5	11.0	13.0	13.5	12.9	10.6	8.7	8.8	10.7	9.7
		MCWBR	8.7	8.1	8.0	8.0	9.0	8.8	8.8	7.2	6.4	6.1	9.0	7.3
Clear-Sky Solar Irradiance	taub		0.254	0.274	0.296	0.336	0.340	0.348	0.356	0.352	0.322	0.289	0.236	0.201
	taud		2.026	2.240	2.277	2.200	2.315	2.376	2.388	2.417	2.442	2.340	2.125	1.948
	Ebn at Noon		147	229	264	271	280	279	273	266	254	221	160	118
	Edh at Noon		14	21	28	37	36	34	33	30	24	19	12	9
All-Sky Solar Radiation	RadAvg		94	318	801	1391	1779	1890	1763	1334	867	469	148	53
	RadStd		8	31	66	97	102	148	141	124	82	38	17	4

Historical Trends

		Heating		Cooling		Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46) Station Only	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47) Regional (4 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		+1.57	+5.22	N/A	+1.10	N/A	-1.13	-490	-464	N/A	N/A

Nomenclature: See separate page