

KAP MORRIS JESUP, Greenland

WMO: 043010

Lat: 83.656N

Lon: 33.374W

Elev: 4

StdP: 101.28

Time Zone: -3.00 (GRL)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	-41.8	-40.4	-43.8	0.1	-41.5	-42.2	0.1	-40.0	19.0	-21.7	16.6	-24.3	2.4	260	1.214

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	2.9	7.3	5.0	6.0	4.1	4.7	3.3	5.2	7.0	4.2	5.7	3.4	4.7	3.7	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3.8	5.0	5.3	2.7	4.6	4.6	1.8	4.3	3.9	19.2	7.1	17.1	5.9	15.5	4.8	9.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.8	14.8	12.7	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			DB													
			WB	-40.1	6.1	3.7	1.1	-42.8	6.9	-44.9	7.5	-47.0	8.1	-49.7	9.0	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-16.1	-29.8	-29.1	-30.3	-22.5	-10.0	0.0	2.2	0.5	-8.3	-16.9	-23.4	-26.7		
	DBStd	13.06	5.71	7.50	5.93	5.06	4.56	2.49	1.93	2.61	4.83	5.52	5.84	6.31		
	HDD10.0	9536	1234	1095	1250	975	621	299	243	296	550	835	1002	1136		
	HDD18.3	12578	1493	1328	1508	1225	879	549	501	554	800	1093	1252	1394		
	CDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0		
(14) Wind	WSAvg	4.5	4.4	4.7	4.0	4.3	4.8	5.2	4.4	4.6	4.2	4.2	4.6	5.1		
(15) Precipitation	PrecAvg	250	22	16	15	15	15	14	23	26	32	25	23	24		
	PrecMax	514	58	39	44	53	117	34	58	49	81	49	61	172		
	PrecMin	147	6	5	1	1	1	3	4	10	8	8	2	2		
	PrecStd	72	15	9	9	10	20	8	11	11	17	10	13	29		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-6.7	1.7	-3.5	-7.1	1.1	8.1	9.2	8.6	2.4	-2.8	-1.6	-4.6		
		MCWB	-7.8	-2.3	-5.0	-7.8	-0.7	6.6	6.2	5.5	0.5	-4.5	-3.7	-5.2		
	2%	DB	-16.5	-5.8	-13.8	-10.6	-0.8	6.1	7.7	6.7	0.1	-5.8	-9.8	-10.2		
		MCWB	-17.0	-7.5	-14.3	-11.3	-1.8	4.3	5.1	4.6	-1.1	-6.5	-10.4	-10.9		
	5%	DB	-19.5	-16.7	-18.9	-13.0	-2.3	4.4	6.4	5.1	-1.2	-7.5	-13.6	-15.0		
		MCWB	-19.8	-17.2	-19.3	-13.6	-3.0	2.9	4.4	3.6	-2.1	-8.1	-14.1	-15.4		
	10%	DB	-21.9	-20.4	-21.9	-15.3	-3.4	3.2	5.2	4.0	-2.4	-9.5	-15.7	-17.9		
		MCWB	-22.1	-20.7	-22.2	-15.7	-4.0	2.0	3.7	2.7	-3.1	-10.0	-16.2	-18.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-7.8	-1.8	-5.2	-7.6	-0.2	7.7	6.6	6.2	0.7	-4.2	-3.6	-5.0		
		MCDB	-6.4	1.6	-3.5	-7.1	1.0	7.8	7.9	7.6	1.8	-3.0	-1.9	-4.7		
	2%	WB	-16.8	-7.4	-14.0	-11.3	-1.7	4.2	5.4	4.7	-0.9	-6.3	-10.4	-10.8		
		MCDB	-16.4	-5.2	-13.7	-10.6	-0.9	5.8	7.2	6.4	-0.1	-5.7	-9.8	-10.0		
	5%	WB	-19.6	-17.0	-19.2	-13.6	-2.9	3.0	4.5	3.7	-2.0	-8.2	-14.0	-15.4		
		MCDB	-19.3	-16.6	-18.8	-13.1	-2.3	4.3	6.2	5.0	-1.3	-7.6	-13.8	-15.0		
	10%	WB	-21.9	-20.7	-22.1	-15.7	-4.0	2.1	3.7	2.8	-3.1	-9.9	-16.1	-18.2		
		MCDB	-21.7	-20.5	-21.8	-15.3	-3.4	3.1	5.1	4.0	-2.5	-9.5	-15.7	-17.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	5.8	6.4	5.3	5.0	3.6	2.9	2.9	3.0	4.3	5.5	5.8	5.9		
		MCDBR	8.8	14.3	9.1	7.5	4.5	5.1	5.2	5.2	4.8	7.7	9.9	12.2		
		MCWBR	8.6	12.8	8.7	7.3	3.9	3.9	3.6	3.6	4.0	7.1	9.3	11.6		
	5% WB	MCDBR	8.8	14.3	9.3	7.2	4.2	4.9	5.1	4.9	4.7	7.5	9.9	12.1		
		MCWBR	8.6	12.8	8.8	7.0	3.7	3.9	3.6	3.5	4.2	6.9	9.3	11.5		
(40) Clear-Sky Solar Irradiance	taub	N/A	N/A	0.166	0.247	0.277	0.301	0.297	0.279	0.185	N/A	N/A	N/A	N/A		
	taud	N/A	N/A	1.902	2.082	2.098	2.110	2.252	2.253	1.977	N/A	N/A	N/A	N/A		
	Ebn at Noon	0	0	438	718	791	789	775	686	419	0	0	0	0		
	Edh at Noon	0	0	28	72	95	102	83	63	27	0	0	0	0		
(44) All-Sky Solar Radiation	RadAvg	0.00	0.00	0.46	3.58	6.85	7.86	6.99	3.98	1.01	0.00	0.00	0.00	0.00		
	RadStd	0.00	0.00	0.04	0.16	0.23	0.36	0.38	0.32	0.07	0.00	0.00	0.00	0.00		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page