

HENRIK KROEYER HOLME, Greenland

WMO: 043130

Lat: 80.649N

Lon: 13.712W

Elev: 33

StdP: 14.68

Time Zone: -3.00 (GRL)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	-30.9	-25.7	-34.2	0.8	-28.2	-29.1	1.1	-23.0	68.6	-6.1	65.2	-7.4	7.8	20	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.9	42.6	38.9	40.5	37.5	38.7	36.3	39.3	42.2	37.7	40.1	36.5	38.4	7.9	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
36.3	31.5	39.5	35.1	30.0	38.0	34.2	28.9	37.0	14.9	42.5	14.2	40.3	13.7	38.7	46.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 57.8	49.5	41.7	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(5)			WB	-34.0	41.7	6.5	2.2	-38.7	43.3	-42.5	44.6	-46.2	45.9	-50.9	47.5	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.9	-3.2	-7.3	-8.7	1.7	18.0	31.1	35.1	32.6	23.3	9.6	0.4	-3.5
	DBStd	17.60	10.72	9.81	8.62	10.08	7.05	4.01	3.09	3.29	5.71	7.78	8.59	9.45
	HDD50	14284	1650	1604	1821	1448	994	567	463	538	800	1251	1488	1660
	HDD65	19759	2115	2024	2286	1898	1459	1017	928	1003	1250	1716	1938	2125
	CDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
	WSAvg	13.3	16.7	17.2	17.4	14.6	11.0	9.7	9.0	9.0	9.9	11.7	17.9	15.8
	PrecAvg	14.6	1.5	1.2	1.1	0.9	0.8	0.6	0.9	1.1	1.8	1.7	1.5	1.6
(15) Precipitation	PrecMax	25.0	5.2	2.5	2.9	3.0	5.6	1.9	3.0	2.6	4.0	4.0	4.0	7.7
	PrecMin	8.3	0.5	0.4	0.2	0.2	0.1	0.0	0.1	0.3	0.1	0.4	0.4	0.1
	PrecStd	3.8	1.1	0.7	0.7	0.6	1.0	0.5	0.6	0.6	1.0	0.8	0.9	1.4
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	29.5	27.8	26.3	31.8	34.6	44.6	46.5	43.0	34.2	31.1	29.3	30.0
		MCWB	29.1	27.4	25.5	31.4	32.0	39.3	41.6	38.8	32.5	30.6	29.0	29.4
	2%	DB	26.4	13.9	11.8	28.8	32.2	40.4	43.8	40.6	32.9	25.3	21.2	24.8
		MCWB	25.9	13.0	11.4	28.1	30.9	36.6	40.0	37.5	31.7	24.5	20.6	24.3
	5%	DB	18.6	8.7	7.4	21.9	30.7	38.0	41.7	38.8	31.8	22.3	15.4	15.3
		MCWB	18.0	8.2	6.9	21.4	29.5	35.2	38.5	36.4	31.0	21.0	14.7	14.7
	10%	DB	11.7	5.5	3.7	14.9	28.0	36.2	39.9	37.3	30.7	19.8	12.0	9.9
		MCWB	11.2	5.0	3.1	14.3	26.8	33.9	37.3	35.3	29.7	18.6	11.4	9.4
	0.4%	WB	29.2	27.5	25.6	31.9	32.8	39.5	42.3	39.4	33.1	30.6	29.1	29.4
		MCDB	29.5	28.0	26.6	32.0	33.8	44.0	45.6	41.9	33.6	30.9	29.4	29.8
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	26.2	12.0	12.9	28.6	31.4	37.0	40.4	37.8	32.2	25.0	20.8	25.4
		MCDB	26.8	12.4	13.2	29.3	32.2	40.0	43.4	39.9	32.6	25.5	21.3	26.0
	5%	WB	18.9	7.7	7.2	23.0	29.8	35.5	38.7	36.7	31.3	21.2	14.8	16.4
		MCDB	19.3	8.0	7.6	23.6	31.0	37.7	41.4	38.5	31.8	22.3	15.4	16.7
	10%	WB	11.7	4.6	2.7	15.1	27.2	34.1	37.4	35.6	29.9	18.8	11.3	10.5
		MCDB	12.1	5.0	3.2	15.7	28.4	35.7	39.5	37.1	30.6	19.8	11.9	11.0
(35) Mean Daily Temperature Range	5% DB	MDBR	10.7	10.1	9.9	9.7	7.2	5.2	4.9	4.6	5.3	7.1	7.9	9.5
		MCDBR	18.1	13.0	10.0	12.0	7.7	7.5	7.7	6.9	5.0	8.4	10.5	16.1
		MCWBR	18.0	12.7	9.6	12.1	6.7	5.1	5.3	5.0	4.6	8.2	10.3	15.5
	5% WB	MCDBR	18.1	12.7	9.9	11.8	7.3	7.2	7.6	6.5	5.0	8.6	10.0	17.2
		MCWBR	17.9	12.6	9.7	11.9	6.5	4.9	5.3	5.0	4.8	8.4	10.1	17.1
(40) Clear-Sky Solar Irradiance	taub		N/A	N/A	0.198	0.276	0.295	0.289	0.336	0.306	0.216	N/A	N/A	N/A
	taud		N/A	N/A	2.005	2.045	2.103	2.257	2.243	2.330	2.190	N/A	N/A	N/A
	Ebn at Noon		0	0	174	229	253	266	240	225	176	0	0	0
	Edh at Noon		0	0	13	27	33	30	29	21	11	0	0	0
(44) All-Sky Solar Radiation	RadAvg		0	0	220	1102	1947	2241	1893	1112	345	0	0	0
	RadStd		0	0	17	79	125	141	152	94	37	0	0	0

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page