

HENRIK KROEYER HOLME, GreenlandWMO: **043130**Lat: **80.649N**Lon: **13.712W**Elev: **10**StdP: **101.20**Time Zone: **-3.00 (GRL)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	-35.0	-32.1	-36.8	0.1	-33.5	-33.9	0.2	-30.5	30.7	-21.2	29.1	-21.9	3.5	20	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	2.7	5.9	3.8	4.7	3.0	3.7	2.4	4.1	5.7	3.2	4.5	2.5	3.6	3.5	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2.4	4.5	4.2	1.7	4.3	3.4	1.2	4.1	2.8	16.8	5.8	15.2	4.6	13.9	3.7	7.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 25.9	22.1	18.6	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			DB	-36.6	5.4	3.6	1.2	-39.3	6.3	-41.4	7.0	-43.4	7.7	-46.1	8.6	
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-11.7	-19.6	-21.8	-22.6	-16.8	-7.8	-0.5	1.7	0.4	-4.8	-12.4	-17.6	-19.7
	DBStd	9.78	5.95	5.45	4.79	5.60	3.92	2.23	1.72	1.83	3.17	4.32	4.77	5.25
	HDD10.0	7936	917	891	1012	804	552	315	257	299	444	695	827	922
	HDD18.3	10977	1175	1124	1270	1054	811	565	516	557	694	953	1077	1181
	CDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	5.9	7.5	7.7	7.8	6.5	4.9	4.4	4.0	4.0	4.4	5.2	8.0	7.1
Precipitation	PrecAvg	370	38	30	27	24	20	15	22	28	46	42	39	40
	PrecMax	634	131	64	74	77	142	49	77	66	102	102	102	195
	PrecMin	212	13	9	5	5	2	1	2	7	3	11	11	3
	PrecStd	96	28	17	18	15	25	13	16	15	26	21	22	36
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-1.4	-2.4	-3.2	-0.1	1.4	7.0	8.0	6.1	1.2	-0.5	-1.5	-1.1
		MCWB	-1.6	-2.5	-3.6	-0.3	0.0	4.0	5.4	3.8	0.3	-0.8	-1.7	-1.5
	2%	DB	-3.1	-10.1	-11.2	-1.8	0.1	4.7	6.5	4.8	0.5	-3.7	-6.0	-4.0
		MCWB	-3.4	-10.5	-11.5	-2.1	-0.6	2.5	4.5	3.1	-0.2	-4.2	-6.3	-4.3
	5%	DB	-7.4	-12.9	-13.6	-5.6	-0.7	3.3	5.4	3.8	-0.1	-5.4	-9.2	-9.3
		MCWB	-7.8	-13.2	-14.0	-5.9	-1.4	1.8	3.6	2.4	-0.5	-6.1	-9.6	-9.6
	10%	DB	-11.3	-14.7	-15.7	-9.5	-2.2	2.3	4.4	2.9	-0.7	-6.8	-11.1	-12.3
		MCWB	-11.5	-15.0	-16.0	-9.9	-2.9	1.1	2.9	1.8	-1.3	-7.5	-11.4	-12.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-1.6	-2.5	-3.5	-0.1	0.4	4.2	5.7	4.1	0.6	-0.8	-1.6	-1.5
		MCDB	-1.4	-2.2	-3.0	0.0	1.0	6.7	7.6	5.5	0.9	-0.6	-1.5	-1.2
	2%	WB	-3.2	-11.1	-10.6	-1.9	-0.3	2.8	4.6	3.2	0.1	-3.9	-6.2	-3.7
		MCDB	-2.9	-10.9	-10.4	-1.5	0.1	4.4	6.4	4.4	0.3	-3.6	-5.9	-3.3
	5%	WB	-7.3	-13.5	-13.8	-5.0	-1.2	1.9	3.7	2.6	-0.4	-6.0	-9.5	-8.7
		MCDB	-7.0	-13.3	-13.6	-4.7	-0.6	3.2	5.2	3.6	-0.1	-5.4	-9.2	-8.5
	10%	WB	-11.3	-15.2	-16.3	-9.4	-2.7	1.2	3.0	2.0	-1.1	-7.3	-11.5	-11.9
		MCDB	-11.0	-15.0	-16.0	-9.1	-2.0	2.1	4.2	2.8	-0.8	-6.8	-11.2	-11.7
Mean Daily Temperature Range	5% DB	MDBR	5.9	5.6	5.5	5.4	4.0	2.9	2.7	2.5	3.0	4.0	4.4	5.3
		MCDBR	10.1	7.2	5.5	6.7	4.3	4.1	4.3	3.8	2.8	4.7	5.8	8.9
		MCWBR	10.0	7.1	5.3	6.7	3.7	2.8	2.9	2.8	2.6	4.6	5.7	8.6
	5% WB	MCDBR	10.0	7.1	5.5	6.6	4.1	4.0	4.2	3.6	2.8	4.8	5.6	9.6
		MCWBR	10.0	7.0	5.4	6.6	3.6	2.7	3.0	2.8	2.7	4.7	5.6	9.5
Clear-Sky Solar Irradiance	taub		N/A	N/A	0.198	0.276	0.295	0.289	0.336	0.306	0.216	N/A	N/A	N/A
	taud		N/A	N/A	2.005	2.045	2.103	2.257	2.243	2.330	2.190	N/A	N/A	N/A
	Ebn at Noon		0	0	547	721	799	839	756	708	554	0	0	0
	Edh at Noon		0	0	40	86	103	94	91	67	35	0	0	0
All-Sky Solar Radiation	RadAvg		0.00	0.00	0.69	3.47	6.14	7.07	5.97	3.51	1.09	0.00	0.00	0.00
	RadStd		0.00	0.00	0.06	0.25	0.39	0.44	0.48	0.30	0.12	0.00	0.00	0.00