

DANEBOG AP, Greenland

WMO: 043300

Lat: 74.308N

Lon: 20.217W

Elev: 144

StdP: 14.62

Time Zone: 0.00 (E00)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-24.1	-21.0	-32.2	0.9	-22.9	-29.4	1.1	-20.2	53.6	6.0	49.1	6.3	5.6	340	1.055

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.5	54.8	46.4	52.0	44.9	49.3	43.1	47.6	53.5	45.3	51.0	43.6	48.7	9.0	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
43.4	41.8	49.2	41.2	38.4	46.2	39.5	35.8	44.4	19.0	53.4	17.8	51.1	16.9	48.9	56.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
43.6	37.2	31.1	DB	-28.8	60.6	3.5	3.8	-31.3	63.3	-33.4	65.5	-35.3	67.7	-37.9	70.5	
			WB	-29.1	49.4	3.4	2.9	-31.6	51.5	-33.6	53.2	-35.5	54.8	-37.9	56.8	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	17.0	0.2	-2.5	-2.6	8.5	23.7	34.9	41.5	41.5	31.4	18.9	6.3	1.2
	DBStd	18.63	11.61	12.31	9.71	10.11	6.68	4.68	5.25	5.16	4.74	8.37	9.20	11.34
	HDD50	12040	1544	1470	1630	1244	816	453	268	269	558	965	1311	1512
	HDD65	17505	2009	1890	2095	1694	1281	903	729	728	1008	1430	1761	1977
	CDD50	10	0	0	0	0	0	0	4	6	0	0	0	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	10.4	13.5	12.6	10.0	9.0	8.9	7.4	9.0	8.6	10.8	11.5	12.1	10.9
Precipitation	PrecAvg	18.4	2.4	1.9	1.4	1.0	0.8	0.5	0.9	1.4	2.1	1.8	2.0	2.1
	PrecMax	34.0	6.5	7.0	4.7	3.4	5.1	1.7	2.6	3.8	8.9	5.5	4.5	10.5
	PrecMin	10.7	0.6	0.2	0.3	0.2	0.1	0.1	0.3	0.4	0.3	0.4	0.2	0.2
	PrecStd	6.4	1.4	1.5	0.9	0.7	1.0	0.4	0.5	0.8	1.8	1.2	1.1	1.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	30.0	30.5	26.0	34.8	40.5	53.2	58.8	59.5	44.3	37.7	30.4	30.5
		MCWB	28.8	29.8	24.3	31.8	34.8	43.6	48.5	48.9	37.8	33.6	27.8	27.7
	2%	DB	25.8	25.0	19.5	31.3	36.8	48.1	55.0	55.4	41.2	34.5	27.1	26.7
		MCWB	24.9	23.7	18.1	29.5	32.6	40.7	46.6	46.8	35.9	31.6	25.0	25.6
	5%	DB	22.6	20.5	15.6	27.6	33.9	45.0	52.6	52.3	39.2	31.9	23.9	22.3
		MCWB	21.8	19.3	14.4	26.1	30.8	39.5	45.3	45.2	35.2	29.6	22.3	20.6
	10%	DB	18.2	16.1	11.9	23.7	32.0	42.2	50.0	49.6	37.5	29.3	20.1	18.0
		MCWB	17.0	14.7	10.6	22.1	29.6	38.1	43.9	43.2	33.9	27.3	18.5	16.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	28.5	29.8	24.9	33.1	35.8	43.9	51.0	50.6	39.3	34.5	29.0	28.5
		MCDB	29.8	30.0	26.6	34.8	38.5	51.1	55.8	56.9	42.3	36.8	29.9	29.4
	2%	WB	24.9	23.8	18.2	29.7	33.1	41.6	47.9	48.2	37.3	32.0	25.1	25.4
		MCDB	25.7	24.8	19.2	30.7	36.0	47.0	54.0	53.8	39.7	33.6	26.7	27.0
	5%	WB	21.6	19.4	14.5	26.1	31.3	39.8	45.6	45.8	35.9	29.6	22.2	20.9
		MCDB	22.5	20.4	15.6	27.8	33.5	44.3	51.2	51.4	38.4	31.7	24.0	22.3
	10%	WB	17.0	14.8	10.6	22.5	29.8	38.2	44.0	43.8	34.5	27.3	18.6	16.4
		MCDB	18.0	16.1	11.9	23.7	31.8	42.0	49.3	49.0	37.0	29.4	20.1	18.0
Mean Daily Temperature Range	5% DB	MDBR	11.7	11.7	12.5	12.4	9.9	8.6	9.5	8.5	6.4	6.2	9.0	10.9
		MCDBR	13.0	13.8	14.7	11.3	11.4	13.5	13.3	12.8	9.2	7.3	11.8	12.1
		MCWBR	12.0	13.3	13.6	9.7	8.3	8.4	7.1	6.5	6.0	5.8	10.7	11.1
	5% WB	MCDBR	11.9	13.7	14.2	9.9	10.0	12.7	12.9	12.1	8.4	6.8	11.7	12.3
		MCWBR	11.3	13.2	13.2	8.6	7.7	8.2	7.7	7.0	6.2	5.7	10.7	11.6
Clear-Sky Solar Irradiance	taub	N/A	0.169	0.231	0.287	0.311	0.314	0.308	0.298	0.258	0.176	N/A	N/A	
	taud	N/A	1.856	2.132	2.056	2.068	2.184	2.327	2.369	2.299	1.871	N/A	N/A	
	Ebn at Noon	0	101	225	252	264	269	268	253	217	84	0	0	
	Edh at Noon	0	7	19	33	38	36	30	24	17	6	0	0	
All-Sky Solar Radiation	RadAvg	0	45	474	1347	2209	2588	2212	1430	609	121	0	0	
	RadStd	0	3	25	66	63	99	107	88	51	9	0	0	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page