

DANEBOG AP, Greenland

WMO: 043300

Lat: 74.308N

Lon: 20.217W

Elev: 44

StdP: 100.80

Time Zone: 0.00 (E00)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-31.2	-29.4	-35.7	0.1	-30.5	-34.1	0.2	-29.0	24.0	-14.5	22.0	-14.3	2.5	340	1.055

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.7	12.7	8.0	11.1	7.2	9.6	6.2	8.7	12.0	7.4	10.5	6.4	9.3	4.0	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6.4	6.0	9.6	5.1	5.5	7.9	4.2	5.1	6.9	26.4	11.9	23.5	10.6	21.5	9.4	13.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.5	16.6	13.9	DB	-33.8	15.9	1.9	2.1	-35.2	17.4	-36.3	18.6	-37.4	19.8	-38.8	21.4	(4)
(5)			WB	-33.9	9.7	1.9	1.6	-35.3	10.8	-36.4	11.8	-37.5	12.6	-38.9	13.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-8.3	-17.7	-19.2	-19.2	-13.0	-4.6	1.6	5.3	5.3	-0.3	-7.3	-14.3	-17.1
	DBStd	10.35	6.45	6.84	5.40	5.62	3.71	2.60	2.92	2.87	2.64	4.65	5.11	6.30
	HDD10.0	6689	858	817	906	691	453	252	149	149	310	536	728	840
	HDD18.3	9725	1116	1050	1164	941	712	502	405	404	560	794	978	1098
	CDD10.0	6	0	0	0	0	0	0	2	3	0	0	0	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	4.6	6.0	5.6	4.5	4.0	4.0	3.3	4.0	3.9	4.8	5.1	5.4	4.9
Precipitation	PrecAvg	467	62	48	36	25	21	12	23	35	54	46	50	54
	PrecMax	864	166	179	119	86	129	44	66	96	226	139	115	266
	PrecMin	271	16	5	8	6	2	3	8	10	8	10	6	4
	PrecStd	162	35	39	24	18	26	9	12	20	46	31	27	49
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-1.1	-0.8	-3.3	1.6	4.7	11.8	14.9	15.3	6.8	3.2	-0.9	-0.9
		MCWB	-1.8	-1.2	-4.3	-0.1	1.5	6.4	9.2	9.4	3.2	0.9	-2.3	-2.4
	2%	DB	-3.4	-3.9	-7.0	-0.4	2.6	8.9	12.8	13.0	5.1	1.4	-2.7	-2.9
		MCWB	-4.0	-4.6	-7.7	-1.4	0.3	4.9	8.1	8.2	2.2	-0.2	-3.9	-3.6
	5%	DB	-5.2	-6.4	-9.1	-2.5	1.1	7.2	11.4	11.3	4.0	0.0	-4.5	-5.4
		MCWB	-5.7	-7.1	-9.8	-3.3	-0.6	4.2	7.4	7.3	1.8	-1.4	-5.4	-6.4
	10%	DB	-7.7	-8.9	-11.1	-4.6	0.0	5.7	10.0	9.8	3.1	-1.5	-6.6	-7.8
		MCWB	-8.3	-9.6	-11.9	-5.5	-1.4	3.4	6.6	6.2	1.1	-2.6	-7.5	-8.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-2.0	-1.2	-3.9	0.6	2.1	6.6	10.5	10.3	4.1	1.4	-1.7	-1.9
		MCDB	-1.2	-1.1	-3.0	1.6	3.6	10.6	13.2	13.8	5.7	2.7	-1.1	-1.4
	2%	WB	-4.0	-4.6	-7.7	-1.3	0.6	5.3	8.8	9.0	3.0	0.0	-3.8	-3.7
		MCDB	-3.5	-4.0	-7.1	-0.7	2.2	8.3	12.2	12.1	4.3	0.9	-2.9	-2.8
	5%	WB	-5.8	-7.0	-9.7	-3.3	-0.4	4.3	7.5	7.7	2.1	-1.3	-5.5	-6.2
		MCDB	-5.3	-6.4	-9.1	-2.3	0.8	6.8	10.7	10.8	3.5	-0.2	-4.5	-5.4
	10%	WB	-8.3	-9.6	-11.9	-5.3	-1.2	3.4	6.7	6.6	1.4	-2.6	-7.4	-8.7
		MCDB	-7.8	-8.9	-11.2	-4.6	-0.1	5.6	9.6	9.4	2.8	-1.4	-6.6	-7.8
Mean Daily Temperature Range	5% DB	MDBR	6.5	6.5	6.9	6.9	5.5	4.8	5.3	4.7	3.5	3.4	5.0	6.0
		MCDBR	7.2	7.7	8.2	6.3	6.3	7.5	7.4	7.1	5.1	4.0	6.6	6.7
		MCWBR	6.7	7.4	7.6	5.4	4.6	4.6	4.0	3.6	3.3	3.2	5.9	6.2
	5% WB	MCDBR	6.6	7.6	7.9	5.5	5.6	7.1	7.1	6.7	4.7	3.8	6.5	6.8
		MCWBR	6.3	7.3	7.4	4.8	4.3	4.6	4.3	3.9	3.4	3.2	6.0	6.5
Clear-Sky Solar Irradiance	taub	N/A	0.169	0.231	0.287	0.311	0.314	0.308	0.298	0.258	0.176	N/A	N/A	
	taud	N/A	1.856	2.132	2.056	2.068	2.184	2.327	2.369	2.299	1.871	N/A	N/A	
	Ebn at Noon	0	318	710	794	831	849	844	798	685	265	0	0	
	Edh at Noon	0	22	60	103	120	112	93	76	53	19	0	0	
All-Sky Solar Radiation	RadAvg	0.00	0.14	1.49	4.25	6.96	8.16	6.97	4.51	1.92	0.38	0.00	0.00	
	RadStd	0.00	0.01	0.08	0.21	0.20	0.31	0.34	0.28	0.16	0.03	0.00	0.00	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page