

ITTOQQORTOORMIIT SCORESBYSUND, Greenland

WMO: 043390

Lat: 70.4844N

Lon: 21.9511W

Elev: 69

StdP: 100.50

Time Zone: -1.00 (AZR)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-26.4	-24.3	-31.2	0.2	-24.1	-28.9	0.3	-22.5	26.9	-7.6	23.1	-6.8	1.5	30	0.967

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.5	12.6	7.1	11.0	6.5	9.6	5.9	7.8	11.1	7.1	10.0	6.4	9.0	2.4	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6.2	5.9	7.7	5.3	5.6	7.2	4.5	5.3	6.8	24.6	11.2	23.1	10.0	21.7	9.1	10.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.5	15.9	12.8	DB	-29.0	15.8	3.9	1.6	-31.8	16.9	-34.1	17.8	-36.2	18.7	-39.0	19.8	(4)
(5)			WB	-28.8	9.3	3.5	0.9	-31.3	9.9	-33.4	10.4	-35.3	11.0	-37.9	11.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-5.0	-12.8	-13.7	-13.2	-8.6	-2.3	2.8	6.0	5.8	1.8	-4.6	-9.3	-12.1		
	DBStd	8.42	6.00	6.01	5.19	4.83	2.92	2.56	2.42	2.27	2.35	3.70	4.21	5.31		
	HDD10.0	5466	706	663	721	559	380	215	126	133	247	453	579	685		
	HDD18.3	8504	964	896	979	809	638	465	382	389	497	712	829	943		
	CDD10.0	4	0	0	0	0	0	0	2	2	0	0	0	0		
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	3.9	4.7	4.4	4.2	3.6	3.6	2.4	2.7	3.2	3.9	4.6	4.4	4.8		
	PrecAvg	411	40	38	38	27	22	19	28	42	42	43	39	39		
(15) Precipitation	PrecMax	738	128	120	128	116	94	64	104	134	117	177	155	105		
	PrecMin	187	4	1	5	0	0	0	0	0	0	2	2	2		
	PrecStd	132	30	24	29	23	20	18	22	33	31	35	31	28		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	1.1	0.8	0.5	3.9	5.7	13.0	15.2	14.8	8.7	4.2	1.7	1.4		
		MCWB	-0.1	-0.4	-1.3	1.6	2.6	6.9	8.0	8.3	4.5	2.3	-0.2	-0.1		
	2%	DB	-1.4	-1.2	-2.0	1.4	3.9	10.1	13.0	12.3	7.1	2.3	-0.2	-0.8		
		MCWB	-2.6	-2.0	-3.1	0.0	1.6	5.4	7.4	7.0	4.1	0.7	-1.1	-2.1		
	5%	DB	-3.0	-3.1	-3.8	-0.3	2.6	8.4	11.4	10.7	6.2	1.1	-1.9	-2.6		
		MCWB	-4.0	-3.9	-4.7	-1.4	0.7	4.7	6.7	6.5	3.8	-0.1	-2.9	-3.7		
	10%	DB	-4.7	-4.9	-5.6	-2.3	1.6	7.0	10.1	9.3	5.3	0.1	-3.4	-4.6		
		MCWB	-5.7	-5.7	-6.5	-3.4	0.1	4.1	6.2	5.9	3.2	-1.0	-4.4	-5.7		
	0.4%	WB	0.0	0.0	-0.7	1.9	3.2	7.3	9.0	9.0	6.5	3.2	0.5	0.5		
		MCDB	1.4	0.6	0.2	3.0	4.9	11.7	12.6	13.3	7.4	3.8	1.2	1.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	-2.3	-1.8	-3.0	0.2	1.9	6.0	8.0	7.8	5.3	1.3	-1.1	-1.8		
		MCDB	-1.7	-1.2	-2.2	1.2	3.3	9.1	11.5	10.9	6.2	1.9	-0.4	-1.0		
	5%	WB	-3.9	-3.8	-4.6	-1.4	1.1	5.0	7.3	7.1	4.4	0.1	-2.8	-3.6		
		MCDB	-3.1	-3.2	-3.8	-0.3	2.2	7.8	10.4	9.6	5.5	0.8	-2.1	-2.7		
	10%	WB	-5.7	-5.7	-6.4	-3.3	0.3	4.2	6.6	6.5	3.5	-0.8	-4.4	-5.7		
		MCDB	-4.8	-5.0	-5.6	-2.4	1.4	6.7	9.5	8.7	4.7	0.0	-3.5	-4.6		
	5% DB	MDBR	5.7	5.8	5.9	6.2	4.7	5.3	5.5	4.8	3.7	3.6	4.4	5.4		
		MCDBR	7.3	6.8	6.5	6.8	5.9	8.0	7.8	7.0	5.0	4.5	5.9	6.8		
		MCWBR	6.5	6.3	5.6	5.6	4.2	4.7	4.3	3.9	3.4	3.6	5.2	6.0		
		MCWBR	7.1	6.8	6.1	6.4	5.5	7.4	7.0	5.9	4.3	3.9	5.7	6.7		
(35) Clear-Sky Solar Irradiance	taub		N/A	0.207	0.252	0.294	0.309	0.312	0.320	0.310	0.283	0.220	N/A	N/A		
		taud	N/A	1.996	2.175	2.104	2.130	2.261	2.402	2.443	2.407	2.044	N/A	N/A		
	Ebn at Noon		0	502	758	827	862	875	857	822	733	457	0	0		
		Edh at Noon	0	38	71	108	120	109	92	78	59	34	0	0		
(44) All-Sky Solar Radiation	RadAvg	0.00	0.29	1.77	4.17	6.27	7.03	5.26	3.53	1.67	0.49	0.00	0.00	0.00		
	RadStd	0.00	0.05	0.11	0.23	0.25	0.52	0.46	0.53	0.25	0.09	0.00	0.00	0.00		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page