

TASIILAQ AMMASSALIK, Greenland

WMO: 043600

Lat: 65.6111N

Lon: 37.6367W

Elev: 171

StdP: 14.61

Time Zone: -3.00 (GRL)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	1.2	4.4	-10.7	3.1	3.9	-6.8	3.8	7.9	40.3	18.3	33.4	19.1	9.8	280	0.811

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.2	56.6	46.8	53.9	46.3	51.8	45.5	48.9	53.5	47.6	52.0	46.4	50.6	6.9	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
46.4	46.9	49.5	45.0	44.4	48.3	43.7	42.3	47.3	19.8	53.8	19.0	52.1	18.4	50.8	58.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 28.7	21.8	16.4	DB	-2.2	63.4	4.8	5.0	-5.7	67.1	-8.5	70.0	-11.2	72.8	-14.7	76.5	(4)
(5)			WB	-2.8	51.8	4.4	2.7	-5.9	53.7	-8.5	55.2	-10.9	56.8	-14.1	58.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	31.8	21.3	21.4	21.6	28.4	34.5	40.7	45.1	44.8	40.0	32.1	27.3	23.5
	DBStd	10.77	8.85	8.31	7.83	6.26	4.19	4.45	4.17	3.51	4.00	5.82	6.24	8.15
	HDD50	6663	889	800	880	649	482	280	161	164	299	556	681	822
	HDD65	12125	1354	1220	1345	1099	947	729	618	625	749	1021	1131	1287
	CDD50	13	0	0	0	0	0	1	8	4	0	0	0	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	5.2	5.8	6.6	6.0	5.3	4.2	4.4	4.1	3.9	4.7	4.9	6.5	6.6
Precipitation	PrecAvg	35.8	3.9	3.8	3.7	2.7	2.4	1.7	1.7	2.4	3.3	3.0	3.7	3.9
	PrecMax	54.3	10.9	9.6	11.3	6.9	6.5	4.4	5.2	7.5	9.2	10.4	8.4	10.4
	PrecMin	22.3	0.9	0.9	0.5	0.0	0.2	0.0	0.0	0.2	0.2	0.4	0.4	0.6
	PrecStd	7.0	2.4	2.1	2.4	1.7	1.7	1.2	1.3	1.7	2.2	1.7	1.7	2.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	40.8	39.6	41.4	46.6	50.7	58.6	63.6	59.2	52.6	47.8	45.8	44.0
		MCWB	36.7	35.1	37.3	39.4	41.0	46.1	49.0	48.9	45.4	41.7	39.7	39.3
	2%	DB	38.5	37.2	38.0	41.8	45.6	53.7	57.5	55.3	49.6	44.9	40.9	40.3
		MCWB	35.8	34.1	35.4	37.5	39.9	44.9	47.3	46.9	43.0	40.7	37.2	36.8
	5%	DB	35.9	35.2	35.3	39.5	42.8	50.4	54.7	53.0	47.8	42.6	38.2	37.5
		MCWB	33.4	32.4	32.8	35.9	38.2	43.9	46.9	46.3	42.6	39.2	34.9	34.7
	10%	DB	33.3	32.9	32.4	37.3	40.6	48.1	52.2	51.0	46.1	40.3	35.8	34.5
		MCWB	31.0	30.4	30.1	34.4	36.7	42.7	46.0	45.6	41.3	37.0	32.9	32.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	38.3	37.2	38.0	40.7	43.1	48.6	51.8	50.6	47.8	44.1	40.6	41.1
		MCDB	39.4	38.5	40.0	45.0	46.8	53.9	59.2	55.0	50.6	46.5	45.4	42.6
	2%	WB	36.1	34.9	35.9	38.4	40.7	46.4	49.3	48.6	45.6	41.6	37.8	37.4
		MCDB	37.8	36.4	37.8	41.2	44.7	51.5	54.4	52.6	48.3	44.0	40.3	39.8
	5%	WB	33.8	32.7	33.2	36.6	38.8	44.8	47.8	47.4	43.8	39.8	35.5	35.1
		MCDB	35.5	34.6	34.7	38.9	41.9	49.2	52.9	51.2	46.5	42.1	37.6	37.2
	10%	WB	31.4	30.6	30.6	34.7	37.4	43.3	46.6	46.3	42.4	37.5	33.4	32.2
		MCDB	32.9	32.7	32.1	36.9	40.1	47.3	51.4	49.9	44.9	39.6	35.1	34.0
Mean Daily Temperature Range	5% DB	MDBR	8.5	8.8	9.8	9.7	9.2	10.9	11.2	9.5	7.8	6.7	7.0	7.4
		MCDBR	9.6	8.9	9.8	10.2	12.3	14.7	15.1	12.7	9.8	8.2	8.8	9.1
		MCWBR	7.5	7.2	7.8	7.4	8.0	8.8	8.2	6.9	6.0	5.7	6.6	6.9
	5% WB	MCDBR	9.1	8.4	9.7	9.5	10.8	12.9	13.0	10.5	8.3	6.9	8.5	8.5
		MCWBR	7.8	7.4	8.2	7.3	7.6	8.5	8.2	6.7	5.9	5.5	7.2	7.2
Clear-Sky Solar Irradiance	taub	0.213	0.263	0.271	0.306	0.322	0.322	0.325	0.318	0.300	0.265	0.368	N/A	
	taud	1.870	2.083	2.240	2.145	2.158	2.290	2.381	2.419	2.412	2.218	2.764	N/A	
	Ebn at Noon	71	190	256	271	278	281	277	268	246	190	89	N/A	
	Edh at Noon	7	18	25	36	39	36	32	28	22	16	7	N/A	
All-Sky Solar Radiation	RadAvg	25	172	625	1283	1824	1953	1701	1247	639	254	47	6	
	RadStd	3	43	82	146	238	258	118	83	101	34	5	1	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+2.11	N/A	N/A	N/A	+0.99	N/A	N/A	N/A	N/A	N/A
(47)	Regional (2 neighbors)	+2.11	N/A	N/A	N/A	+0.99	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page