

IKERMIT, Greenland

WMO: 043730

Lat: 64.782N

Lon: 40.302W

Elev: 262

StdP: 14.56

Time Zone: -3.00 (GRL)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	4.6	6.9	-6.4	3.9	8.3	-4.0	4.5	9.4	76.1	15.6	69.3	12.8	40.2	310	1.004

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.7	54.3	44.4	51.8	43.1	49.8	42.2	46.3	51.1	44.6	49.6	43.3	47.9	9.6	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
44.5	43.7	45.4	42.1	39.9	44.1	40.5	37.4	43.0	18.4	50.9	17.5	49.6	16.9	48.2	56.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.7	55.0	45.6	1.1	59.3	3.8	2.2	-1.6	60.9	-3.9	62.2	-6.0	63.4	-8.8	65.0
			0.4	48.8	3.6	2.7	-2.2	50.7	-4.3	52.3	-6.3	53.8	-8.9	55.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	30.5	21.7	20.4	20.7	27.1	33.0	38.9	43.4	42.8	37.2	30.5	26.3	23.2
	DBStd	9.75	6.95	6.88	6.51	5.52	3.91	4.63	4.36	3.79	3.71	4.88	5.13	6.18
	HDD50	7130	879	829	909	688	527	335	208	225	383	605	711	831
	HDD65	12598	1344	1249	1374	1138	992	784	669	688	833	1070	1161	1296
	CDD50	7	0	0	0	0	0	1	4	2	0	0	0	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	15.4	20.4	20.5	18.4	15.5	10.2	7.4	7.1	8.5	14.5	18.7	22.0	21.8
Precipitation	PrecAvg	53.8	5.5	5.2	4.9	4.3	3.3	3.2	2.5	3.7	4.9	4.7	6.3	5.4
	PrecMax	81.7	13.2	12.4	9.3	10.0	6.6	6.6	7.1	6.3	9.5	11.9	13.1	13.9
	PrecMin	30.0	1.1	0.7	1.1	0.2	0.8	0.7	0.1	0.9	0.5	0.7	1.4	0.6
	PrecStd	13.1	2.9	3.0	2.3	2.1	1.5	1.7	1.7	1.3	2.2	2.7	3.2	3.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	38.6	34.5	37.6	46.4	50.2	56.6	58.1	56.7	48.3	44.4	42.8	41.8
		MCWB	31.8	31.7	33.4	39.5	40.9	45.4	47.7	45.2	39.1	36.2	35.6	34.1
	2%	DB	34.1	32.4	33.5	39.7	44.6	51.7	54.4	53.6	45.8	40.4	35.7	35.6
		MCWB	31.3	31.3	32.2	34.6	37.3	42.5	45.0	43.4	38.3	35.1	32.4	32.2
	5%	DB	32.2	31.3	32.0	36.1	41.4	48.7	52.1	51.2	44.2	38.6	34.0	32.4
		MCWB	30.8	30.5	31.2	33.1	36.2	41.5	43.9	42.0	37.6	34.3	31.4	30.9
	10%	DB	30.5	29.6	30.2	33.9	38.8	45.9	50.2	48.8	42.5	36.9	32.3	31.1
		MCWB	29.3	28.8	29.0	31.6	34.6	40.6	43.2	40.9	36.6	33.4	30.6	29.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	33.8	33.2	35.4	40.7	42.1	47.4	50.7	45.9	44.2	39.4	37.5	35.7
		MCDB	34.5	33.3	36.6	43.1	47.3	51.9	53.3	53.2	44.7	41.4	42.3	39.1
	2%	WB	32.3	31.9	32.7	35.8	39.4	44.6	47.8	44.5	40.9	37.5	33.9	33.2
		MCDB	33.3	32.1	33.1	37.6	43.2	49.6	51.1	50.4	42.6	38.9	35.1	35.2
	5%	WB	31.2	30.6	31.4	33.9	37.1	42.8	45.5	43.4	39.5	35.9	32.3	31.6
		MCDB	32.2	31.2	31.9	35.7	39.5	47.2	50.0	48.3	41.6	37.4	32.9	32.4
	10%	WB	29.5	29.1	29.3	32.4	35.5	41.3	44.0	42.3	38.5	34.2	31.3	30.1
		MCDB	30.5	29.7	30.1	33.5	37.8	45.2	48.7	46.7	40.7	36.1	32.0	31.0
Mean Daily Temperature Range	5% DB	MDBR	6.3	6.7	7.4	7.7	7.8	8.5	8.7	8.1	6.3	5.1	5.3	5.7
		MCDBR	6.9	7.1	7.2	10.4	12.8	13.1	11.1	11.6	8.4	7.6	6.8	6.5
		MCWBR	5.9	6.7	6.2	7.5	7.9	7.2	6.1	6.0	5.1	5.4	5.4	5.7
	5% WB	MCDBR	6.9	6.2	6.4	9.2	10.8	10.9	10.2	9.5	6.7	6.6	5.9	5.9
		MCWBR	6.5	6.3	6.2	7.1	7.7	7.3	6.9	5.8	5.2	5.4	5.6	5.7
Clear-Sky Solar Irradiance	taub	0.201	0.264	0.275	0.313	0.325	0.331	0.329	0.317	0.296	0.270	0.188	N/A	
	taud	1.881	2.077	2.201	2.095	2.119	2.247	2.358	2.413	2.412	2.221	1.939	N/A	
	Ebn at Noon	96	196	257	270	278	279	277	270	251	195	102	N/A	
	Edh at Noon	8	19	27	38	41	37	33	28	22	16	7	N/A	
All-Sky Solar Radiation	RadAvg	46	267	822	1564	2232	2388	2172	1631	929	409	88	15	
	RadStd	3	23	34	76	93	152	77	60	57	34	4	1	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	+2.11	N/A	N/A	N/A	+0.99	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page