

IKERMIUARSUK, Greenland

WMO: 043820

Lat: 61.936N

Lon: 42.068W

Elev: 39

StdP: 100.86

Time Zone: -3.00 (GRL)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-11.6	-10.2	-19.9	0.6	-9.7	-18.3	0.7	-8.5	28.0	-5.6	26.3	-5.0	8.6	300	1.029

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.1	10.6	6.4	9.4	5.7	8.5	5.2	7.2	9.3	6.6	8.4	6.0	7.6	3.9	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6.1	5.8	7.2	5.5	5.6	6.7	4.8	5.4	6.2	23.2	9.4	21.9	8.5	20.7	7.6	11.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 23.4	20.3	17.9	-13.2	15.0	2.1	2.2	-14.7	16.6	-15.9	17.9	-17.1	19.1	-18.6	20.6		
(5)			-13.8	9.4	2.3	1.0	-15.4	10.2	-16.8	10.8	-18.0	11.4	-19.7	12.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	0.2	-3.9	-4.5	-4.2	-1.5	0.8	2.9	5.0	5.6	4.0	1.2	-0.9	-2.7
	DBStd	4.16	2.83	2.98	2.84	2.26	1.47	2.01	2.18	1.81	1.73	2.01	1.91	2.49
	HDD10.0	3586	431	405	441	344	286	212	154	136	179	273	328	395
	HDD18.3	6627	689	638	699	594	544	462	412	394	429	531	578	653
	CDD10.0	1	0	0	0	0	0	0	1	0	0	0	0	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
(14) Wind	WSAvg	6.9	8.7	8.8	7.2	7.1	6.2	5.6	5.3	4.9	6.6	7.0	7.8	8.3
(15) Precipitation	PrecAvg	1178	133	111	86	78	67	77	76	92	111	102	121	122
	PrecMax	1569	285	264	160	161	165	119	122	150	199	220	215	356
	PrecMin	940	35	35	16	28	21	23	24	26	60	33	53	21
	PrecStd	163	57	48	34	31	29	26	26	30	34	42	43	60
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	2.2	2.2	3.1	5.3	7.1	11.0	12.9	12.5	10.1	8.1	5.1	3.7
		MCWB	0.1	0.9	0.5	1.4	2.5	6.8	8.3	7.3	4.4	2.9	0.8	1.5
	2%	DB	0.9	1.2	1.3	3.3	4.7	8.8	10.7	10.4	8.7	5.7	3.1	2.2
		MCWB	-0.4	0.4	0.2	0.7	1.8	5.4	6.8	6.2	3.9	2.5	0.7	0.5
	5%	DB	0.2	0.2	0.5	2.1	3.7	7.3	9.4	9.3	7.5	4.7	2.1	1.3
		MCWB	-0.7	-0.5	-0.4	0.4	1.5	4.5	6.1	5.8	3.8	2.5	0.2	-0.2
	10%	DB	-0.4	-0.5	-0.2	1.2	2.9	6.0	8.3	8.3	6.5	3.9	1.4	0.4
		MCWB	-1.3	-1.3	-1.0	0.1	1.1	4.0	5.6	5.4	3.8	1.8	-0.2	-0.7
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	0.9	1.6	1.6	2.4	3.8	7.3	8.8	8.1	6.8	4.7	2.7	2.5
		MCDB	1.2	1.8	2.1	4.1	5.1	9.6	12.2	10.6	7.3	5.6	3.5	3.2
	2%	WB	0.1	0.7	0.6	1.5	2.7	6.1	7.3	7.1	5.6	3.9	1.5	1.1
		MCDB	0.4	0.9	1.0	2.3	3.9	8.1	9.7	9.1	6.7	4.8	2.1	1.8
	5%	WB	-0.4	-0.3	0.0	0.9	2.0	5.1	6.6	6.5	5.0	3.1	0.8	0.3
		MCDB	0.0	0.0	0.3	1.5	3.0	6.6	8.6	8.3	6.2	4.2	1.5	0.8
	10%	WB	-1.0	-1.1	-0.8	0.4	1.5	4.3	6.0	6.0	4.4	2.3	0.2	-0.5
		MCDB	-0.5	-0.7	-0.2	1.0	2.5	5.7	7.7	7.5	5.6	3.5	0.9	0.2
(35) Mean Daily Temperature Range	MDBR		3.1	3.6	3.9	4.0	3.7	4.0	4.4	4.1	3.3	3.0	2.7	2.7
	5% DB	MCDBR	3.5	3.9	4.2	5.3	5.3	6.3	6.5	5.8	4.8	4.2	3.8	3.7
		MCWBR	3.2	3.5	3.6	3.6	3.3	3.6	3.7	3.1	2.7	2.6	2.6	2.7
	5% WB	MCDBR	3.4	3.4	3.5	3.9	4.4	5.3	5.9	4.9	3.6	3.7	3.2	3.1
		MCWBR	3.3	3.4	3.3	2.8	3.0	3.5	3.7	3.1	2.5	2.6	2.6	2.7
(40) Clear-Sky Solar Irradiance	taub		0.244	0.277	0.284	0.323	0.333	0.341	0.336	0.326	0.307	0.277	0.224	0.373
	taud		2.014	2.201	2.295	2.190	2.211	2.290	2.377	2.430	2.418	2.332	2.084	2.769
	Ebn at Noon		423	687	836	861	882	881	878	858	806	690	459	313
	Edh at Noon		38	65	84	115	123	116	104	91	75	56	33	23
(44) All-Sky Solar Radiation	RadAvg		0.26	0.96	2.54	4.54	6.11	6.32	5.96	4.60	2.85	1.40	0.41	0.14
	RadStd		0.03	0.10	0.16	0.36	0.43	0.56	0.31	0.31	0.18	0.14	0.03	0.01

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)		+0.87	+2.90	N/A	+0.61	N/A	-0.63	-272	-258	N/A	N/A

Nomenclature: See separate page