

AKRABERG FYR, Faroe Islands

WMO: 060090

Lat: 61.3956N

Lon: 6.6817W

Elev: 335

StdP: 14.52

Time Zone: 0.00 (EUW)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	28.3	30.2	15.2	12.1	31.3	19.0	14.5	31.7	58.1	43.4	52.3	42.3	19.3	340	0.932

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	3.7	55.6	54.1	54.4	53.1	53.6	52.4	54.7	55.3	53.7	54.1	53.0	53.3	11.8	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
54.3	63.6	54.9	53.5	61.6	53.9	52.8	59.9	53.2	23.1	55.4	22.5	54.1	22.1	53.4	58.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 53.7	45.5	39.8	25.3	57.8	2.3	1.5	23.7	58.9	22.3	59.8	21.1	60.6	19.4	61.7		
(5)			22.7	56.4	2.0	1.6	21.3	57.6	20.1	58.5	19.0	59.4	17.5	60.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	44.1	39.8	39.3	39.9	41.3	44.1	47.6	50.4	49.8	48.4	45.3	42.7	40.9		
	DBStd	5.77	4.19	4.62	4.25	4.03	3.31	2.36	2.50	5.00	4.98	4.94	4.85	4.68		
	HDD50	2241	317	300	315	261	185	77	21	45	70	149	218	283		
	HDD65	7612	782	720	780	711	648	523	453	470	498	611	668	748		
	CDD50	103	0	0	0	0	2	4	33	39	22	3	0	0		
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	12.6	16.1	14.5	14.2	12.1	11.2	10.0	9.9	10.0	11.8	13.0	14.9	13.1		
	PrecAvg	86.5	10.9	8.6	8.4	5.7	4.3	3.5	3.9	5.1	7.3	9.1	9.6	10.0		
(15) Precipitation	PrecMax	111.1	19.1	16.9	15.2	10.4	9.4	6.8	6.9	8.1	12.5	16.9	14.5	15.6		
	PrecMin	62.8	5.4	3.9	4.3	2.2	1.5	1.3	0.9	3.4	3.5	3.7	4.0	4.9		
	PrecStd	13.2	3.1	3.0	2.6	2.1	1.6	1.4	1.1	1.4	2.4	2.7	2.9	3.0		
	PrecStd	13.2	3.1	3.0	2.6	2.1	1.6	1.4	1.1	1.4	2.4	2.7	2.9	3.0		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	48.2	47.5	47.9	49.7	55.3	57.3	57.8	57.5	54.6	52.8	50.4	49.2			
	0.4% MCWB	46.9	46.4	46.8	47.4	51.4	54.8	56.2	55.5	52.6	51.7	49.4	48.3			
	2% DB	47.2	46.6	46.7	47.7	51.3	52.7	55.7	55.1	53.7	51.9	49.5	48.4			
	2% MCWB	46.2	45.5	45.7	46.1	49.2	50.7	54.7	53.7	52.6	51.0	48.6	47.6			
	5% DB	46.3	45.8	46.0	46.9	49.4	51.4	54.5	54.1	53.1	51.2	48.8	47.7			
	5% MCWB	45.4	44.6	44.9	45.7	48.1	50.1	53.5	52.9	52.2	50.4	48.0	46.8			
	10% DB	45.4	45.1	45.2	46.3	48.2	50.6	53.4	53.5	52.6	50.5	48.3	46.9			
	10% MCWB	44.1	43.7	44.0	45.2	47.1	49.5	52.5	52.4	51.8	49.8	47.4	46.0			
	0.4% WB	47.7	47.2	47.5	48.4	52.0	54.6	56.6	56.1	53.9	52.2	50.2	49.0			
	0.4% MCDB	47.8	47.3	47.5	49.3	54.4	56.6	57.2	57.3	54.0	52.3	50.3	49.1			
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2% WB	46.8	46.2	46.4	47.0	49.7	51.6	55.0	54.5	53.1	51.4	49.2	48.2			
	2% MCDB	47.0	46.4	46.5	47.5	50.7	52.0	55.5	55.0	53.2	51.6	49.4	48.3			
	5% WB	45.9	45.2	45.5	46.4	48.5	50.6	53.9	53.6	52.7	50.9	48.5	47.4			
	5% MCDB	46.3	45.7	45.8	46.7	49.2	51.0	54.3	53.9	52.9	51.1	48.7	47.6			
	10% WB	44.7	44.2	44.6	45.6	47.4	49.9	52.9	52.9	52.1	50.2	47.7	46.4			
	10% MCDB	45.2	44.9	45.0	46.1	48.0	50.3	53.3	53.3	52.4	50.5	48.1	46.8			
(35) Mean Daily Temperature Range	MDBR	4.7	4.4	4.7	4.8	4.7	3.9	3.7	3.4	3.3	3.7	4.1	4.7			
	5% DB MCDBR	5.6	4.7	4.7	4.4	5.7	4.8	4.9	4.1	3.3	3.2	3.8	4.8			
	5% DB MCWBR	6.6	5.5	4.9	4.5	4.4	3.9	4.0	3.5	3.2	3.7	4.9	6.1			
	5% WB MCDBR	5.6	4.5	4.4	4.0	4.9	4.1	4.5	3.5	3.2	3.3	3.9	4.9			
	5% WB MCWBR	6.9	5.5	5.0	4.5	4.2	3.7	4.0	3.3	3.2	3.8	5.0	6.4			
	5% WB MCWBR	6.9	5.5	5.0	4.5	4.2	3.7	4.0	3.3	3.2	3.8	5.0	6.4			
(40) Clear-Sky Solar Irradiance	taub	0.316	0.345	0.357	0.378	0.367	0.361	0.367	0.357	0.359	0.338	0.303	0.382			
	taud	2.062	2.206	2.310	2.299	2.404	2.466	2.471	2.498	2.423	2.313	2.110	2.388			
	Ebn at Noon	113	192	239	257	271	275	270	264	238	194	116	72			
	Edh at Noon	13	22	28	34	33	31	30	28	25	19	12	8			
	Edh at Noon	13	22	28	34	33	31	30	28	25	19	12	8			
(44) All-Sky Solar Radiation	RadAvg	62	214	552	1030	1460	1565	1393	1135	693	308	91	36			
	RadStd	7	24	47	80	132	153	95	100	48	31	9	2			

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)		+0.92	+2.05	N/A	N/A	N/A	N/A	N/A	N/A	+54	N/A

Nomenclature: See separate page