

AKRABERG FYR, Faroe Islands

WMO: 060090

Lat: 61.3956N

Lon: 6.6817W

Elev: 102

StdP: 100.11

Time Zone: 0.00 (EUW)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-2.1	-1.0	-9.3	1.7	-0.4	-7.2	2.1	-0.1	26.0	6.3	23.4	5.7	8.6	340	0.932

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	2.0	13.1	12.3	12.4	11.7	12.0	11.4	12.6	12.9	12.1	12.3	11.6	11.8	5.3	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.4	9.1	12.7	11.9	8.8	12.1	11.5	8.6	11.8	36.0	13.0	34.6	12.3	33.5	11.9	14.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.0	20.4	17.8	-3.7	14.4	1.3	0.8	-4.6	15.0	-5.4	15.4	-6.1	15.9	-7.0	16.5
			-5.2	13.5	1.1	0.9	-6.0	14.2	-6.6	14.7	-7.2	15.2	-8.0	15.9
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	6.7	4.3	4.1	4.4	5.2	6.7	8.6	10.2	9.9	9.1	7.4	6.0	4.9	(6)
(7)		DBStd	3.20	2.33	2.57	2.36	2.24	1.84	1.31	1.39	2.78	2.77	2.74	2.70	2.60	(7)
(8)		HDD10.0	1245	176	167	175	145	103	43	12	25	39	83	121	157	(8)
(9)		HDD18.3	4229	434	400	433	395	360	291	252	261	277	339	371	416	(9)
(10)		CDD10.0	57	0	0	0	0	1	2	18	22	12	2	0	0	(10)
(11)		CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)
(12)		CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)
(13)		CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	5.6	7.2	6.5	6.3	5.4	5.0	4.5	4.4	5.3	5.8	6.7	5.9	(14)	
(15)	Precipitation	PrecAvg	2197	276	218	213	146	108	89	100	129	186	232	244	255	(15)
(16)		PrecMax	2822	486	429	386	264	239	172	175	205	318	430	368	396	(16)
(17)		PrecMin	1594	138	100	108	55	39	34	22	86	89	94	102	125	(17)
(18)		PrecStd	335	80	75	67	53	41	36	29	35	62	69	73	76	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.0	8.6	8.8	9.8	13.0	14.1	14.3	14.2	12.5	11.5	10.2	9.6	(19)
(20)			MCWB	8.3	8.0	8.2	8.6	10.8	12.6	13.4	13.0	11.5	11.0	9.7	9.0	(20)
(21)		2%	DB	8.5	8.1	8.2	8.7	10.7	11.5	13.2	12.8	12.1	11.0	9.7	9.1	(21)
(22)			MCWB	7.9	7.5	7.6	7.8	9.6	10.4	12.6	12.1	11.4	10.6	9.2	8.7	(22)
(23)		5%	DB	8.0	7.7	7.8	8.3	9.7	10.8	12.5	12.3	11.7	10.6	9.4	8.7	(23)
(24)			MCWB	7.5	7.0	7.2	7.6	8.9	10.1	11.9	11.6	11.2	10.2	8.9	8.2	(24)
(25)		10%	DB	7.5	7.3	7.3	7.9	9.0	10.3	11.9	11.9	11.4	10.3	9.0	8.3	(25)
(26)			MCWB	6.7	6.5	6.7	7.3	8.4	9.7	11.4	11.3	11.0	9.9	8.6	7.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.7	8.5	8.6	9.1	11.1	12.6	13.7	13.4	12.2	11.2	10.1	9.5	(27)
(28)			MCDB	8.8	8.5	8.6	9.6	12.5	13.7	14.0	14.1	12.2	11.3	10.1	9.5	(28)
(29)		2%	WB	8.2	7.9	8.0	8.3	9.8	10.9	12.8	12.5	11.7	10.8	9.6	9.0	(29)
(30)			MCDB	8.4	8.0	8.1	8.6	10.4	11.1	13.1	12.8	11.8	10.9	9.7	9.0	(30)
(31)		5%	WB	7.7	7.4	7.5	8.0	9.2	10.3	12.1	12.0	11.5	10.5	9.2	8.5	(31)
(32)			MCDB	7.9	7.6	7.7	8.2	9.5	10.6	12.4	12.2	11.6	10.6	9.3	8.7	(32)
(33)		10%	WB	7.1	6.8	7.0	7.6	8.6	9.9	11.6	11.6	11.2	10.1	8.7	8.0	(33)
(34)			MCDB	7.4	7.2	7.2	7.8	8.9	10.2	11.8	11.8	11.3	10.3	8.9	8.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	2.6	2.4	2.6	2.7	2.6	2.2	2.0	1.9	1.8	2.1	2.3	2.6	(35)
(36)			MCDBR	3.1	2.6	2.6	2.5	3.2	2.7	2.7	2.3	1.8	1.8	2.1	2.7	(36)
(37)			MCWBR	3.7	3.1	2.7	2.5	2.4	2.2	2.2	2.0	1.8	2.1	2.7	3.4	(37)
(38)		5% WB	MCDBR	3.1	2.5	2.4	2.2	2.7	2.3	2.5	2.0	1.8	1.8	2.1	2.7	(38)
(39)			MCWBR	3.8	3.1	2.8	2.5	2.3	2.0	2.2	1.8	1.8	2.1	2.8	3.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.316	0.345	0.357	0.378	0.367	0.361	0.367	0.357	0.359	0.338	0.303	0.382	(40)	
(41)		taud	2.062	2.206	2.310	2.299	2.404	2.466	2.471	2.498	2.423	2.313	2.110	2.388	(41)	
(42)		Ebn at Noon	355	605	753	810	855	867	852	831	750	612	367	227	(42)	
(43)		Edh at Noon	42	70	87	106	103	99	96	87	78	61	39	26	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.20	0.68	1.74	3.25	4.60	4.93	4.39	3.58	2.18	0.97	0.29	0.12	(44)	
(45)		RadStd	0.02	0.08	0.15	0.25	0.42	0.48	0.30	0.32	0.15	0.10	0.03	0.01	(45)	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)	+0.51	+1.14	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+30	N/A

Nomenclature: See separate page