

KIRKJA, Faroe Islands

WMO: 060120

Lat: 62.319N

Lon: 6.321W

Elev: 184

StdP: 14.60

Time Zone: 0.00 (EUW)

Period: 01-16

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	25.6	28.8	N/A	N/A	N/A	N/A	N/A	N/A	39.7	41.5	33.6	41.4	10.1	340	0.753

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.1	59.4	N/A	57.8	N/A	56.6	N/A	N/A	N/A	N/A	N/A	N/A	N/A	8.6	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 33.8	29.5	25.8	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	45.2	40.3	40.4	40.7	42.2	44.4	48.7	49.6	52.6	51.7	46.8	43.6	41.4
	DBStd	6.29	4.37	5.06	4.56	4.35	4.10	3.21	7.33	2.33	3.00	4.51	5.10	4.91
	HDD50	1999	300	268	290	236	179	60	68	4	17	115	194	268
	HDD65	7221	765	688	755	684	639	489	478	385	400	565	641	732
	CDD50	255	0	0	0	2	5	21	56	84	67	15	4	1
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	11.0	13.2	12.3	12.0	10.8	10.1	8.7	8.8	8.8	8.2	9.9	14.1	15.2
Precipitation	PrecAvg	88.7	10.7	8.1	8.5	6.6	4.9	3.8	3.8	5.2	7.8	9.6	10.2	9.6
	PrecMax	104.4	18.0	14.8	13.0	10.0	13.2	7.2	6.8	9.9	13.9	16.4	14.3	15.5
	PrecMin	71.3	6.5	3.6	4.4	3.3	1.5	1.4	0.9	2.6	3.0	5.0	6.0	4.2
	PrecStd	8.2	2.5	2.6	2.3	1.9	2.3	1.6	1.2	1.9	2.8	2.7	2.4	3.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.2	52.1	52.3	58.9	59.4	60.9	62.3	62.5	59.9	57.1	56.5	53.9
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	49.6	50.6	49.2	51.2	54.7	56.6	58.0	58.8	58.5	55.1	54.2	52.0
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	47.8	48.9	47.5	49.1	51.5	54.4	56.6	56.9	57.4	53.5	51.8	49.8
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	46.1	47.0	46.2	47.6	49.5	52.9	55.4	55.6	56.1	52.2	50.0	47.8
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	5.5	5.4	5.7	5.7	5.8	5.2	4.8	5.1	5.3	5.3	5.9	6.1
		MCDBR	8.3	7.5	7.5	6.9	8.3	7.5	6.7	6.8	7.2	6.5	9.7	8.9
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.302	0.343	0.354	0.376	0.369	0.361	0.364	0.358	0.358	0.337	0.295	0.378	
	taud	2.058	2.196	2.307	2.298	2.390	2.461	2.476	2.494	2.419	2.296	2.083	2.373	
	Ebn at Noon	105	186	237	256	269	274	270	262	235	188	105	58	
	Edh at Noon	12	21	27	33	33	31	30	27	24	19	11	7	
All-Sky Solar Radiation	RadAvg	51	185	508	963	1371	1479	1337	1069	644	277	74	29	
	RadStd	5	21	47	78	101	143	85	105	46	23	8	1	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	+0.92	+2.05	N/A	N/A	N/A	N/A	N/A	N/A	+54	N/A

Nomenclature: See separate page